

(LOT 3)

38-44 CARTER STREET

SHAW-WALKER
STENOGRAPHERS
87201-JR

CITY OF PORTLAND, MAINE

Application for Permit to Install Wires

Permit No. 56199
 Issued 8/11/70
 Portland, Maine Aug 11, 1970

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee \$1.00)

Owner's Name and Address C. H. Hanson & Sons Tel. _____
 Contractor's Name and Address J. W. Cassidy Tel. _____
 Location 38 Carter St Use of Building _____
 Number of Families CARON Apartments _____ Stores _____ Number of Stories _____
 Description of Wiring: New Work _____ Additions _____ Alterations _____
 Pipe _____ Cable _____ Metal Molding _____ BX Cable _____ Plug Molding (No. of feet) _____
 No. Light Outlets _____ Plugs _____ Light Circuits _____ Plug Circuits _____
 FIXTURES: No. _____ Fluor. or Strip Lighting (No feet) _____
 SERVICE: Pipe _____ Cable _____ Underground _____ No. of Wires _____ Size _____
 METERS: Relocated _____ Added _____ Total No. Meters _____
 MOTORS: Number _____ Phase _____ H. P. _____ Amps _____ Volts _____ Starter _____
 HEATING UNITS: Domestic (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Commercial (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Electric Heat (No. of Rooms) _____
 APPLIANCES: No. Ranges _____ Watts _____ Brand Feeds (Size and No.) _____
 Elec. Heaters _____ Watts _____
 Miscellaneous _____ Watts _____
 Transformers _____ Air Conditioners (No. Units) _____ Extra Cabinets or Panels _____
 Will commence _____ 19 _____ Ready to cov. r in _____ 19 _____ Signs (No. Units) _____
 Amount of Fee \$.. 1.00 Inspection Aug 11 19 70

Signed J. W. Cassidy

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND	
VISITS: 1	2	3	4
..... 7	8	9	10
REMARKS: 11	12	

CO 202

INSPECTED BY [Signature]
 (OVER)

LOCATION *Caron ST 38*
 INSPECTION DATE *5/14/70*
 WORK COMPLETED *5/14/70*
 TOTAL NO. INSPECTIONS
 REMARKS:

FEEES FOR WIRING PERMITS EFFECTIVE JULY 31, 1968

WIRING	
1 to 30 Outlets	\$ 2.00
31 to 60 Outlets	3.00
Over 60 Outlets, each Outlet	.05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	
SERVICES	
Single Phase	2.00
Three Phase	4.00
MOTORS	
Not exceeding 50 H.P.	3.00
Over 50 H.P.	4.00
HEATING UNITS	
Domestic (Oil)	2.00
Commercial (Oil)	4.00
Electric Heat (Each Room)	.75
APPLIANCES	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Built-in Dishwashers, Dryers, and any permanent built-in appliance — each unit	1.50
MISCELLANEOUS	
Temporary Service, Single Phase	1.00
Temporary Service, Three Phase	2.00
Circuses, Carnivals, Fairs, etc.	10.00
Meters, relocate	1.00
Distribution Cabinet or Panel, per unit	1.00
Transformers, per unit	2.00
Air Conditioners, per unit	2.00
Signs, per unit	2.00
ADDITIONS	
5 Outlets, or less	1.00
Over 5 Outlets, Regular Wiring Rates	



(RAY BUILDING ZONE - A)

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, May 20, 1957

PERMIT ISSUED

MAY 24 1957
00686

CITY OF PORTLAND
OFFICE OF PERMITS

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect ~~and repair~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 3 Carter Street (38-44) Within Fire Limits? Dist. No. _____

Owner's name and address Glendon C. Strout, 76 Edgewood Ave. Telephone _____

Lessee's name and address _____ Telephone _____

Contractor's name and address OWNER Telephone _____

Architect _____ Specifications _____ Plans _____ Telephone _____

Proposed use of building Dwelling No. of sheets _____

Last use _____ No. families 1

Material _____ No. stories _____ Heat _____ Style of roof _____ No. families _____

Other building on same lot _____ Roofing _____

Estimated cost \$ 15,000. Fee \$ 15.00

General Description of New Work

To construct 2-1 story frame dwelling (split level) 24'x42' and garage

The inside of the garage will be covered, where required by law, with rock lath and plaster - solid wood door 1 3/4" thick fire door.

Permit Issued with Letter

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work? yes

Is any electrical work involved in this work? yes

Is connection to be made to public sewer? no If not, what is proposed for sewage? septic

Has septic tank notice been sent? yes Form notice sent? yes

Height average grade to top of plate 10' - 14' Height average grade to highest point of roof 15' - 19'

Size, front _____ depth _____ No. stories 1-2 solid or filled land? solid earth or rock? earth

Material of foundation concrete existing Thickness, top _____ bottom _____ cellar _____

Material of underpinning _____ Height _____ Thickness _____

Kind of roof pitch Rise per foot 5" Roof covering asphalt roofing Class C Und. Lab. _____

No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat oil fuel oil

Framing Lumber—Kind hemlock Dressed or full size? dressed Corner posts 4x6 Sills 4x6

Size Girder yes 6x10 Columns under girders 6x6 Jolly Size 2 1/2" Max. on centers 6'5"

Kind and thickness of outside sheathing of exterior walls? 1" boards

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd 2x6 ceiling, roof 2x8

O. centers: 1st floor 16", 2nd 16", 3rd 16", roof 24"

Maximum span: 1st floor 12', 2nd 12', 3rd _____, roof 12' height?

If a Garage

No. cars now accommodated on same lot _____, to be accommodated 1 number commercial cars to be accommodated no

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will work require disturbing of any tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

with letter by agf

Signature of owner *agf*

REJECTION COPY

May 23, 1957

AP Lot 3 Carter Street

Mr. Glendon C. Strout
76 Edgewood Avenue

Copy to L. O. Andrew
Brighton Ave.

Dear Mr. Strout:-

Building permit for construction of a single family dwelling with one-car garage in basement is issued herewith based on plan filed with application for permit, but subject to the following conditions as agreed upon by Mr. Munson Strout:-

1. Sills around the entire perimeter of the building are to be 4x6 anchored to the foundation wall at the corners and at intervals of not over 6 feet between corners.
2. Studs in side and rear walls of higher section are to extend down to the double 2x4 girts and are not to be supported on shoes on top of floor timbers. Corner posts of this section are to extend in one length from sill to plate level.
3. Floor of garage section is to be at least 6 inches lower than that in other part of cellar.
4. Header over large window opening in front wall of living room is to be no less than 4x10 dressed Douglas Fir.
5. All other openings over 3 feet wide in walls and bearing partitions are to have 4x6 headers.

Very truly yours,

Albert J. Sears
Deputy Inspector of Buildings

AJS/O

(COPY)



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

Issued to **Glendon C. Strout**

LOCATION **Lot 3 Carter Street**

Date of Issue **October 21, 1957**

This is to certify that the building, premises, or part thereof, at the above location, built ~~under~~ ~~change of use~~ under Building Permit No. **57/686**, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

Limiting Conditions:

APPROVED OCCUPANCY

1-family dwelling

This certificate supersedes
certificate issued

Approved:

(Date)

Earle Smith
Inspector

W. A. ...
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, August 8, 1957

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location of ~~appliance~~ *at Carter St. (3844)* Use of Building dwelling No. Stories 1 ~~New Building~~ Existing "
 Name and address of owner of appliance Glendon Strout, 76 Edgewood Ave.
 Installer's name and address Pallotta Oil Co., 112 Exchange St. Telephone A-2671

General Description of Work

To install forced hot water boiler and oil burning equipment

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
 If so, how protected? no Kind of fuel? oil
 Minimum distance to burnable material, from top of appliance or casing top of furnace 40"
 From top of smoke pipe 20" From front of appliance over 2' From sides or back of appliance over 4'
 Size of chimney flue 8x8 Other connections to same flue none
 If gas fired, how vented? Rated maximum demand per hour
 Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Columbia Labelled by underwriters' laboratories? yes
 Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
 Type of floor beneath burner cement Size of vent pipe 1 1/2"
 Location of oil storage basement Number and capacity of tanks 1-275 gal.
 Low water shut off Make No.
 Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
 Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
 If so, how protected? Height of Legs, if any
 Skirting at bottom of appliance? Distance to combustible material from top of appliance?
 From front of appliance From sides and back From top of smokepipe
 Size of chimney flue Other connections to same flue
 Is hood to be provided? If so, how vented? Forced or gravity?
 If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

.....

Amount of fee enclosed? \$2.00 (\$3.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:
 O.K. E.S.S. 8/8/57

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Pallotta Oil Co.

By:

S. J. Pallotta #13

Signature of Installer

INSPECTION COPY

7 ags.

CITY MAINE PRINTING CO



CE - A
APPLICATION FOR PERMIT

Class of Building or Type of Structure. Foundation

Portland, Maine, May 8, 1957

PERMIT 1957
MAY 08 1957
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect ~~and repair~~ ~~and~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location . . . Lot 3. Garter St. (28.44) Within Fire Limits? Dist. No.
 Owner's name and address Glendon C. Strout, 76 Edgewood Ave. Telephone 5-1623
 Lessee's name and address Telephone
 Contractor's name and address owner Telephone
 Architect Specifications Plans **yes** No. of sheets **1**
 Proposed use of building No. families
 Last use No. families
 Material No. stories Heat Style of roof Roofing
 Other building on same lot Fee \$ **1.00**
 Estimated cost \$

General Description of New Work

For excavation and construction of foundation only

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work Is any electrical work involved in this work?
 Is connection to be made to public sewer? If not, what is proposed for sewage?
 Has septic tank notice been sent? Form notice sent?
 Height average grade to top of plate Height average grade to highest point of roof
 Size, front depth No. stories solid or filled land? earth or rock?
 Material of foundation concrete at least 4' below grade Thickness, top 10" bottom 10" cellar
 Material of underpinning Height Thickness
 Kind of roof Rise per foot Roof covering
 No. of chimneys Material of chimneys of lining Kind of heat fuel
 Framing Lumber—Kind Dressed or full size? Corner posts Sills
 Size Girder Columns under girders Size Max. on centers
 Kind and thickness of outside sheathing of exterior walls?
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor , 2nd , 3rd , roof
 On centers: 1st floor , 2nd , 3rd , roof
 Maximum span: 1st floor , 2nd , 3rd , roof
 If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will work require disturbing of any tree on a public street? **no**
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? **yes**

Glendon C. Strout

APPROVED:
OR-5/9/57-928

INSPECTION COPY Signature of owner By: *Glendon C. Strout*

NOTES

5/17/57 - Home imp
res. at 88
5/29/57 - Spec.
Construction permit
issued - 5/28/57

Permit No. 57/613

Location

Owner

Date of permit

Notif. closing-in

Inspr. closing-in

Final Notif

Final Inspn.

Cert. of Occupancy issued

Slaking Out Notice

Form Check No.

5/19/57 - 1.30 PM