

16-22 Caron St. (lot #18)

SHAW-WALKER
2203-111

PERMIT TO INSTALL PLUMBING

Date Issued **7-24-78**
 Portland Plumbing Inspector
 By ERNOLD R GOODWIN

App. First Insp.
 Date
 By

App. Final Insp.
 Date
 By

Type of Bldg.
 Commercial
 Residential
 Single
 Multi Family
 New Construction
 Remodeling

Address 20 Caron Street		PERMIT NUMBER 1658		
Installation For one family				
Owner of Bldg one family				
Owner's Address W. McGee				
Plumber base		Date 7-24-78		
NEW	REPL	Homeowner	NO	
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS FLOOR SURFACE		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS		
		GARBAGE DISPOSALS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS	1	2.00
		AUTOMATIC WASHERS		
		DISHWASHERS		
		OTHER base fee		3.00
TOTAL				5.00

JUL 31 1978
 ERNOLD R. GOODWIN
 CIVIL PL.

Building and Inspection Services Dept.: Plumbing Inspection



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

PERMIT ISSUED 00164 FEB 19 1958

Portland, Maine, Feb. 14, 1958

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 20 Caron Street Lot 18 Use of Building Residence No. Stories 1 XNew Building Existing " Name and address of owner of appliance Mr. Olaf H. Adler RFD #5, Box 225 Portland Installer's name and address Ballard Oil & Equipment Co. Telephone

General Description of Work

To install oil fired forced hot water heating system

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? None If so, how protected? Kind of fuel? #2 oil Minimum distance to burnable material, from top of appliance or casing top of furnace 30" From top of smoke pipe 2 1/2" From front of appliance 5' From sides or back of appliance 5' Size of chimney flue 8 X 8 Other connections to same flue None If gas fired, how vented? Rated maximum demand per hour 1.0 GPH Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes

IF OIL BURNER

Name and type of burner Ballard Gun Type Model B-3-9 Labelled by underwriters' laboratories? Yes Will operator be always in attendance? No Does oil supply line feed from top or bottom of tank? Bottom Type of floor beneath burner Concrete Size of vent pipe 1 1/4" Location of oil storage Basement Number and capacity of tanks 1-275 Low water shut off Not required Make No Will all tanks be more than five feet from any flame? Yes How many tanks enclosed? None Total capacity of any existing storage tanks for furnace burners None

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Height of Legs, if any Skirting at bottom of appliance? Distance to combustible material from top of appliance? From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

New construction

Amount of fee enclosed? \$2.00 (\$3.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Ballard Oil & Equipment Co.

MAINE PRINTING CO.

INSPECTION COPY

Signature of Installer Richard J. Cole, Manager Oil Heating Department

F.M.

City of Portland, Maine
Board of Appeals
—ZONING—

July 23,

57/58
Granted
8/5/57
19 57

To the Board of Appeals:

Your appellant, Olaf Addler, who is the owner of property at ²⁰18 Caron Street, respectfully petitions the Board of Appeals of the City of Portland to permit an exception to the regulations of the Zoning Ordinance relating to this property, as provided by Section 18 ~~of the~~ said Zoning Ordinance.

Building permit for construction of a one family dwelling house on Lot 18 Caron St. is not issuable under the Zoning Ordinance because the lot contains 10,000 square feet and the Health Department, whose approval is required before such a permit can be issued, reports that the minimum area of lot required to meet the provisions for sewage disposal under Section 18 of the Zoning Ordinance is 13,750 square feet.

The facts and conditions which make this exception legally permissible are as follows:

An exception is necessary in this case to grant reasonable use of property where necessary to avoid confiscation and can be granted without substantially departing from the intent and purpose of the Zoning Ordinance.

Olaf H. Addler
Appellant

After public hearing held on the 2 day of August, 19 57 the Board of Appeals finds that an exception is necessary in this case to grant reasonable use of property and can be granted without substantially departing from the intent and purpose of the Zoning Ordinance.

It is, therefore, determined that exception to the Zoning Ordinance may be permitted in this specific case.

Bern P. Wilson
W. J. ...
...
...
...
BOARD OF APPEALS

W. DONALD
BUILDINGS

ALBERT J. SEARS
DEPUTY INSPECTOR OF BUILDINGS

CITY OF PORTLAND, MAINE

Department of Building Inspection

July 26, 1957

AP Lot 18 Caron St.—Proposed new dwelling and lot size insufficient to satisfy the requirements of the sewage disposal and zoning appeal relating thereto

Mr. Olaf Addler
5 R. F. D.
Portland, Maine

Copy to Corporation Counsel

Dear Mr. Addler,

Building permit for construction of a one family dwelling house on Lot 18 Caron St. is not issuable under the Zoning Ordinance because the lot contains 10,000 square feet and the Health Department, whose approval is required before such a permit can be issued, reports that the minimum area of lot required to meet the provisions for sewage disposal under Section 18 of the Zoning Ordinance is 13,750 square feet.

You have indicated your desire to seek an exception from the Zoning Board of Appeals; so, there is enclosed an outline of the appeal procedure.

Very truly yours,

Warren McDonald
Inspector of Buildings

WMcD/B

Enc: Outline of appeal procedure

C
O
P
Y

July 30, 1957

Mr. Olaf Addler
5 R. F. D.
Portland, Maine

Dear Mr. Addler:

August 2, 1957,

Ben B. Wilson

AP - Lot #18 Caron Street

August 7, 1957

Mr. Olaf H. Adler,
RFD #5
Portland, Maine

Dear Mr. Adler:

Appeal under the Zoning Ordinance having been sustained, building permit for construction of a single family dwelling with attached garage at the above named location is issued herewith based on revised plans filed August 5, 1957, but subject to the following conditions:

1. Anchors from floor and ceiling timbers are to be no less than $1\frac{1}{2}$ inches by $\frac{3}{8}$ inches by 16 inches long, are to be fastened to bottoms of timbers, and where joists run parallel to wall are to be long enough to engage three joists.
2. If metal covered fire door is used in opening in masonry wall between garage and rest of building, frame in which it is hung is required to be of all metal construction. If desired, a solid core plywood door at least $1\frac{3}{4}$ inches thick may be used, in which case an ordinary wood frame can be used. In any case this door is required to be equipped with a self-closing device.
3. Ceiling beams or ties across garage are to be hung at the center to the ridge of the roof.
4. We understand that gable end walls are to be made of wood construction with 2x4 studs spaced 16 inches on centers and covered with the usual boarding and weatherboarding. The permit is issued on this basis.
5. Care is to be taken to make sure that floor of entry between garage and dwelling is at least six inches higher than floor of garage.

Very truly yours,

Albert J. Sears
Deputy Inspector of Buildings.

AJS/H

Mr. Wink

CITY OF PORTLAND, MAINE
Department of Building Inspection
NOTICE RELATING TO SEWAGE DISPOSAL

(date) July 25, 1957

RECEIVED
JUL 26 1957
DEPT. OF BLDG. INSP.
CITY OF PORTLAND

X means copy sent to the parties
so marked

Job Data

Location Lot 18 Caron Street Description New Dwelling & Garage
Owner and Address Olaf Adler, RFD #5, Portland
Contractor and Address Same
Architect or Engineer and Address _____

Application for a building permit for the above job indicates that no connection is possible to a public sewer. In such a case the Building Code directs that the proposed method of sewage disposal shall be approved by the Director of Health before the building permit may be issued.

It is necessary that the owner or his agent contact the Health Department, explain the proposed method of sewage disposal, and make arrangements for any tests the Director of Health deems essential as to the nature of the soil and other features under the supervision of that department.

The 1957 revision of the Zoning Ordinance of the City sets up a formula for determining the minimum area of lot required for septic tank disposal systems, and one of the factors in that formula is the number of bedrooms in the building in question. If the correct number of bedrooms has not been stated on the plans or application for the building permit, it is important that you inform the Health Department of the correct number of bedrooms proposed, so that the formula may be worked.

Two copies to Health Director

Walter W. Donald
Inspector of Buildings

(This space for Health Department use)

No. of bedrooms reported to Building Dept. 3

(a)—total lot width 74 feet (b)—maximum depth of building 25 feet

Inspector of Buildings:

(Date) 26 July 1957

The method of sewage disposal proposed for above job is is not approved.

Minimum area of lot required for septic tank disposal system as determined from use of formula stipulated by Section 18 of the Zoning Ordinance is 3750 sq. ft., based on the owner's stated intention to have 3 bedrooms.

Edmund [Signature]
Director of Health

July 26, 1957

AP Lot 18 Caron St.—Proposed new dwelling and lot size insufficient to satisfy the requirements of the sewage disposal and zoning appeal relating thereto

Copy to Corporation Council

Mr. Olaf Addler
5 R. F. D.
Portland, Maine

Dear Mr. Addler,

Building permit for construction of a one family dwelling house on Lot 18 Caron St. is not issuable under the Zoning Ordinance because the lot contains 10,000 square feet and the Health Department, whose approval is required before such a permit can be issued, reports that the minimum area of lot required to meet the provisions for sewage disposal under Section 18 of the Zoning Ordinance is 13,750 square feet.

You have indicated your desire to seek an exception from the Zoning Board of Appeals; so, there is enclosed an outline of the appeal procedure.

Very truly yours,

Warren McDonald
Inspector of Buildings

WMcD/B

Enc: Outline of appeal procedure

AP - Lot 18 Caron Street

July 26, 1957

Mr. Olaf H. Adler,
RFD #5
Portland, Maine

Mr. Charles E. Jackson
74 Hamblet Ave.

Gentlemen:

While awaiting report from Health Department on sewage disposal facilities for proposed dwelling at the above named location, we have examined plans filed with application for permit and found variances from and questions as to compliance with Building Code requirements as listed below. Before a permit can be issued it is necessary that revised plans showing compliance with requirements be filed for checking and approval. Details in question are as follows:

1. The estimated cost of \$10,000 given seems somewhat small for a masonry building of the size contemplated. This estimate is supposed to include excavation, general construction, plumbing, heating, electrical work and all other built-in construction and equipment considered a part of the completed building. Second hand materials, labor or materials furnished to owner without cost and materials on hand, as well as your own labor, must be figured at current market prices. In the light of this information please revise estimated cost and pay adjusted permit fee.
2. What is maximum overhang of eaves on front of building to be? On basis of information shown on plans overhang would be about three feet instead of two feet eight inches shown and require a set back from street line of 26 feet instead of the 25 feet eight inches indicated.
3. Is there to be any masonry over openings in concrete block bearing wall in cellar? If not, plate on top of the wall needs to be made thicker over openings and angle iron lintels will not be needed. We do not understand, in any case, how the three pieces of angle iron specified for use over each opening can be used effectively in an eight inch concrete block wall.
4. What is size of anchors from floor timbers to masonry walls? Indication needs to be made that where joists run parallel to walls, anchors are to be long enough to engage three timbers.
5. A statement of design (blank copy enclosed) is required for steel lintels. This is required to be signed by some person qualified to figure out what is needed. Sizes of lintels indicated appear to be

Not corrected?

O.H.

OK

OK

Should be
1/2" x 1/2" x 11"
1/2" x 1/2" x 12"

OK

July 29, 1957

Adler
Allen E. Jackson → 2

...of what is needed and it is not clear how the shapes specified can be used effectively. Is there to be any masonry above door and window openings anyway? If not, loads across openings can probably be taken care of by increasing size of woodplates.

6. Plans call for 12 inch poured concrete foundation wall while application indicates the use of concrete blocks of unindicated thickness. Which is right and, if blocks are to be used, what is their thickness to be?

7. What kind of fire doors are to be used at entrances to dwelling from garage? If metal covered doors are used, all metal frames are required. Indication needs to be made that doors will be equipped with self-closing devices.

8. The eight inch concrete block foundation wall between garage and cellar of dwelling is not allowable.

9. Is top of wall at side and end of cellar stairs and platform at entrance to kitchen to be at least six inches higher than garage floor, as required?

10. How are ceiling joists or ties across garage to be supported at center?

11. The 2x5 rafters and ceiling timbers indicated in application in place of 2x6 on plan are not acceptable.

12. Width of "cheeks" of fireplace does not meet Building Code requirements.

13. Are there to be supporting studs between sections of mullion windows?

14. Indication needs to be made that anchors similar to those at floor level are to be provided from gable end walls to bottom of ceiling timbers.

Very truly yours,

Albert J. Sears
Deputy Inspector of Buildings

AJS/H

12" Now OK
OK
Not measured?
OK
OK
Size?

(COPY)



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 18 Caron St.

Issued to **Olef Adler**

Date of Issue **June 9, 1958**

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. **57/1167**, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Article

APPROVED OCCUPANCY

1-family dwelling house

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

(Date)

Carl Smith
Inspector

Walter J. Donald
Inspector of Buildings

CS 147
CS 147

Notice: This certificate is for the use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



RI RESIDENCE ZONE

PERMIT ISSUED
01107
AUG 7 1957

APPLICATION FOR PERMIT

Class of Building or Type of Structure masonry
Portland, Maine, July 22, 1957

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect ~~alter repair demolish~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 2018 Caron Street (Lot #18) Within Fire Limits? Yes Dist. No. 8-1111

Owner's name and address Olaf Adler, R. F. D. 5 Portland, Me. Telephone Va 9-5977

Lessee's name and address _____ Telephone _____

Contractor's name and address owner Telephone _____

Architect _____ Specifications Yes Plans Yes No. of sheets 3

Proposed use of building 1-story dwelling and attached garage No. families 1

Last use brick No. families 1

Material cinder blocks stories 1 Heat hot water Style of roof pitch Roofing asphalt

Other buildings on same lot _____

Estimated cost \$ 10,000 Fee \$ 10.00
4,000 General Description of New Work 4.00
14,000 14.00

To construct 1-story masonry dwelling and attached garage as per plan
59' x 24' 8"
3 Bedrooms

Permit Issued with Letter

Appeal date 8/5/57

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? septic tanks
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate 10' Height average grade to highest point of roof 15'
Size, front 59' depth 24' 8" No. stories 1 solid or filled land? solid earth or rock? earth
Material of foundation concrete blocks at least 4' below grade Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof pitch Rise per foot 5" Roof covering asphalt Class C Und. Lab. _____
No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat hot water fuel oil
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. cu centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x8, 2nd 2x6, 3rd _____, roof 2x6
On centers: 1st floor 16", 2nd 16", 3rd _____, roof 16"
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof 12' 4"
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated 1 number commercial cars to be accommodated 0
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous


Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining to safety are observed? yes

APPROVED:
With letter by OJF

NOTES

8/19/57 - Form map made E & S
 8/26/57 - Laying concrete blocks. E. & S.
 9/19/57 - Blocks laid up 3' high - E. & S.
 10/25/57 - Laying blocks progressively away from
 11/19/57 - Same, EB
 12/14/57 - Laid wood over Cinder block wall could be used between garage and house.
 1/15/58 - Moors around E & S
 1/23/58 - Left G.T. to class in morning of dumb. to be covered until next approval
 2/14/58 - in dry weather
 3/19/58 - Movable 6 feet in
 5/17/58 - Fixing tub. E. & S.
 6/11/58 - Man over and so at tub. side of right
 Cert. to be issued E. & S.

Permit No. 1123154
 Date of permit 6/12/57
 Inspn closing-in 1/22/58
 Notif. closing-in
 Final Notif. 1/23/58
 Total Inspn. 1/23/58
 Cert. of Occupancy issued 6/19/58 W.C.P.
 Staking Out Notice
 Form Check Notice



PERMIT # 00032 CITY OF Portland BUILDING PERMIT APPLICATION

MAP # _____ LOT# _____

(Please fill out any part which applies to job. Proper plans must accompany form.)
 Name: David L. and Cora B. Eyer

Address: 20 Caron St., Portland, 04103

LOCATION OF CONSTRUCTION: 20 Caron Street

CONTRACTOR: EYCO Construction SUBCONTRACTORS 757-5983

ADDRESS: 20 Caron St., Portland

Est. Construction Cost: \$1,800 Type of Use: Single Family

Building Dimensions: L. _____ W. _____ St. Ft. _____ Stories: _____ Lot Size: _____

Proposed Use: _____ Seasonal: _____ Condominium: _____ Apartment: _____

Conversion: Constructing new addition to garage

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE
 Residential Dwellings Only: _____ # of New Dwelling Units: _____

Foundation:
 1. Type of Soil: _____
 2. Set Backs - Front _____ Rear _____ Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 5. Other: _____

Floors:
 1. Joist Size: _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lally Column Spacing: _____ Size _____
 4. Joist Spacing: _____ Spacing 16" O.C.
 5. Framing Type: _____ Size _____
 6. Floor Sheathing Type: _____ Size _____
 7. Other Material: _____

Exterior Walls:
 1. Studding Size: _____ Spacing _____
 2. No. windows _____
 3. No. Doors _____
 4. Header Sizes: _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size: _____
 7. Insulation Type: _____ Size _____
 8. Sheathing Type: _____ Size _____
 9. Siding Type: _____ Weather Exposure _____
 10. Masonry Materials: _____
 11. Metal Materials: _____

Interior Walls:
 1. Studding Size: _____ Spacing _____
 2. Header Sizes: _____ Span(s) _____
 3. Wall Covering Type: _____
 4. Fire Wall if required: _____
 5. Other Materials: _____

For Official Use Only

Date: June 23, 1988 Subdivision: Yes / No _____
 Inside Fire Lapse: _____ Name: _____
 Bid Code: _____ Block: _____
 Time Limit: _____ Permit Expiration: _____
 Estimated Cost: \$1,800 Owner: _____ Public _____ Private _____
 Value/Structure: _____
 Fee: \$55.00 JUL 11 1988

Ceiling:
 1. Ceiling Joists Size: _____
 2. Ceiling Strapping Size: _____ Spacing _____
 3. Type Ceilings: _____
 4. Insulation Type: _____ Size _____
 5. Ceiling Height: _____

Roof:
 1. Truss or Rafter Size: _____ Spacing _____
 2. Sheathing Type: _____ Size _____
 3. Roof Covering Type: _____
 4. Other: _____

Chimneys:
 Type: _____ Number of Fire Places: _____

Heating:
 Type of Heat: _____

Electrical:
 Service Entrance Size: _____ Smoke Detector Required: Yes _____ No _____

Plumbing:
 1. Approval of soil test if required: Yes _____ No _____
 2. No. of Tubs or Showers: _____
 3. No. of Flushes: _____
 4. No. of Lavatories: _____
 5. No. of Other Fixtures: _____

Swimming Pools:
 1. Type: _____
 2. Pool Size: _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law

Zoning:
 District: _____ Street Frontage Req. _____ Provided _____
 Required Setbacks: Front _____ Back _____ Side _____

Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shore and Floodplain Mgmt. _____ Special Exemption _____
 Other: _____ (Explain) _____
 Date Approved: _____

Permit Received By: _____

Signature of Applicant: David L. Eyer Date: _____

Signature of CEO: _____ Date: _____

Inspection Dates: _____

PERMIT # 000821 CITY OF Portland BUILDING PERMIT APPLICATION MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: David L. and Norma B. Dyer

Address: 20 Caron St., Portland, 04103

LOCATION OF CONSTRUCTION 20 Caron Street

CONTRACTOR: Dyco Construction SUBCONTRACTORS: 797-5983

ADDRESS 20 Caron St., Portland

Est. Construction Cost: \$3,000 Type of Use: single family

Past Use: _____

Building Dimensions L _____ W _____ Sq Ft. _____ # Stories _____ Lot Size _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Constructing new addition to garage

Conversion - Explain to a single family dwelling as per plan.

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only: _____

Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:

1. Type of Soil: _____

2. Set Backs - Front _____ Rear _____ Side(s) _____

3. Footings Size: _____

4. Foundation Size: _____

5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.

2. Girder Size: _____

3. Lally Column Spacing: _____ Size: _____ Spacing 16" O.C.

4. Joists Size: _____

5. Bridging Type: _____ Size: _____

6. Floor Sheathing Type: _____ Size: _____

7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____

2. No. windows _____

3. No. Doors _____

4. Header Sizes _____ Span(s) _____

5. Bracing: Yes _____ No _____

6. Corner Posts Size _____

7. Insulation Type _____ Size _____

8. Sheathing Type _____ Size _____

9. Siding Type _____ Weather Exposure _____

10. Masonry Materials _____

11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____

2. Header Sizes _____ Span(s) _____

3. Wall Covering Type _____

4. Fire Wall if required _____

5. Other Materials _____

For Official Use Only

Date: June 28, 1988 Subdivision: 11 **ISSUED**

Inside Fire Limits _____ Lot _____

Blgd Code _____ Block: 11 1988

Time Limit _____ Permit Expires _____

Estimated Cost: \$3,000 Ownership: _____ Public _____

Value Structure _____ Private _____

Fee: \$55.00 **City Of Portland**

Ceiling:

1. Ceiling Joists Size: _____

2. Ceiling Strapping Size _____ Spacing _____

3. Type Ceilings: _____

4. Insulation Type _____ Size _____

5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size _____ Span _____

2. Sheathing Type _____ Size _____

3. Roof Covering Type _____

4. Other _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____

2. No. of Tubs or Showers _____

3. No. of Flushes _____

4. No. of Lavatories _____

5. No. of Other Fixtures _____ 00.01

Swimming Pools:

1. Type: _____

2. Pool Size: _____ x _____ Square Footage _____

3. Must conform to National Electrical Code and State Law.

Zoning:

District: R-2 Street Frontage Req: _____ Provided _____

Required Setbacks: Front _____ Back _____ Side _____

Review Required:

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shore and Floodplain Mgmt _____ Special Exception _____

Other: _____ (Explain) _____

Date Approved: June 28, 1988

Permit Received By: _____

PERMIT ISSUED WITH LETTER

Signature of Applicant: _____ Date: _____

Signature of CEO: _____ Date: _____

Inspection Dates: _____

White-Tax Assessor

Yellow-GPCOG

Write Tag - CEO


© Copyright GPCOG 1987

1001 Ms Taylor

20 Caron

PLOT PLAN

7/20 - Nothing yet.
8/20 - "
9/16 - Foundation in OK - attached OK
10/26 - completed OK



FEES (Breakdown From Front)

Base Fee \$ 25.00
Subdivision Fee \$ _____
Site Plan Review Fee \$ _____
Other Fees \$ 10.00
(Explain) _____
Late Fee \$ _____

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS

Signature of Applicant _____

Date _____