

42-44 VERMONT AVENUE



Full cut #920R - Half cut #9202R - Third cut #8203R - Fifth cut #8205R



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Sept. 13, 19 77
 Receipt and Permit number A03193

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 42 Vermont Ave.

OWNER'S NAME: Edina Bane ADDRESS: same

OUTLETS: (number of)

Lights	_____	
Receptacles	_____	FEES
Switches	_____	
Plugmold	_____ (number of feet)	
TOTAL	_____	

FIXTURES: (number of)

Incandescent	_____	
Fluorescent	_____ (Do not include strip fluorescent)	
TOTAL	_____	
Strip Fluorescent, in feet	_____	

SERVICES:

Permanent, total amperes <u>100</u>	_____	3.00
Temporary	_____	

METERS: (number of) 1 _____ .50

MOTORS: (number of)

Fractional	_____	
1 HP or over	_____	

RESIDENTIAL HEATING:

Oil or Gas (number of units)	_____	
Electric (number of rooms)	_____	

COMMERCIAL OR INDUSTRIAL HEATING:

Oil or Gas (by a main boiler)	_____	
Oil or Gas (by separate units)	_____	
Electric (total number of kws)	_____	

APPLIANCES: (number of)

Ranges	_____	Water Heaters	_____
Cook Tops	_____	Disposals	_____
Wall Ovens	_____	Dishwashers	_____
Dryers	_____	Compactors	_____
Fans	_____	Others (denote)	_____
TOTAL	_____		

MISCELLANEOUS: (number of)

Branch Panels	_____	
Transformers	_____	
Air Conditioners	_____	
Signs	_____	
Fire/Burglar Alarms	_____	
Circus, Fairs, etc.	_____	
Alterations to wires	_____	
Repairs after fire	_____	
Heavy Duty, 220v outlets	_____	
Emergency Lights, battery	_____	
Emergency Generators	_____	

INSTALLATION FEE DUE: _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ... DOUBLE FEE DUE: _____

FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____

FOR PERFORMING WORK WITHOUT A PERMIT (304-9) _____

TOTAL AMOUNT DUE: 3.50

INSPECTION: after 1 p. m.
 Will be ready on 9-14, 19 77 or Will Call _____

CONTRACTOR'S NAME: Donald Pinkham

ADDRESS: 121 South St. Gorham

TEL.: 839-4802

MASTER LICENSE NO.: 1572

SIGNATURE OF CONTRACTOR: Donald Pinkham

LIMITED LICENSE NO.: _____

INSPECTOR'S COPY

L # 3034

ELECTRICAL INSTALLATIONS -

Permit Number 03193

Location 412 Vermont St.

Owner Elvira Bane

Date of Permit 9-13-77

Final Inspection 9-15-77

By Inspector Tom Adams

Permit Application Register Page No. 113

INSPECTIONS: Service ✓ by Libby
Service called in 9-14-77

Closing-in _____ by _____
PROGRESS INSPECTIONS: 9-15-77 No access

CODE
COMPLIANCE
COMPLETED recers
DATE 9-15-77

DATE:	REMARKS:
<u>9-14-77</u>	<u>No access</u>

[Faint mirrored text and signatures at the bottom of the page]

CITY OF PORTLAND, MAINE
Application for Permit to Install Wires

Permit No. 54709
 Issued 2/23/21
 Portland, Maine 2/23/21 1921

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address Robert Young & Son Tel. _____
 Contractor's Name and Address Robert Young Tel. _____
 Location at 54 Vermont Ave Use of Building _____
 Number of Families _____ Apartments _____ Stories _____ Number of Stories _____
 Description of Wiring: New Work _____ Additions _____ Alterations _____

Pipe _____ Cable Metal Molding _____ BX Ca _____ Plug Molding (No. of feet) _____
 No. Light Outlets 10 Plugs 20 Light Circuits _____ Plug Circuits 2
 FIXTURES: No. _____ Fluor. or Strip Lighting (No feet) _____
 SERVICE: Pipe _____ Cable Underground _____ No. of Wires 3 Size 2/0 or 1/4
 METERS: Relocated _____ Added _____ Total No. Meters _____
 MOTORS: Number _____ Phase _____ H. P. _____ Amps _____ Volts _____ Starter _____
 HEATING UNITS: Domestic (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Commercial (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Electric Heat (No. of Rooms) _____
 APPLIANCES: No. Ranges Watts 6kw Brand Feeds (Size and No.) 3/4
 Elec. Heaters _____ Watts _____
 Miscellaneous _____ Watts _____ Extra Cabinets or Panels _____
 Transformers _____ Air Conditioners (No. Units) _____ Signs (No. Units) _____
 Will commence 19 Ready to cover in _____ 19 _____ Inspection _____ 19 _____
 Amount of Fee \$ 3.50

will call. Signed Robert Young

DO NOT WRITE BELOW THIS LINE

SERVICE		METER		GROUND	
VISITS: 1	2	3	4	5	6
..... 7	8	9	10	11	12

REMARKS:

INSPECTED BY [Signature]
 (OVER)

LOCATION *VERMONT AV. Act #53*
 INSPECTION DATE *3/25/71*
 WORK COMPLETED *3/25/71*
 TOTAL NO. INSPECTIONS
 REMARKS:

FEE S FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING	\$ 2.00
1 to 30 Outlets ..	3 00
31 to 60 Outlets ..	.05
Over 60 Outlets, each Outlet (Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	
SERVICES	2.00
Single Phase . . .	4.00
Three Phase . . .	
MOTORS	\$ 00
Not exceeding 50 H.P.	4.00
Over 50 H.P. . . .	
HEATING UNITS	2.00
Domestic (Oil)	4.00
Commercial (Oil)75
Electric Heat (Each Room) ..	
APPLIANCES	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Built-in Dishwashers, Dryers, and any permanent built-in appliance — each unit ..	1.50
MISCELLANEOUS	
Temporary Service, Single Phase ..	1.00
Temporary Service, Three Phase ..	2.00
Circuses, Carnivals, Fairs, etc.	10.00
Meters, relocate ..	1.00
Distribution Cabinet or Panel, per unit ..	2.00
Transformers, per unit ..	2.00



(RC) RESIDENCE ZONE - C
APPLICATION FOR PERMIT

PERMIT ISSUED
 60624
 MAY 6 1952
CITY of PORTLAND

Class of Building or Type of Structure Third Class
 Portland, Maine, May 5, 1952

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 42 Vermont Avenue Within Fire Limits? no Dist. No. _____
 Owner's name and address Edina Bane, 42 Vermont Ave. Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address Earle Bane, " Telephone _____
 Architect _____ Specifications _____ Plans no No. of sheets _____
 Proposed use of building Dwelling No. families 1
 Last use " No. families 1
 Material frame _____ No. stories 1 1/2 Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot garage
 Estimated cost \$ 75. Fee \$ 50.

General Description of New Work

To demolish existing rear piazza 5'x7' on dwelling and
 To construct 5'x8' addition on rear of building.

Permit Issued with Memo

CERTIFICATE OF OCCUPANCY
 REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Height average grade to top of plate 10' Height average grade to highest point of roof 12'
 Size, front _____ depth _____ No. stories 1 solid or filled land? solid earth or rock? earth
 Material of foundation cedar posts at least 4' below grade Thickness, top _____ bottom _____ cellar _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof shed Rise per foot 5" Roof covering asphalt roofing Class C Lind Lab.
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing lumber—Kind second-hand Dressed or full size? dressed
 Corner posts 4x4 Sills 4x6 Girt or ledger board? _____ Size _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor 2x5, 2nd _____, 3rd _____, roof 2x4
 On centers: 1st floor 16", 2nd _____, 3rd _____, roof 16"
 Maximum span: 1st floor 5', 2nd _____, 3rd _____, roof 5'
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

Earle B. Bane PH

NOTES

5-11-15 2. Walden St. P.S.

(This section contains a large diagonal scribble across the lined area.)

5/15

Permit No. 5-21624

Location Walden St

Owner Edward Hayes

Date of permit 5/6/52

Notif. closing-in _____

Inspr. closing-in _____

Final Notif. _____


Final Insp. 5/11/52

Cert. of Occupancy issued 5-11-52

(This section contains a large diagonal scribble across the lined area.)

RECEIVED
MAY 5 1952
DEPT. OF BLD'G. INSP.
CITY OF PORTLAND

702



42 Vermont Ave

Memorandum from Department of Building Inspection, Portland, Maine

AP 42 Vermont Ave. --Demolishing existing rear piazza and constructing new addition--


May 6, 1952

Note 4x6 sill is to be set with 6" dimension upright, supported either on top of sill or notched over no less than 2x3 nailing strip spiked to side of sill--not "tee-nailed".

Note requirement for notice, inspection, and approval before any part of inside of walls or any part of ceiling is covered from view.

WMCD/H

(Signed) Warren McDonald
Inspector of Buildings



RECEIVED
SEP 14 1946
DEPT OF E.D.C. INSP.
CITY OF PORTLAND

(RC) RESIDENCE ZONE - C

APPLICATION FOR PERMIT



Class of Building or Type of Structure Third Class

Portland, Maine, September 14, 1946

PERMIT ISSUED

01755
SEP 14 1946

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter ~~repair~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location: 12 Vermont Avenue Within Fire Limits? NO Dist. No. _____

Owner's name and address: Edira L. Bane, 12 Vermont Avenue Telephone _____

Lessee's name and address _____ Telephone _____

Contractor's name and address: Earl Bane, 12 Vermont Avenue Telephone _____

Architect _____ Specifications _____ Plans yes No. of sheets _____

Proposed use of building: Dwelling No. families 1

Last use _____ No. families 1

Material frame No. stories 1 1/2 Heat _____ Style of roof _____ Roofing _____

Other buildings on same lot _____

Estimated cost \$ 10. Fee \$ 50

General Description of New Work

To construct roof over existing rear platform 4'6" x 7'.
To be fastened by brackets.

NOTIFICATION BEFORE LATHING
OR CLOSING-IN IS WAIVED

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? _____ Is any electrical work involved in this work? _____

Height average grade to top of plate _____ Height average grade to highest point of roof _____

Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____ cellar _____

Material of underpinning _____ Height _____ Thickness _____

Kind of roof _____ Rise per foot _____ Roof covering asphalt roofing Class C. Ord. Tab.

No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____

Framing lumber—Kind _____ Dressed or full size? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____

Joists (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: _____ 1st floor _____, 2nd _____, 3rd _____, roof 2x4

On centers: _____ 1st floor _____, 2nd _____, 3rd _____, roof 15"

Maximum span: _____ 1st floor _____, 2nd _____, 3rd _____, roof 4'6"

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

Signature of owner Earl E. Bane

INSPECTION COPY

Permit No. 46/1755

Location 12 Vermont Ave

Owner Carl Greene

Date of permit 9/14/46

Notif. closing-in

Inspn. closing-in

Final Notif.


Final Inspn. 11/8/46

Cert. of Occupancy issue! None

NOTES

11/8/46 - Work done

ELL



sills 4x6
 2 girders 4x6 flat on posts floor to the over yard and sills
 6 in. gaps 4 in. a yard
 corner posts 4 in
 Posts 2x4 - 2 in spacing
 Roof 1/2 pitch
 asphalt Hays on shingles on roof
 Posts under sills 5 ft. space on sides and in 6 ft
 ft on ends.

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for one car garage

at 42 Vermont Avenue

Date 6/15/62

1. In whose name is the title of the property now recorded? Carl E. Bane
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? none at all
3. Is the outline of the proposed work now staked out upon the ground? yes
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? _____
4. What is to be maximum projection or overhang of eaves or drip? 10"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

Wm Carl E. Bane



APPLICATION FOR PERMIT

PERMIT ISSUED

Class of Building or Type of Structure Third Class

Portland, Maine, June 15 1942 JUN 18 1942

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter-install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location: 12 Vermont Avenue Within Fire Limits? no Dist. No. _____
Owner's or Lessee's name and address Earl E. Banc, 12 Vermont Avenue Telephone no
Contractor's name and address Owner Telephone _____
Architect _____ Plans filed yes No. of sheets 1
Proposed use of building 1 car garage No. families _____
Other buildings on same lot _____
Estimated cost \$ 100. Fee \$.50

Description of Present Building to be Altered

Memorandum from Department of Building Inspection, Portland, Maine

42-44 Vermont Ave.- New Garage for Earl E. Banc ---6/18/42

To Owner:

Application and sketch seem somewhat at variance. Application says dirt floor, but note on sketch seems to indicate wood floor as follows: " 2 girders 4"x5" flat on posts floor to be over girder and sills-6 in. posts 4 to a girder."

Permit is issued on basis of a ~~wood~~ dirt floor. No reason why you cannot have a wood floor if you want it, but if you do the framing ought to be straightened out. If you lay the girders with the 4-inch dimension upright (indicated by word "flat") you will not get nearly as much strength as though you set it with the 6-inch dimension upright. The same applies to the sills.

(Signed) Warren McDonald
Inspector of Buildings

the issuing contractor.

Details of New Work

Is any plumbing work involved in this work? no
Is any electrical work involved in this work? no Height average grade to top of plate 9'
Size, front 12' depth 20' No. stories 1 Height average grade to highest point of roof 13'
To be erected on solid or filled land? solid earth or rock? earth
Material of foundation cedar posts Thickness, top 5' 00" bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof pitch Rise per foot 8" Roof covering asphalt roofing Class C Und. Lab.
No. of chimneys no Material of chimneys _____ of lining _____
Kind of heat no Type of fuel _____ Is gas fitting involved? _____
Framing lumber--Kind Spruce or Hemlock Dressed or full size? full size
Corner posts 2x4 Sills 1-6 Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor dirt, 2nd _____, 3rd _____, roof 2x4
On centers: 1st floor _____, 2nd _____, 3rd _____, roof 2x4
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No cars now accommodated on same lot none, to be accommodated 1
Total number commercial cars to be accommodated none
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Signature of owner Wm. Earl E. Banc

INSPECTION COPY

17304



(R) GENERAL RESIDENCE ZONE

APPLICATION FOR PERMIT

PERMIT ISSUED

Class of Building or Type of Structure Third Class

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, June 15, 1942 JUN 18 1942

Building structure equipment in accordance

General Description of New Work

To erect one car frame garage 22' x 20'

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately and in the charge of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? no

Is any electrical work involved in this work? no Height average grade to top of plate 9'

Size, front 12' depth 20' No. stories 1 Height average grade to hip'st point of roof 13'

To be erected on solid or filled land? solid earth or rock? earth

Material of foundation cedar posts Thickness, top 5' 00" bottom cellar

Material of underpinning _____ Height _____ Thickness _____

Kind of roof pitch Rise per foot 2" Roof covering asphalt roofing Class C Ind. Lab.

No. of chimneys no Material of chimneys _____ of lining _____

Kind of heat no Type of fuel _____ Is gas fitting involved? _____

Framing lumber—Kind spruce or hemlock Dressed or full size? full size

Corner posts 4x4 Sills 2x6 Cirt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Status (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor 4x8, 2nd _____, 3rd _____, roof 2x4

On centers: 1st floor _____, 2nd _____, 3rd _____, roof 20"

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot none to be accommodated 1

Total number commercial cars to be accommodated none

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Wm. Earl C. Bane

INSPECTION COPY

17302

Permit No 42/662

Location 42 Vermont St

Owner Carl E. Bang

Date of permit 6/18/42

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. 8/19/42

Cert. of Occupancy issued None

O. W. L. B. NOTES

6/18/42 - Erection OK

7/8/42 - Work well along


OK

7/14/42 - Work OK

Work OK

F. E. CRANDALL
LOTS 895-896 VERMONT AVE

MINIMUM RESEARCH ZONE



VERMONT AVE



ZONE

PERMIT NO. 6073

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

JAN 19 1928

Portland, Maine, January 16, 1928

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lots 895-896 Vermont Avenue Ward 9 Within Fire Limits? No Dist. No. _____
 Owner's or Lessee's name and address F. E. Orndall, Virginia St. Telephone F 9415
 Contractor's name and address Owner Telephone _____
 Architect's name and address _____
 Proposed use of building Dwelling house No. families 1
 Other building on same lot none

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
 Last use _____ No. families _____

General Description of New Work

To erect one family dwelling house

Details of New Work

Size, front 24' depth 54' No. stories 1 Height average grade to highest point of roof 24' 20"
 To be erected on solid or filled land? solid earth or rock? earth
 Material of foundation Concrete Thickness, top 10" bottom 14"
 Material of underpinning Concrete blocks Height 24" Thickness 6"
 Kind of roof Pitch Roof covering Asphalt shingles ^{Hyboroid} Class C Und. Lab.
 No. of chimneys one Material of chimneys brick of lining tile
 Kind of heat one pipe - hot air Type of fuel Coal Distance, heater to chimney 9'
 If oil burner, name and model _____
 Capacity and location of oil tanks _____
 Is gas fitting involved? no Size of service _____
 Corner posts 4x6 Sills 4x6 Girt or ledger board? Girt Size 2-2x1
 Material columns under girders Iron pipe Size 4" Max. on centers 7'
 Studs (outside walls and carrying partitions) 2x1-16" O.C. Girders 6x8 or la.g.r. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
 Joists and rafters: 1st floor 2x8 2nd 3x6 no floor 3rd _____ roof 2x6
 On centers: 1st floor 16" 2nd 20" 3rd _____ roof 24"
 Maximum span: 1st floor 18' 2nd 12' 3rd _____ roof _____
 Is one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____
 Total number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
 Plans filed as part of this application? yes No. sheets 1
 Estimated cost \$ 3000. Fee \$ 1.25
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

INSPECTION COPY

Signature of owner F. E. Orndall

Additional Plans
905 7709
5630

9 Permit No. 2873
Location Lots 895 + 896 Vermont Ave
Owner F. E. Casadall
Date of permit Jan 17/28
Notif. closing-in 4/15/28 4:15 PM
Inspn. closing-in 1/16/28 G.T. C.H.
Final Notif. 5/24/28 10:00
Final Inspn.

Cert. of Occupancy issued

Plumb. + Elect NOTES OK.
5 large cracks in foundation
on final closing-in
1 large crack not out at
Cl. on part
2 cracks in foundation
1/2" x 1/2" x 1/2"

Has Gas, no Tag ~~1/2" x 1/2"~~
~~should~~ from additional fee collected,
Upstairs not used for sleeping at
this date 1/22/28
Due to questionable foundation, trial
Job was not passed by this Dept.
Check off, no certificate
3/8/28 G.T.