

NIGHTOAN AVENUE 406-H-14 & 15

BURNSIDE - AVENUE .

SHAW-WALKER

First cut # 020R Second cut # 9202R Third cut # 0203R Fourth cut # 0203R

72.00

CITY OF PORTLAND, MAINE Application for Permit to Install Wires

Permit No. 58695
Issued 5/10/72

Portland, Maine, 1972

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address *Victor Miranski* Tel.
Contractor's Name and Address *Casper & Kelly* Tel.
Location *250 Burnside Ave.* Use of Building *Residential*
Number of Families *1* Apartments Stores Number of Stories
Description of Wiring: New Work Additions Alterations

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)
No. Light Outlets Plugs Light Circuits Plug Circuits
FIXTURES: No. Fluor. or Strip Lighting (No. feet)
SERVICE: Pipe Cable Underground No. of Wires *3* Size *#2*
METERS: Relocated Added Total No. Meters
MOTORS: Number Phase H. P. Amps Volts Starter
HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.
Commercial (Oil) No. Motors Phase H.P.
Electric Heat (No. of Rooms)

APPLIANCES: No. Ranges Watts Brand Feeds (Size and No.)
Elec. Heaters Watts
Miscellaneous Watts Extra Cabinets or Panels

Transformers Air Conditioners (No. Units) Signs (No. Units)

Will commence . . . 19 Ready to cover in 19 Inspection 19
Amount of Fee \$ *2.00*

Signed *Casper & Kelly*

DO NOT WRITE BELOW THIS LINE

SERVICE METER . . . GROUND
VISITS: 1 2 3 4 5 6
7 8 9 10 11 12

REMARKS:

INSPECTED BY

CS 203

(OVER)



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, April 24, 1969

PERMIT ISSUED
315
APR 24 1969
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 250 Burnside Road Within Fire Limits? _____ Dist. No. _____
Owner's name and address Mr. Murawski, 250 Burnside Road Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address All State Home Improvement Co. 217 Brighton Ave Telephone _____
Architect _____ Specifications _____ Plans _____ No. of sheets _____
Proposed use of building Dwelling No. families 1
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ _____ Fee \$ 5.00

General Description of New Work

To cover outside walls of dwelling with aluminum siding.

Handwritten signature: JWA

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractors

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing Lumber—Kind _____ Dressed or full size? _____ Corner posts _____ Sills _____
Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

Miscellaneous

Will work require disturbing of any trees on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

All State Home Improvement Company

CS 301

INSPECTION COPY

Signature of owner by: Margaret T. Walker

CITY OF PORTLAND, MAINE
Application for Permit to Install Wires

Permit No. **55319**
 Issued
 Portland, Maine **Oct 19**, 19**66**

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address **DARRELL COHIER** Tel. **779 FOWLER**
 Contractor's Name and Address **Murray Bros** **240R ELIZ** Tel. **799 2458**
 Location **250 BURNSIDE AVE** Use of Building **DWELLING**
 Number of Families **1** Apartments Stores Number of Stories
 Description of Wiring: New Work Additions Alterations

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)
 No. Light Outlets Plugs Light Circuits Plug Circuits
 FIXTURES: No. Light Switches Fluor. or Strip Lighting (No. feet)
 SERVICE: Pipe Cable Underground No. of Wires **3** Size **#2**
 METERS: Relocated Added Total No. Meters
 MOTORS: Number Phase H. P. Amps Volts Starter
 HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.
 Commercial (Oil) No. Motors Phase H.P.
 Electric Heat (No. of Rooms)
 150 APPLIANCES: No. Ranges **1** Watts **900W** Brand Feeds (Size and No.)
 Elec. Heaters Watts
 150 Miscellaneous **DRYER** Watts Extra Cabinets or Panels
 Transformers Air Conditioners (No. Units) Signs (No. Units)
 5.00 Will commence **Oct 17, 1966** Ready to cover in 19 Inspection **Oct 20, 1966**
 Amount of Fee \$ **5.00** Signed **Douglas H Murray**

DO NOT WRITE BELOW THIS LINE

SERVICE	<input checked="" type="checkbox"/>	METER	<input checked="" type="checkbox"/>	GROUND	<input checked="" type="checkbox"/>
VISITS: 1	2	3	4	5	6
7	8	9	10	11	12

REMARKS:

INSPECTED BY **FW Ashford**
 (OVER)

Memorandum from Department of Building Inspection, Portland, Maine

250 Burnside Ave.--To construct one story tool house for and by
Walter W. MacLeod--August 29, 1957

Building permit for construction of a one story tool house six feet by nine feet on the lot with your dwelling at 250 Burnside Ave. is issued herewith subject to the following conditions:

1. Use of this building is limited by the Zoning Ordinance to one commonly considered accessory to the dwelling on the lot, such as the storage of garden tools, lawn mower, screens, storm windows, etc. and permit is issued on this basis.
2. The 4x6 sills are to extend around the four walls of the building, are to be all one piece in cross section (not made of two pieces of 2x6), and are to be set with the 6 inch dimension upright.
3. The 2x6 floor joists either are to rest on top of the sills or are to be notched over 2x3 nailing strips spiked to the sides of the sills.

AJS/B

(Signed) Warren McDonald
Inspector of Buildings

CS-27

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for terrace Date 8/20/57
at 250 Burnside Ave

1. In whose name is the title of the property now recorded? Walter W MacLeod.
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? yes
3. Is the outline of the proposed work now staked out upon the ground? yes
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? will call
4. What is to be maximum projection or overhang of eaves or drip? 8"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

Walter W. MacLeod

R3 RESIDENCE ZONE 1551

APPLICATION FOR PERMIT

01211
AUG 28 1957



Class of Building or Type of Structure Third Class
Portland, Maine, August 20, 1957

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, Maine, and specifications, if any, submitted herewith and the following specifications:

Location: 250 Burnside Ave. Within City Limits? Dist. No.
 Owner's name and address Walter W. MacLeod, 250 Burnside Ave. Telephone
 Lessee's name and address Telephone
 Contractor's name and address owner Telephone (2-6988 neighbor)
 Proposed use of building Tool House Specifications Plans yes No. of sheets 2
 Last use No. stories No. families
 Material frame No. stories Heat Style of roof Roofing
 Other building on same lot Dwelling House
 Estimated cost \$ 100.00 Fee \$ 50

General Description of New Work

frame
To construct tool house in rear of dwelling house 6' x 9'.

INSPECTION NOT COMPLETED
5/28/57

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Permit Issued with Memo

Details of New Work

Is any plumbing involved in this work? no Is any electrical work involved in this work? no
 Is connection to be made to public sewer? If not, what is proposed for sewage?
 Has septic tank notice been sent? Form notice sent?
 Height average grade to top of plate 8' Height average grade to highest point of roof 12'
 Size, front 7' depth 10' at least 4' below grade solid or filled land? solid earth or rock? earth
 Material of foundation concrete posts Thickness, top 8" bottom 12" cellar
 Material of underpinning Height Thickness
 Kind of roof pitch Rise per foot 7" Roof covering Asphalt Class C Und. Lab.
 No. of chimneys Material of chimneys Kind of heat fuel
 Framing Lumber—Kind dressed or full size? dressed Corner posts 4x4 Sills 2x6
 Size Girder Columns under girders Size Max. on centers
 Kind and thickness of outside sheathing of exterior walls?
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet
 Joists and rafters: 1st floor 2x6 2nd 3rd roof 2x4
 On centers: 1st floor 16" 2nd 3rd roof 2x4
 Maximum span: 1st floor 7' 2nd 3rd 3'6"
 If one story building with masonry walls, thickness of walls? height

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

Signature of owner by: *Walter W. MacLeod*

Walter W. MacLeod

Walter W. MacLeod

Signature of owner by: *ags*

F.M.

NOTES

8/29/57 - Section 0.15,
S.S.

9/17/57 - work started
S.S.


12/2/57 - fill level -
no further progress
S.S.

2/11/58 - Same E.S.

3/14/58 - No further work
done S.S.

4/14/58 - No further
work done S.S.

12/12
1/12
2/12
3/12
4/12



8/29/57
9/17/57
12/2/57
2/11/58
3/14/58
4/14/58

Permit No. 57/1241
 Location 2100 Burnside Ave.
 Owner Walter W. MacLeod
 Date of permit 8/29/57
 Notif. opening-in
 Inspn. closing-in
 Final Notif.
 Final Inspn
 Cert. of Occupancy issued
 Standing Out Notice
 Form Check Notice

INSPECTION NOT COMPLETED
5/28/58

406-H-14-15-2

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

Room 21, City Hall

Gentlemen:

In connection with the installation of oil burning equipment as indicated in statement below, please sign this statement and return to this office as promptly as possible so that the permit may be issued if everything else is found in order, retaining the copy for your file.

Very truly yours,

(Signed) Warren McDonald
Inspector of Buildings.

1. This statement is to become as much a part of the application for a permit to cover installation of oil burning equipment for A. H. Pakinsaul at Lot 250 Michigan Ave. , as though written on the application form.

2. A switch or other manual control capable of completely stopping flow of oil to the burner will be provided, such device to be so located as to be conveniently reached and operated without being exposed to danger that may exist at or near the burner. If feasible this switch or similar device will be located at or near the top of the cellar stairs. In case the burner is of a type without electrical controls, a quick-closing valve will be provided in the oil supply line so located and arranged that the valve may be manually closed from the top of the cellar stairs, or outside of the room where the burner is located or from outside the building.

3. A quick action, self-closing valve designed to close at 160 to 165 degrees Fahrenheit will be provided in oil supply line.

4. Readily accessible shut-off valves, one of which may be the self-closing valve indicated in No. 3 if capable of manual operation, will be installed in oil supply line near each burner and close to supply tank. Shut-off valves will be installed on each side of oil strainers which are not a part of the oil burner unit or which are connected to oil burner unit without intervening piping or tubing. Shut-off valves will be provided both on the discharge side and the suction side of oil pumps, if any, which pump directly to the burner but which are not a part of the burner unit.

5. If there is to be a shut-off valve in the discharge line of an oil pump, a suitable pressure relief valve will be connected into the discharge line between pump and shut-off valve and arranged to return surplus oil to the storage tank or to by-pass it around the pump.

Gould-Farmer Co. of Maine, Inc.

Installer

(Date) 12/9/41

By W. Allen



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT NO. 1948
Permit No. 1948

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Dec 9, 1941

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 150 Michigan Ave Use of Building dwelling No. Stories 1 New Building Existing "
Name and address of owner of appliance A. H. Pabian 150 Michigan Ave
Installer's name and address Gould-Farmer Co. of Maine, Inc. 70 Free St Telephone 68-187

General Description of Work

To install Oil Burner in steam heating plant

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? yes If not, which story _____ Kind of fuel oil
Material of supports of appliance (conc. etc floor or what kind) concrete
Minimum distance to wood or combustible material, from top of appliance or casing top of furnace, _____
from top of smoke pipe _____ from front of appliance _____ from sides or back of appliance _____
Size of chimney flue _____ Other connections to same flue _____

IF OIL BURNER

Name and type of burner Petro P-4-70 Labeled and approved by Underwriters' Laboratories? yes
Will operator be always in attendance? no Type of oil feed (gravity or pressure) pressure
Location oil storage Basement No. and capacity of tanks 1 - 22.5 gal
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? none

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of Installer Gould-Farmer Co. of Maine, Inc.
H. T. Allen

INSPECTION COPY



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED

0177

Permit No. 2-1933

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, MAY 1 1933

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location - Lots. 249-250 Lincoln Ave Use of Building Dwelling

Name and address of owner A. J. Chavon Inc Ward 8

Contractor's name and address J. K. Kilday & Co. Telephone 7

General Description of Work

To install steam heating plant

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? YES If not, which story 1st Kind of Fuel

Material of supports of heater or equipment (concrete floor or what kind) Concrete base

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 2 ft

from top of smoke pipe 16 ft, from front of heater OVER 4 ft from sides or back of heater 4 ft

Except one side which will be protected with metal lath IF OIL BURNER

Name and type of burner Labeled and approved by Underwriters' Laboratories?

Will operator be always in attendance? Type of oil feed (gravity or pressure)

Location oil storage No. and capacity of tanks

Will all tanks be more than seven feet from any flame? How many tanks fireproofed?

Amount of fee enclosed? 1.01 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor J. K. Kilday & Co

by J. H. Macomber 730

NOTIFICATION BEFORE OCCUPANCY OR CLOSING IS WAIVED. CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED.

#32/029-1

Copy to Mr. Arthur Soule, 15 Dudley Street

February 27, 1933

Mr. James K. Kidder
55 Maine Avenue
Portland, Maine

Dear Sir:

We find that you have installed a heater, or at least partially installed a heater in the new house under construction by Arthur Soule at Lots 249-250 Michigan Avenue, and that you have never applied for a permit to install this heater.

At least once in the past, we have taken the matter up with you of the installation of heating plants without first securing the permit, and I am at a loss to understand why you should show so little cooperation with this department as to again install a heater without a permit.

You are fully aware that we have plenty of authority under the law to proceed against you in this instance. This we have no desire to do. It is not clear any way steps which would be a burrassing for you and troublesome for us should be necessary. This department has always tried to cooperate with you in every way possible, and will continue to do. Under these circumstances, do you not think that you owe us at least the amount of cooperation necessary to see to it that every heater which you install in the future has the permit card on the job before the work is commenced?

It is necessary that you apply for and secure the permit for the heater now installed in the house on Michigan Avenue, and I should like to talk with you concerning this whole situation without delay.

Very truly yours,

Inspector of Buildings.

THI/HC

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for one family dwelling house with one car garage attached
at Lots 249-59 Michigan Avenue Date 5/30/32

1. In whose name in the title of the property now recorded? A. H. Chapman, Inc
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? wood stakes
3. Is the outline of the proposed work now staked out upon the ground? Yes If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? _____
4. What is to be maximum projection or overhang of eaves or drip? 12"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches, and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

A. H. Chapman

PERMIT ISSUED
Permit No. 0999



APPLICATION FOR PERMIT

JUL 1 1982

Class of Building or Type of Structure Third Class

Portland, Maine, July 1, 1982

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 249-50 Michigan Avenue Ward 3 Within Fire Limits? NO Dist. No. _____
 Owner's or Lessee's name and address Arthur Coule, Ludlow Street Telephone _____
 Contractor's name and address Crazer Telephone _____
 Architect's name and address _____
 Proposed use of building swelling house with one car garage attached No. families 1
 Other buildings on same lot NONE
 Plans filed as part of this application? yes No. of sheets 1
 Estimated cost \$ 2500. Garage Fee \$ 1.50

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
 Last use _____ No. families _____

General Description of New Work

To erect one family frame dwelling house with one car garage attached

The inside of the garage will be covered, where required by law, with metal lath and cement plaster

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate _____
 Size, front 37'6" depth 34' No. stories 1 Height average grade to highest point of roof 20'
 To be erected on solid or filled land? solid earth or rock? earth and rock
 Material of foundation concrete Thickness, top 10" bottom 12"
 Material of underpinning concrete blocks Height 24" Thickness 8"
 Kind of Roof Asph. Flt. Shingles Rise per foot 5" Roof covering Asph. Flt. roofing Class C 2nd Lab.
 No. of chimneys one Material of chimneys brick of lining tile
 Kind of heat steam or hot air Type of fuel oil Is gas fitting involved? no
 Corner posts 4x6 Sills 4x6 Girt or ledger board? none Size _____
 Material columns under girders iron columns Size 1/2" Max. on centers 8'
 Studs (outside walls and carrying partitions) 2x4-16" O.C Girders 6x8 or larger Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
 Joists and rafters: 1st floor 2x8 concrete floor in garage 2nd 2x8 inf. 3rd _____, roof 2x8 inf.
 On centers: 1st floor 16" 2nd 24" 3rd _____, roof 24"
 Maximum span: 1st floor 14' 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot none, to be accommodated 1
 Total number commercial cars to be accommodated none
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Arthur Coule

INSPECTION COPY

Oliver T. Sanborn

CHIEF OF FIRE DEPT

Card 9 Permit No. 32/929
 Location 49.50 Michigan Ave.
 Arthur Soule
 Date of permit 7/1/32
 Notif. closing-in 2/21/33 2130
 Closing-in 2/21/33 G.T. O.B.
 Final Inspr. 4/28/33 O.B.
 Cert. of Occupancy issued 4/28/33

NOTES
 6/30/32. Location as attached O.K. O.B.
 7/19/32. Foundation found
 forer not relieved. O.B.
 7/25/32. Same. O.B.
 8/1/32. Forms removed.
 framing not started. O.B.
 8/7/32. Framing not
 started. O.B.
 11/1/32. Same. O.B.
 12/6/32. No change. O.B.
 12/28/32. Laying blocks. O.B.
 1/4/33. Same. O.B.
 1/10/33. First floor framed. O.B.
 1/12/33. Same. O.B.
 Corner posts up and
 rib studding started. O.B.

1/20/33. Framing up plate,
 went over roof framing
 with the South St. 102x8
 hips and 2x6 common
 rafters, these will be
 supported as will the
 hips, as as to break the
 long spar. O.B.
 1/24/33. Putting on gutters
 additional supports to
 be put in roof. O.B.
 1/27/33. No work being
 done. O.B.
 1/31/33. Clapboarding.
 O.B.
 2/4/33. Mr. Soule asked permission
 to put metal lath on garage
 before regular closing or
 inspection, this is to allow
 the party buying the house
 to put on his insulation.
 O.B.
 2/9/33. No work being done.
 O.B.
 2/13/33. No work being done. O.B.
 2/21/33. Mr. Chapman said this
 house is sold. The party
 that bought is insulating
 the outside walls with
 Cabot insulation. O.B.

4/28/33. Coal (blasts) done
 in cellar to be opening
 to keep closed.
 In cellar opening
 under floor to be
 closed in O.B.
 4/28/33 Gas applied for
 by owner. O.B.
 5/3/33. Gas O.B.