

ILAHO STREET 407-E-15-22
408-B-28-34



Fifth cut # 920R - First cut # 0202R - Third cut # 0203R - Fifth cut # 92001



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED
Permit No. 1341

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, July 6, 1941

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooling or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lots 285-292 Idaho Street Use of Building dwelling house No. Stories 2 New Existing

Name and address of owner of appliance G. A. Bratt, Idaho Street

Installer's name and address Harris Oil Co., 17 Main St., So. Portland Telephone 2-8304

General Description of Work

To install Oil Burning Equipment in connection with existing warm air heat

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel oil

Material of supports of appliance (concrete floor or what kind) concrete

Minimum distance to wood or combustible material, from top of appliance or casing top of furnace, 36"

from top of smoke pipe 40" from front of appliance 36" from sides or back of appliance 36"

Size of chimney flue 3x12 Other connections to same flue steam boiler

IF OIL BURNER

Name and type of burner Fluid Heat Labeled and approved by Underwriters' Laboratories? yes

Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) pressure

Location oil storage basement No. and capacity of tanks 1 - 275 gal.

Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? _____

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Harris Oil Co.

Signature of Installer

By

John B. Downie

INSPECTION COPY

CERTIFICATE OF UNDERWRITERS' LABORATORIES
OR CLOSING IN IS WAIVED
EQUIPMENT IS WAIVED

7-95C

Permit No. 41/968

Location Lot 285-292 Selco St.

Owner G. A. Burt

Date of Permit 7/8/41.

Post Card sent _____

INSPECTION NOT COMPLETED
Notif. for Inspn. _____

Approval Tag Issued _____

Oil Burner Check List (date) _____

1. Kind of heat _____
2. Label _____
3. Anti-siphon _____
4. Oil storage _____
5. Tank distance _____
6. Vent Pipe _____
7. Fill Pipe _____
8. Gauge _____
9. Rigidity _____
10. Feed safety _____
11. Pipe sizes and material _____
12. Control valve _____
13. Ash pit vent _____
14. Temp. or pressure safety _____
15. Instruction card _____
16. _____

NOTES

No record of this burner in heat
in at all.
7/8/41. Unit on job but

work not started. MB.
7/10/41. Mr. Lowne will
notify when work started.
MB.



APPLICATION FOR PERMIT

PERMIT ISSUED

Class of Building or Type of Structure Third Class

0382

Portland, Maine, April 4, 1939 APR 4 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications: 407-E-15-22-408-D-28-34

Location Lot 285-232 Idaho Street Ward _____ Within Fire Limits? no Dist. No. _____

Owner's or Lessee's name and address Alice P. Bratt, Idaho Street Telephone 2-7561

Contractor's name and address Edward Emlin, 107 Maine Avenue Telephone _____

Architect _____ Plans filed no No. of sheets _____

Proposed use of building Dwelling and garage No. families 2

Other buildings on same lot _____

Estimated cost \$ 300. Fee \$.75

Description of Present Building to be Altered

Material Frame No. stories 1 1/2 Heat steam Style of roof _____ Roofing _____

Last use Dwelling and garage No. families 1

General Description of New Work

To construct non-bearing partitions in basement to make four room apartment.
To change mullion window on east side of house to door. To cut in new mullion window on rear of dwelling.
To cut in three new windows.
To change door in rear of dwelling to ^{existing} window.
Changing existing toilet to bathroom, window at least three square feet in area for ventilation of same.
There will be at least one window which will open directly to the outside air in each room in the new apartment, and every such window shall open upon a yard space at least five feet wide on the land of the owner. The window in the new bathroom will open to the outside air also.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate _____

Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____

Total number commercial cars to be accommodated: _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Alice P. Bratt

INSPECTION COPY

RESTRICTION REMOVE LAYERS OF CLOSING-IN IS WE-122

1572

Ward 9 Permit No. 38/382

Location: 78285 292 2nd St.

Owner: Alice P. Bratt

Date of permit 4/4/38

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. INSPECTION NOT COMPLETED

507 32/1198
017 4/1960
Cert. of Occupancy issued

NOTES

4/8/38 - New mullion
- window opening being
cut in under pier. -
A.G.B.

4/14/38 - Some prog. -
being made. - A.G.B.

4/20/38 - Put out over setting
of pier + sill in with
Mr. Bratt + plumber -
A.G.B.

4/28/38 - Work well along
- in chimney location?
- sawdust in from kitchen
range. - A.G.B.



(R) GENERAL RESIDENCE ZONE

PERMIT No. ISSUED

APPLICATION FOR PERMIT

1198

AUG 13 1932

Class of Building or Type of Structure Third Class

Portland, Maine, August 15, 1932

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lots 288-290 Idaho Street 407-E-15-22 1108-B-28-34 Ward 9 Within Fire Limits? Div. Dist. No.

Owner's or Lessee's name and address Gustaf W. Bratt, Idaho St. Telephone P 1805 R

Contractor's name and address Omer Telephone

Architect's name and address

Proposed use of building dwelling house with 2 car garage attached No. families 1

Other buildings on same lot

Plans filed as part of this application? no No. of sheets

Estimated cost \$ 73. Fee \$.50

Description of Present Building to be Altered

Material wood No. stories 1 1/2 Heat Style of roof Roofing

Last use dwelling house with one car garage No. families 1

General Description of New Work

To enclose space under existing sleeping porch for storage of one car. The ceiling of the garage space will be covered with sheets of combined asbestos and Portland cement at least 3/8" in thickness with cement at the joints. The two walls adjoining the cellar will be all masonry exposure except one window leading to the cellar which is about 5' above the floor of the garage. Since this window is necessary for ventilation, a shutter covered all over with metal with locked joints will be provided opening into the garage controlled by fusible link so as to close automatically in case of fire.

Renewal of Permit No. 81/2520

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate

Size, front depth No. stories Height average grade to highest point

To be erected on solid or land? earth or rock?

Material of foundation Thickness, top bottom

Material of underpinning Height Thickness

Kind of Roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining

Kind of heat Type of fuel Is gas fitting involved?

Corner posts Sills Girt or ledger board? Size

Material columns under girders Size Max. on center

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor , 2nd , 3rd , roof

On centers: 1st floor , 2nd , 3rd , roof

Maximum span: 1st floor , 2nd , 3rd , roof

If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot 1, to be accommodated 2

Total number commercial cars to be accommodated 1

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes Gustaf W. Bratt

Signature of owner by

Gustaf W. Bratt

INSPECTION COPY

Oliver T. Sandora

CHIEF OF FIRE DEPT.

CERTIFICATE OF OCCUPANCY
FOR
REAR PORCH

4097A

3/6/34. Part done. etc.

Ward 9 Permit No. 32/1198

Location Lot 289-90 Idahost

Owner Wm. H. Bratt

Date of permit 8/15/32

Notif. closing-in _____

Inspn closing-in _____

Final Notif. _____

Final Inspn. _____

5-2-38/382
04-11868
Cert. of Occupancy issued

8/20/32 NOTES
Painting on ceiling etc.

8/1/32 Ceiling & only
work done. etc.

10/9/32 Same. etc.

11/19/32. Some gut lining on
window fixed. etc.

11/23/32. Same. etc.

2/2/33. Same. etc.

5/12/33. Same. etc.

10/26/33. Nothing done. Mr
Bratt will return
this week. etc. etc.

10/26/33. Same. etc.

11/9/33. Same. etc.

12/1/33. Same. etc.

5/1/34 Mr Bratt out of town

7/23/34 Mr Bratt will
have this work done
etc. etc.

RECEIVED BY THE CITY ENGINEER

RECEIVED BY THE CITY ENGINEER

#31/2520-I

June 25, 1932

Mr. Gustaf W. Brett
Idaho Street
Portland, Maine

Dear Sir:

With reference to permit issued from this department on December 14, 1931 to cover enclosing a certain space under a sloping porch in your dwelling at Lots 239-240 Idaho Street to make thereof a garage, we find that no work has been done upon this project over a period exceeding five months.

In such a case the Building permit according to the Building Code becomes void. If you desire to resume work on this project at some time in the future, it will be necessary to apply for and secure another building permit before the work is resumed.

Very truly yours,

Inspector of Buildings.

WEL/HB



(R) GENERAL RESIDENCE ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED
Permit No. 2520
DEC 14 1931

Class of Building or Type of Structure Third Class

Portland, Maine, December 12, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 289-290 Idaho Street 407-E-15-22 405-B-28-34 Ward 9 Within Fire Limits? no Dist. No. _____

Owner's or Lessee's name and address Gustaf H. Bratt, Idaho St. Telephone P 1803 R

Contractor's name and address Owner Telephone _____

Architect's name and address _____

Proposed use of building dwelling house with 2 car garage No. families 1

Other buildings on same lot none

Plans filed as part of this application? no No. of sheets _____

Estimated cost \$25 Fee \$.50

Description of Present Building to be Altered

Material wood No. stories 1 1/2 Heat _____ Style of roof _____ Roofing _____

Last use dwelling house with one car garage No. families 1

General Description of New Work

To enclose space under existing sleeping porch for storage of one car. The ceiling of the garage space will be covered with sheets of combined asbestos and Portland Cement at least 3/8" in thickness with and cemented at the joints. The two walls adjoining the cellar will be masonry exposure except one window leading to the cellar which is about 5' above the floor of the garage. Since this window is necessary for ventilation a shutter covered all over with metal with locked joints will be provided opening into the garage controlled by fusible link so as to close automatically in case of fire.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED.

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
Height average grade to highest point of roof _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____ 2nd _____ 3rd _____ roof _____

On centers: 1st floor _____ 2nd _____ 3rd _____ roof _____

Maximum span: 1st floor _____ 2nd _____ 3rd _____ roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot 1 to be accommodated 1

Total number commercial cars to be accommodated 1

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY Signature of owner Gustaf H. Bratt

Oliver T. Sanborn

CHIEF OF FIRE DEPT.

66731

Ward 9 Permit No. 31/2520

Location Lots 289-90 Idaho St.

Owner Gustaf W. Blatt

Date of permit 12/14/31

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

C. U. NOTES

1/7/32. Work not started. O.K.

1/16/32. A couple of sheets of asbestos removed on ceiling only work done. O.K.

1/25/32. Same. O.K.

3/11/32. Same. O.K.

3/25/32. Same. O.K.

4/11/32. Mr. Blatt said he will start this work again in a short time. O.K.

5/4/32. Nothing more. O.K.

5/19/32. Same. O.K.

6/16/32. Nothing more has been done. O.K.

6/25/32. Better - Mrs. Blatt set permit under 8/15/32. for this location.

51/1727-1

November 20, 1931

Copy to Mr. Gustaf W. Bratt-Idaho Street

Hulverson Bros.
2-15 Union Street
Portland, Maine

ATTENTION: Mr. L. C. Minor

Gentlemen:

With reference to the installation of oil burner for Gustaf W. Bratt on Idaho Street, an inspector from this office reports that wooden supports have been provided for the oil storage tank and also for supporting a part of the apparatus inside of the former ash pit of the boiler.

Combustible supports for an oil storage tank is distinctly forbidden by the Building Code and the use of wood or any other combustible material inside of the heater itself is not considered safe by this Department.

Please arrange to have both conditions remedied without fail on or before November 27, 1931.

Very truly yours,

Inspector of Buildings.

MP/HC



FILL IN COMPLETELY AND SIGN WITH INK

Permit No. 1107

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Me. Sept. 11, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Fuller Street Lots 289-290 407-E-15-22 408-B-28 Use of Building drilling house & garage

Name and address of owner Walter J. Bratt Idaho Street P1803W Ward 5

Contractor's name and address Halverson Bros. 8-15 Union St. Telephone P 2050

General Description of Work

To install Oil Burning Equipment

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel oil
Material of supports of heater or equipment (concrete floor or what kind) concrete floor
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, _____
from top of smoke pipe _____ from front of heater _____ from sides or back of heater _____

IF OIL BURNER

Name and type of burner Silent Automatic Approved by Underwriters' Laboratories? yes labelled
Location oil storage in garage adj. dwg. No. and capacity of tanks 1-275 gallon
vent pipe & fill pipe on outside of garage
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? none

Amount of fee enclosed? \$1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at _____ ae.)
Halverson Bros.

Signature of contractor by Chas. Halverson

INSPECTION COPY

NOTIFICATION BEFORE LATHING OR CLOSING IN IS WAIVED.
CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED.

Ward 9 Permit No. 311727

Location Lots 289-90 Idaho St.

Owner Gustaf W. Pratt

Date of permit 9/11/31

Notif. closing-in

Inspn. closing-in

Final Notif. 10/2/31

Final Inspn. 1/7/32. O.T.

Cert. of Occupancy issued None

NOTES

~~10/2/31 - Nobody home
so no electrical work
done as to the garage
work on the wooden
crate. O.T.~~

~~10/6/31 - Nobody home.
O.T.~~

~~10/12/31 - Same O.T.~~

~~11/5/31 - Spent 1/2 hr
on the pit
pump sets on wood
frames - O.T.~~

~~11/6/31 - Talked with Mrs. Minott~~

Work blocking in ash
pit, and supporting oil
storage tank in the
re. room. O.T.

11/19/31 - Better - wind

13/10/31 Nothing done. O.T.


12/11/31. Mr Halverson
said this would be
done the first of next
week. O.T.

Department of Public Health
H. O. T. PROCEEDING

LOT 287-288-289-292 IDAHO ST
 OWNER GUSTAF BRATT
 SCALE 20 FT TO INCH
 ARCHITECT JOHN THOMAS

(R) GENERAL RESIDENCE ZONE

RECEIVED
 AUG 19 1925
 DEPT. OF PUBL. WORKS
 CITY OF PORTLAND



IDAHO STREET



(R) GENERAL RESIDENCE ZONE

Permit No. 1592

APPLICATION FOR PERMIT

Class of Building or Type of Structure Foundation

SEP 8 1927

Portland, Maine September 1, 1927

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ erect the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lots 289-290 Idaho Street Ward 7 Within Fire Limits? no Dist. No. _____

Owner's ~~or Lessee's~~ name and address Gustaf Bratt, Munjoy Street Telephone _____

Contractor's name and address Leavitt, Allan Avon Telephone _____

Architect's name and address _____

Proposed use of building: 1 family dwelling house and 1 car private garage No. families _____

Other buildings on same lot none

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____

Last use _____ No. families _____

General Description of New Work

To build foundation only

NOTIFICATION BEFORE LEAVING
OR CLOSING IN IS WAIVED.
CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED.

Details of New Work

Size, front 27' 6" depth 45' No. stories _____ Height average grade to highest point of roof _____

To be erected on solid or filled land? solid earth or rock? earth

Material of foundation Concrete Thickness, top 10" bottom 14"

Material of underpinning _____ Height _____ Thickness _____

Kind of roof _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Distance, heater to chimney _____

If oil burner, name and model _____

Capacity and location of oil tanks _____

Is gas fitting involved? _____ Size of service _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Stud (outside walls and carrying partitions) 2x4-16" O.C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____; to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Plans filed as part of this application? yes No. sheets 1

Estimated cost \$ 900. Fee \$ 1.00

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes
Gustaf Bratt

Signature of owner By

INSPECTION COPY

45206

Ward 9 Permit No. 271592 #

Location Lots 287-290 Idaho St.

Owner Trust of Beatt.

Date of permit Sept 8/27

Whit closing-in _____



Inspn. closing-in _____

Final Notif. _____

Final Inspn. 11/2/27

Cert. of Occupancy issued _____

NOTES





APPLICATION FOR PERMIT

PERMIT ISSUED

Class of Building or Type of Structure Trial Class

1893
SEP 10 1928

Portland, Maine, September 5, 1928

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location lots 289-290 Idaho Street 1107-E-15-22 408-13-28-347 Ward 9 Within Fire Limits? No Dist. No.

Owner's or Lessee's name and address Justaf Bratt, 74 Hanjoy Street Telephone P344-7

Contractor's name and address H. Hamlin, 525 Washington Ave. Telephone

Architect's name and address

Proposed use of building Dwelling house with one car garage in basement No. families 1

Other buildings on same lot none

Description of Present Building to be Altered

Material No. stories Heat Style of roof Roofing

Last use No. families

General Description of New Work

To erect one dwelling house with one car garage in basement
Foundation concreted Permit No. 27/1592

The inside of the garage will be covered, where required by law, with metal lath and cement plaster

Details of New Work

Size, front 37'6" over all depth 42' No. stories 1 Height average grade to highest point of roof

To be erected on solid or filled land? solid earth or rock? earth

Material of foundation 27/1592 Thickness, top bottom

Material of underpinning concrete block Height 4' Thickness 8"

Kind of roof Flat Roof covering Asphalt shingles Class O Und. Lab.

No. of chimneys one Material of chimneys brick of lining tile

Kind of heat steam Type of fuel coal Distance, heater to chimney 3'

If oil burner, name and model

Capacity and location of oil tanks

Is gas fitting involved? yes Size of service

Corner posts 4x8 Sills 4x8 Girt or ledger board? Girt Size 2-3x4

Material columns under girders iron posts Size 4" Max. on centers 8'

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 8x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd , roof 2x6

On centers: 1st floor 16', 2nd 16', 3rd , roof 24"

Maximum span: 1st floor 14', 2nd 14', 3rd , roof

If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot none, to be accommodated one

Total number commercial cars to be accommodated none

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? yes

Plans filed as part of this application? see 27/1592 No. sheets

Estimated cost \$ 5,000.

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Signature of owner Justaf W. Bratt

INSPECTION COPY

Olivia P. Scudron


Gas .25
Fee \$ 1.25
Garage .50 \$3.00

Permit No. 28/1823
 289-290 Idaho St.
 Owner Quintal Beatt
 Date of permit 9/10/26
 Notif. closing-in 10/25/28 1:40 P.M.
11/2/28 10:40 A.M.
 Inspn. closing-in
 Final Notif. None Given
 Final Inspn. None Given
 Cert. of Occupancy issued Not Issued

NOTES

Talked with Mr. Loveloy at
 Mr. Thomas' office relative to
 3" concrete slab under bearing
 partition in Basement with
 bearing Partition over it on 1st
 Floor. They have no connection
 with job outside of the plans.

9/26/28 All.



10/22/28 R.T. #3 done
 firestops missing 1st
 floor level.
 Some firestops needed
 at the floor level
 provide missing
 fire stops
 and supports

for rear carrying partition
 before certificate is
 given for lathing.
 notify again

Provide inside window
 or vents through roof
 for all toilets.
 Extend chimneys
 five down rods at
 least one length.

elf. End meet as both
 + plastered firestop in
 brick partition
 for rest of it as
 shown - 1st & 2nd floor

either not a work. just
 vents not in, fire chimney
 not in, Mr. Hamilton said
 ceiling is not to be plastered

11/5/28

With drawn if all
 rods of chimney, all
 punched pipe are not
 less than 6" thick

Changed R.T. to no lathing
 whatever info. all. No. 1
 22.201 - 10/1/28
 11/6/28

11/7/28 - R.T. - Vent
 for all the toilet -
 needed in order to
 be provided.

This house occupied (or
 without notification
 of final check, check
 off no certificate
 3/11/29