

29-31 OREGON STREET

SHAW-WALKER

Full cut # 920R - 11a. cut # 9202R - 11b. cut # 9203R - Full cut # 9203R

NOTES

10/8/51 - Location at 288 2nd St.
 4/17/52 - Garage built walls
 clear dim with wallboard.
 NO shingles on roof.
 MA Barry says applicant
 in 4 months to be approved.
 5/2/52 - Work done. P. 28.

5/1/52

Permit No. 51/1974

Location 29 Leggett Ave.

Owner John E. Barry

Date of permit 10/8/51


Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. 5/8/52

Cert. of Occupancy issued



STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for garage
at 29 Oregon Street Date 10/5/51

1. In whose name is the title of the property now recorded? John E. Barry
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? stakes
3. Is the outline of the proposed work now staked out upon the ground? no
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? Monday
4. What is to be maximum projection or overhang of eaves or drip? 4"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

John E. Barry



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, August 22, 1949

PERMIT ISSUED 01318 AUG 23 CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

N-Dwg ESS

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 29 Oregon Street Use of Building Dwelling house No. Stories New Building "Existing" Name and address of owner of appliance John E. Barry, 29 Oregon Street Installer's name and address Paine Heating Co., County Road, Westbrook Telephone 4-3936

General Description of Work

To install forced warm air heating system

IF HEATER, OR POWER BOILER

Location of appliance or source of heat Basement Type of floor beneath appliance concrete If wood, how protected? Kind of fuel coal Minimum distance to wood or combustible material, from top of appliance or casing top of furnace 15" From top of smoke pipe 18" From front of appliance over 4' From sides or back of appliance over 3' Size of chimney flue 8x10 Other connections to same flue kitchen stove If gas fired, how vented? Rated maximum demand per hour

IF OIL BURNER

Name and type of burner Labelled by underwriter's laboratories? Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? Type of floor beneath burner Location of oil storage Number and capacity of tanks If two 275-gallon tanks, will three-way valve be provided? Will all tanks be more than five feet from any flame? How many tanks fire proofed? Total capacity of any existing tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Kind of fuel Type of floor beneath appliance If wood, how protected? Minimum distance to wood or combustible material from top of appliance From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

[Empty lines for miscellaneous information]

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

O. N. E. S. S. 8/22/49

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES

Paine Heating Co.

Signature of Installer by:

Ernest J. Stalling

INSPECTION COPY

Permit No. 49/1318
Location 29 Oregon St.
Owner John P. Barry
Date of permit 8/23/49
Approved 8/30/49

NOTES

8/30/49 - 12/22/49
done



(R) RESIDENCE ZONE - C

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, June 9, 1947

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

PERMIT ISSUED

00598

APR 28 1947

CITY OF PORTLAND

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 29-31 Oregon Street Within Fire Limits? no Dist No 2286
Owner's name and address John E. Barry, 21 Oregon Street Telephone 7-
Lessee's name and address _____ Telephone _____
Contractor's name and address owner Telephone _____
Architect _____ Specific _____ Plans yes No of sheets 2
Proposed use of building Dwelling No families _____
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 4000. Fee \$ 3.00

General Description of New Work

To construct 1 story frame dwelling 32'x26'

INSPECTION NOT COMPLETED 3/3/50

Permit Issued with Letter

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? yes Is any electrical work involved in this work? yes
Height average grade to top of plate 7'6" 10' Height average grade to highest point of roof 18'
Size, front _____ depth _____ No. stories 1 solid or filled land? solid earth or rock? earth
Material of foundation concrete Thickness, top 10" bottom 12" cellar yes
Material of underpinning Concrete to sill Height _____ Thickness _____
Kind of roof pitch-gable Rise per foot 1 1/2" Roof covering asphalt roofing Class C Und. Lab.
No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat stove fuel _____
Framing lumber--Kind hemlock Dressed or full size? dressed
Corner posts 4x4 Sills 4x8 Girt or ledger board? _____ Size _____
Girders yes Size 6x10 Columns under girders Deer Col Size 3 1/2" Max. on centers 4'7 1/2"
Studs (outside walls and carrying partitions) 2x4-10" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x8, 2nd 2x6, 3rd _____, roof 2x6
On centers: 1st floor 16", 2nd 16", 3rd _____, roof 16"
Maximum span 1st floor 13', 2nd 13', 3rd _____, roof 13'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

By ags

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner

John E. Barry

INSPECTION COPY

11/7/48 - 1/4" ...	9/18/49 - ...
11/12/48 - Works progressing slowly	3/18/49 - ...
11/30/48 - Works progressing slowly	5/17/49 - Works progressing
Excavation 12/9/48 - Mr. Barry ...	8/19/49 - ...
12/12/48 - Headers & Trusses to be	8/30/49 - Two side porch
1/6/49 - Garage G.T. to close	9/11/49 - Temp. Certificate
1/26/50 - Solid covered porch	3/13/50 - Side porch not built

APPLICATION FOR AMENDMENT TO PERMIT



Amendment No. 1

Portland, Maine, May 6, 1948

PERMIT ISSUED

MAY 8 1948

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for an amendment to Permit No. 48/598 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 29-31 Oregon Street Within Fire Limits? LO Dist. No. _____
 Owner's name and address John F. Barry, 21 Oregon Street Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address owner Telephone _____
 Architect _____ Plans filed by No. of sheets _____
 Proposed use of building Dwelling No. families 1
 Increased cost of work _____ Additional fee .25

Description of Proposed Work

To construct concrete block foundation and underpinning in place of concrete wall stated in original application. Concrete footing at least 8" thick.

Details of New Work

Is any plumbing work involved in this work? _____ Is any electrical work involved in this work? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation concrete blocks at least 4" below grade Thickness, top 12" bottom 18" cellar yes
 Material of underpinning _____ Height 24" Thickness 8"
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____
 Framing lumber—Kind _____ Dressed or full size? _____
 Corner posts _____ Sills _____ Girt or ledger board? _____ Sire _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

Approved: _____


Signature of Owner John F. Barry

Approved: 5/8/48


Inspector of Buildings.

INSPECTION COPY

Original lot 40' in width has been enlarged by additional 20' width purchased from adjoining lot.




FRONT YARD OF EXISTING DWELLING
 = 4' (TO FRONT OF PLAZA)
 FRONT YARD OF VACANT LOT
 ON OTHER SIDE = 15'
 AVERAGE = $\frac{15+4}{2} = 9\frac{1}{2}'$
 HOWEVER, WALL OF HOUSE IS
 11' FROM STREET, SO THIS
 DISTANCE WILL GOVERN OVER
 THE AVERAGE FRONT YARD



~~SUPERSEDED~~

PRESUMPT SCOTT
RIVER



40'-0
29 ORIGONE ST

RECEIVED
3 1917
DEPT. OF BLD'G. INSP.
CITY OF PORTLAND

Plot Plan

JOHN E. BARRY

ORIGONE ST PORTLAND ME

AP 29-31 Oregon Street-I

April 27, 1943

Mr. John E. Barry
21 Oregon Street
Portland, Maine

Subject: Permit for construction
of one-family dwelling at 29-31
Oregon Street

Dear Sir:

The permit for the above work is issued herewith based on the plan filed with application and subject to the following:

1. Although it is not shown on the plan, we understand that a rollway entrance to cellar is to be provided with the concrete foundation wall of the building extended to form the wall of the cellarway entrance.
2. A scuttle at least 2' x 3', located at some convenient place in the ceiling, is required to give access to the attic space.
3. Before any lath or plaster is applied to walls, partitions or ceiling, notice for an inspection is required to be given this office. This should not be done until the plumbing and electric wiring has been installed and approved by the proper inspectors and after all framing and firestopping has been completed.
4. A certificate of occupancy, issued after a final inspection of the building has indicated everything to be in compliance with Building Code requirements, is required before the building is used for living purposes.

Very truly yours,

Inspector of Buildings

AJS/S

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for dwelling

at Lot Oregon Street

Date 6/9/47

1. In whose name is the title of the property now recorded? John E. Barry
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? iron posts
3. Is the outline of the proposed work now staked out upon the ground? yes
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? _____
4. What is to be maximum projection or overhang of eaves or drip? _____
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

John E. Barry