

Chase Transfer Corp.

October 31 1941

required an exit sign showing letters in the word exit at least four and one-half inches high either red or green and a white light is required outside of this door, both lights to be on a single circuit and controlled by a single switch. Outside of the rear door is required a platform or landing with a railing, the platform to be as wide and as deep as the doorway is wide. The steps leading from this platform to the ground are required to have risers no more than eight and one-half inches and treads no less than nine inches and to have a handrail on both sides of the steps. There is a low step in front of the entrance door on Commercial Street which will not be safe when the door is made to swing outwards. I suggest a ramp with non-slip surface.

6. No single steps in the floor of the restaurant are permitted as shown in two places, but ramps may be used to overcome the differences in elevation. If the difference in elevation to be overcome is more than ten inches, the slope is required to be no steeper than one in twelve. If ten inches or less the pitch is not regulated, but if the pitch is steeper than one in fifteen a non-slip surface is required on the ramp.

7. From the statement on the application it is understood that there is no intention of dispensing beer or alcohol beverages on the premises. If that were the case, the Building Code requires that the Municipal Officers approve the permit before issuance.

8. Cooking appliances, hot water heaters, ventilation equipment and refrigeration equipment other than a refrigerator merely plugged into the usual outlet all require separate permits which may only be issued to the actual installer of the equipment. All of these permits must be approved by the Health Officers before issuance.

It will be appreciated if you will proceed to have the plans revised to show all of these matters that can be properly shown on the plans and show the balance in some sort of written statement to be filed with the application for the permit. The basis of most of the criticisms as above may be found in Section 236 and 237 of the Building Code, copies of which are available for all.

Very truly yours,

Inspector of Building

Mel/H

CC: Philip Rhodes
3 Cliff Avenue
So. Portland, Maine
King Butland
219 Cumberland Avenue



INDUSTRIAL APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, October 3, 1921

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 65-1 Commercial Street Fire Limits? yes Dist. No. 2
Owner's or Lessee's name and address Chase Transfer Corp. 25 Commercial St. Telephone
Contractor's name and address King-Butland, 219 Cumberland Avenue Telephone
Architect Philip Vessey, 3 Cliff Avenue So. Portland Plans filed yes No. of sheets 1
Proposed use of building Restaurant No. families
Other buildings on same lot
Estimated cost \$1,000 Fee \$ 2.00

Description of Present Building to be Altered

Material wood No. stories 1-1 Heat steam Style of roof shed Roofing metal
No. families

General Description of New Work

To remove 19' bearing partitions (crossway) and support as shown on plan, to make
To remove existing platform and close in outside edge of same. - ALL FLOORWORK OTHERWISE
EXCEPT FLOOR AND NOT MORE THAN 21 SQUARE FEET IN AREA AND WINDOW SILLING.
To remove present ladder to second floor and provide scuttle
To provide new vestibule in front of existing toilet and provide new toilet with vestibule,
doors to be at least 24" wide and to be made self-closing in such a way that there will be
little chance of both doors being open at the same time - partitions 2x4 studs 16" Oc
covered on both sides with sheathing or plywood

Beer will not be sold on premises

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? yes
Is any electrical work involved in this work? yes Height average grade to top of plate
Size, front depth No. stories Height average grade to highest point of roof
To be erected on solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining
Kind of heat Type of fuel Is gas fitting involved?
Framing lumber-Kind Dressed or full size?
Corner posts Sills Girt or ledger board? Size
Material - studs under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x1-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated
Total number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Chase Transfer Corp.

INSPECTION COPY

Thomas L. Leduc Philip Vessey

1422

Permit No. 411521

certificate issued, etc.

Location 46-48 Commercial St.
 owner Chas. Transilling
 date of permit - 10/14/41
 off. closing-in
 Inspn. closing-in
 Final Notif
 Final Inspn. 2/12/42 Ra
 Cert. of Occupancy issued 2/12/42
 Date 4/1/42
 Sign 4/1/42

NOTES

12/23/41. All windows replaced completely, second floor down. Machine at rear side of building made temporary credit side of front door to be provided, no permit required. All people received finally. All locks installed, used. Restaurant has been operating for some time. All credit side finished. All because of scale. It has been...
 12/23/41. All windows replaced completely, second floor down. Machine at rear side of building made temporary credit side of front door to be provided, no permit required. All people received finally. All locks installed, used. Restaurant has been operating for some time. All credit side finished. All because of scale. It has been...

MILLER



PERMIT ISSUES

Original Permit No. _____

Amendment No. 18620 1948

AMENDMENT TO APPLICATION FOR PERMIT

Portland, Maine, August 15, 1948

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for an amendment to Permit No. 10,1035 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 48 Commercial Street Within Fire Limits? yes Dist. No. 4

Owner's or Lessee's name and address Forster Express Co.

Contractor's name and address T. N. Stokes, 355 Pride St., Westbrook No. of Sheets 3, 5, 7, 9

Plans filed as part of this Amendment yes Is any plumbing work involved in this work? yes

Is any electrical work involved in this work? no

Increased cost of work _____ Additional fee 25

Framing Lumber: Kind? _____ Dressed or Full Size? _____

Description of Proposed Work

To locate tank and pump as shown on pls. submitted with this appx amendment

Approved: William T. Johnson
Chief of Fire Department.

INSPECTION COPY - Commissioner of Public Works.

Forster Express Co.
Signature of Owner: T. N. Stokes

Approved: 8/12/48
Inspector of Buildings.



INDUSTRIAL ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED

Permit No. 7-123

JUL 20 1940

Class of Building or Type of Structure Gasoline Installation

Portland, Maine, July 27, 1940

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect and install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 480 Commercial Street Within Fire Limits? yes Dist. No. 2

Owner's or Lessee's name and address Border Express Co. 180 Commercial St. Telephone

Contractor's name and address T. H. Stokes, 355 Pride St. Westbrook Telephone 3-5179

Architect Plans filed yes No. of sheets 1

Proposed use of building No. families

Other buildings on same lot

Estimated cost \$ 125. Fee \$.75

Description of Present Building to be Altered

Material No. stories Heat Style of roof Roofing

Last use No. families

General Description of New Work

To install one 1,000 gallon tank and one electric pump for gasoline, new installation, private use, tank will bear Underwriters' Label, coated with asphaltum, will be at least three feet below grade, minimum diameter of piping tank to pump 1 1/2"

Storage applied for

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

CERTIFICATE OF QUALITY
REQUIREMENT IS WAIVED

Is any plumbing work involved in this work?

Is any electrical work involved in this work? Height average grade to top of plate

Size, front depth No. stories Height average grade to highest point of roof

To be erected on solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cellar

Material of underpinning Height Thickness

Kind of Roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining

Kind of heat Type of fuel Is gas fitting involved?

Framing Lumber—Kind Dressed or Full Size?

Corner posts Sills Girt or ledger board? Size

Material columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor, 2nd, 3rd, roof

On centers: 1st floor, 2nd, 3rd, roof

Maximum span: 1st floor, 2nd, 3rd, roof

If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated

Total number commercial cars to be accommodated

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of owner Border Express Co.

INSTRUCTION COPY By T. H. Stokes

CHIEF OF FIRE DEPT.

Permit No. 40/1035

Location 48 Commercial St.

Owner Bondi Egan Co

Date of permit 7/29 /40

Notif. closing-in

Inspnr closing-in

Final Notif.

Final Inspn. 10/22/40, C.D.S.

Cert. of Occupancy issued *Ames*

NOTES

10/19/40

Ready for closing

C.D.S.

10/19/40 - O.K. to cover.

Check in next later.

Work located as called

for in original permit

possible at this location

in plan -

E.G.S.

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

10/19/40

September 21, 1936

File: P. No. 36/1361-1

Chase Transfer Corp.,
48 Commercial St.,
Portland, Me.

Gentlemen:

Enclosed is amendment to building permit No. 36/1361,
approved as covering an addition to the original work.

Please note that bridging at least 1"x 3" in size is
required in the first floor, and also that permanent signs are
required in the warehouse stating clearly that the allowable load
on the floor is 150 pounds per square foot.

The framing of the outside walls of the warehouse and the
location of the cedar posts for foundation beneath the outside walls
are not indicated on the plan. It is assumed that the outside walls
will be framed with solid 4x4 or 4x6 corner posts, 2x4 studs not more
than 16 inches from center to center, and doubled 2x4 plate at the
tops of the studs. It is assumed that the cedar posts under outside
walls will be located similarly to those under the girders, that is,
five feet from center to center. If deviation from this arrangement
is intended, please outline in detail to the architect before proceeding
with the work.

I believe that, if you will have your designer again go over
the roof framing in light of the total live and dead load of 50 pounds
per square foot over the roof area, that some economy may be effected
in sizes of roof joists and roof girders, in view of the short spans,
but please do not make any changes without consulting this office be-
fore proceeding with them.

Very truly yours,

(Signed) Warren McDonald

Inspector of Buildings



Original PERMIT IS. 111
Amendment No. 1

AMENDMENT TO APPLICATION FOR PERMIT 111

Portland, Maine, September 17, 1936

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for an amendment to Permit No. 28/1181 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 43 Commercial Street Ward 3 With the Fire Limits? yes Dist. No. 2

Owner's or Lessee's name and address Chase Transfer Corp., 43 Commercial St.

Contractor's name and address Owner

Plans filed as part of this Amendment yes No. of Sheets 1

Increased cost of work \$00. Additional fee .25

Description of Proposed Work

To remove the second story of a portion 15'x24' of the existing two story building, to repair and strengthen the remaining first story and provide a new shed roof over this one story portion, framing as shown on plan.
To construct new one story addition approximately 30'x24', 16 feet high, foundation to be cedar posts and balises of framing to be shown on plan. The floor of the addition to be designed to carry 150 lb. per square foot live load and permanent signs will be posted in the building to that effect. All new roof covering will be rolled asphalt roofing Class C Under Lab.

Signature of Owner By *[Signature]* Chase Transfer Corp.

Approved:

Chief of Fire Department.

Approved: 9/21/36

3/18
1/18



Original Permit No. PERMIT 15-120
Amendment No. 1

AMENDMENT TO APPLICATION FOR PERMIT 15-120

Portland, Maine, September 17, 1926

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for an amendment to Permit No. 26/1-161 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 48 Commercial Street Ward 3 With the Fire Limits: Yes Dist. No. 2

Owner's or Lessee's name and address Chase Transfer Corp., 46 Commercial St.

Contractor's name and address W. A. B. Co.

Plans filed as part of this Amendment Yes No. of Sheets 1

Increased cost of work \$00. Additional fee \$.25

Description of Proposed Work

To remove the second story of a portion 15' x 24' of the existing two story building, to repair and strengthen the remaining first story and provide a new shed roof over this one story portion, framing as shown on plan.
To construct new one story addition approximately 30' x 24', 10 feet high, foundation to be cedar posts and balancers of framing to be shown on plan. The floor of the addition to be designed to carry 150 lb. per square foot live load and permanent loads will be placed in the building to that effect. All new roof covering will be rolled asphalt roofing Class C Und. Lab.

Approved:

Chief of Fire Department.

Commissioner of Public Works.

Signature of Owner Chase Transfer Corp.
[Signature]

Approved: 9/21/26

Inspector of Buildings

INSPECTION COPY



File

APPLICATION FOR PERMIT

Permit Issued
1361

Class of Building or Type of Structure Third Class SEP 2 1938

Portland, Maine, September 2, 1938
Supersedes p. of 8/21/38

To the INSPECTOR OF BUILDINGS, PORTLAND, ME

The undersigned hereby applies for a permit to erect, alter, install the following building structural equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 48 Commercial Street Ward 3 Within Fire Limits? Yes Dist. No. 2
 Owner's or Lessee's name and address Chase Transfer Corp 43 Commercial St. Telephone 3-3847
 Contractor's name and address Owner Telephone _____
 Architect's name and address _____
 Proposed use of building Office No. families _____
 Other buildings on same lot _____
 Plans filed as part of this application? yes No. of sheets 1
 Estimated cost \$ 500. Fee \$.75

Description of Present Building to be Altered

Material wood No. stories 2-1 Heat _____ Style of roof _____ Roofing _____
 Last use Freight Shed and Office No. families _____

General Description of New Work

To demolish existing freight shed as shown by dotted line on plan attached, leaving only the present two story office building and small one story office.

To construct a new one story addition approximately 27' x 14' over all indicated on plan "addition to office" in red, the general construction of this portion being also indicated on the drawing.

ALL EXTERIOR EXPOSED ROOFWORK EXCEPT WINDOW SASHES AND DOORS TO BE COVERED WITH METAL

It is contemplated later to construct an additional warehouse about 24' x 45', one story high, and when these plans are definitely decided upon suitable plan will be filed and application for an amendment to this permit.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
 Height average grade to highest point of roof _____
 To be erected on solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of Roof _____ Rise per foot _____ Roof covering Asphalt roofing Class C Und. Lub.
 No. of chimneys _____ Material of chimneys _____ of lining _____
 Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
 Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
 Material columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____
 Total number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
 Signature of owner By Chase Transfer Corp
J. B. [Signature]

INSPECTION COPY

7-2-38



Permit No. _____

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, August 21, 1926

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~erect~~ ~~alter~~ ~~install~~ the following building structure/equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 48 Commercial Street Ward 2 Within Fire Limits? Yes Dist. No. 2
 Owner's or Lessee's name and address Chase Transfer Corp. 48 Commercial St. Telephone 3-3347
 Contractor's name and address Owner Telephone _____
 Architect's name and address _____
 Proposed use of building Freight Shed and Offices No. families _____
 Other buildings on same lot _____
 Plans filed as part of this application? yes No. of sheets 2
 Estimated cost \$ 500. Fee \$ 22 x 1.00

Description of Present Building to be Altered

Material wood No. stories 2-1 Heat _____ Style of roof _____ Roofing _____
 Last use Freight Shed and Offices No. families _____

General Description of New Work

To demolish existing freight sheds in rear of existing two story Office building (also section 19'6" x 14'6" two story high) app. 25' x 47' and rebuild as one story frame, metal-clad freight shed
 To build new roof over two existing small additions app. 6'6" x 15' making the new side line of this addition in line with new freight shed

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate 14'
 Height average grade to highest point of roof 17'
 To be erected on solid or filled land? filled earth or rock? _____
 Material of foundation concrete pier Thickness, top _____ bottom _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of Roof flat Rise per foot 1/8" Roof covering Asphalt roofing Class C Und. Lab.
 No. of chimneys no Material of chimneys _____ of lining _____
 Kind of heat no Type of fuel _____ Is gas fitting involved? _____
 Corner posts 6x8 Sills 8x8 Girt or ledger board? _____ Size _____
 Material columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof 2x8
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof 2'
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof 12'
 If one story building with masonry walls, thickness of walls? 8x8 spruce on 6" centers height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
 Total number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner By Chase Transfer Corp
[Signature]

INSPECTION COPY

Ward 3 Permt No 36/1361
 Location 48 Commercial St.
 Order Case Transfer Co.
 Date Permt 9/2/56
 Notif. closing-in 9/8/56
 Inspr. closing-in
 Final Notif.
 Final Inspn. 9/16/57
 Cert. of Occupancy issued None

present structure of
 24' x 30' on 4' x 12' concrete
 plan, especially was
 in a bad condition.
 2 - 10' x 12'
 NY 2X12⁸ x 2X12⁸
 3X6 6'3"
 - 28' 100 - 3122²
 3122 - 1622² per sq ft
 6' on 5' spans is good
 for 3X 3122 = 9166²

2X12⁸ x 2X6⁸
 2X12⁸ - 4693
 50,493

NOTES
 9/16/57 - O.N. to
 2' x 12' x 12'
 2' x 12' x 12'
 4/24/56 As framed
 12' x 12' x 12' consists
 of 2X12⁸ x 12' x 12'
 12' x 12' x 12' spans
 with 6' x 6' dimension
 12' x 12' x 12' x 12'
 12' x 12' x 12' x 12'
 12' x 12' x 12' x 12'
 12' x 12' x 12' x 12'
 12' x 12' x 12' x 12'
 on a center girder
 of 8x10 spans
 12' x 12' x 12' x 12'
 ing is 16' x 30' with
 a platform on

9166 - 367² per sq ft
 NY 2X11⁶ x 2X12⁸
 176000 - 6578²
 16518 - 54² per sq ft
 16518 - 54² per sq ft
 16518 - 54² per sq ft

Area	Per Sq Ft	Total
6' on 5' spans	9166	9166
12' x 12' x 12' x 12'	6578	176000
12' x 12' x 12' x 12'	54	16518
12' x 12' x 12' x 12'	54	16518



APPLICATION FOR PERMIT

Permit No. 4474

Class of Building or Type of Structure

Portland, Maine, MAY 22, 1955

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Commercial St. Ward E Within Fire Limits? yes Dist. No. 2
Owner's or Lessee's name and address Chase Transfer Corp 48 Commercial St. Telephone
Contractor's name and address owner Telephone
Architect's name and address
Proposed use of building Office bldg. No. families
Other buildings on same lot office bldg.
Plans filed as part of this application? no No. of sheets
Estimated cost \$ Fee \$ 50

Description of Present Building to be Altered

Material frame No. stories 1 Heat none Style of roof pitch Roofing asphalt, shingles
Last use office No. families

General Description of New Work

To move present office building 10'-0 x 15'-0 about 1000 to new location on same property, to adjoin present office building and cut in one door between.

CERTIFICATE OF OCCUP. REQUIREMENT IS WAIVED
NOTIFICATION BEFORE LAYING OR COMMENCING IN IS IN THE NAME OF

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate
Size, front 10' depth 15' No. stories 1 Height average grade to highest point of roof
To be erected on solid or filled land? earth or rock?
Material of foundation cedar posts Thickness, top bottom
Material of underpinning Height Thickness
Kind of Roof Rise per foot Roof covering
No. of chimneys none Material of chimneys of lining
Kind of heat none Type of fuel Is gas fitting involved?
Corner posts Sills Girt or ledger board? Size
Material columns under girders. Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated
Total number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes


Signature of owner Chase Transfer Corp by [Signature]

INSPECTION COPY

4474B

Ward 3 Permit No. 30/691
Location 48 Commercial St.
Owner Chas. Transfer Corp
Date of permit 6/22/35
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. 6/29/35
Cert. of Occupancy issued None

NOTES
5/29/35 - Building
insp'd - AGS





Location, Ownership and detail must be correct, complete and legible.
 Separate application required for every building.
 Plans must be filed with this application.

Application for Permit for Alterations, etc.

Portland, Me., October 7, 1924. 10

To the
 INSPECTOR OF BUILDINGS:

The undersigned applies for a permit to alter the following described building:—

Location State Pier (See 36-66 Commercial Street) Ward 3 in fire-limits? Yes
 Name of Owner or Lessee, Directors of the Port of Portland, St of Maine
 " " Contractor, "
 " " Architect, Webster & Libby " 11 Exchange St.
 Material of Building is Style of Roof, Material of Roofing,
 Size of Building is feet long; feet wide. No. of Stories,
 Cellar Wall is constructed of is inches wide on bottom and tatters to inches on top.
 Underpinning is is inches thick; is feet in height.
 Height of Building Wall, if Brick; 1st, 2d, 3d, 4th, 5th,
 What was Building last used for? shed No. of Families?
 What will Building now be used for? shed

Descrip-
 tion of
 Present
 Bldg.

PERMIT MUST BE OBTAINED BEFORE BEGINNING WORK

Detail of Proposed Work

build addition 30x40 feet of steel with tar & gravel roof
all to comply with the building ordinance

 Estimated Cost \$ 13,000.

If Extended On Any Side

Size of Extension, No. of feet long?; No. of feet wide?; No. of feet high above sidewalk?
 No. of Stories high?; Style of Roof?; Material of Roofing?
 Of what material will the Extension be built? Foundation?
 If of Brick, what will be the thickness of External Walls? inches; and Party Walls inches.
 How will the extension be occupied? How connected with Main Building?

When Moved, Raised or Built Upon

No. of Stories in height when Moved, Raised, or Built upon? Proposed Foundations?
 No. of feet high from level of ground to highest part of Roof to be?
 How many feet will the External Walls be increased in height? Party Walls

If Any Portion of the External or Party Walls Are Removed

Will an opening be made in the Party or External Walls? in Story.
 Size of the opening? How protected?
 How will the remaining portion of the wall be supported?

Signature of Owner or
 Authorized Representative

Address

Webster & Libby
11 Exchange St.

ms. h...

D 894

36-66 Commercial St

State Pier

Oct 7, 1924

Bill
Election
tion of
Description

Application for Permit for
Excavation, etc.

Particulars of Proposed Work

It Extended on 10/10/24

When Moved, Raised or Built Upon

PERMIT MUST BE OBTAINED BEFORE BEGINNING WORK



Location, ownership and detail must be correct, complete and legible. Separate application required for every building. Plans must be filed with this application.

APPLICATION FOR PERMIT TO BUILD

(3D CLASS BUILDING)

Portland, Me., November 9, 1923 19

TO THE
INSPECTOR OF BUILDINGS

The undersigned hereby applies for a permit to build, according to the following Specifications:— *Code 36-16 Commercial Street*

Location State Pier, Commercial St Ward 3 Fire Limits? yes

Name of owner is? State of Maine Address _____

Name of mechanic is? Thomas Skinner Co Address 43 Cotton Street

Name of architect is? _____ Address _____

Proposed occupancy of building (purpose)? (steel) storage of hose & pumps

If a dwelling or tenement house, for how many families? _____

Are there to be stores in lower story? _____

Size of lot, No. of feet front? _____; No. of feet rear? _____; No. of feet deep? _____

Size of building, No. of feet front? 10ft No. of feet rear? 10ft; No. of feet deep? 18ft

No. of stories, front? 1; rear? _____

No. of feet in height from the mean grade of street to the highest part of the roof? 12ft

Distance from lot lines, front? _____ feet; side? _____ feet; rear? _____

Firestop to be used? _____

Will the building be erected on solid or filled land? _____

Will the foundation be laid on earth, rock or piles? _____

If on piles, No. of rows? _____ distance on centres? _____ length of? _____

Diameter, top of? _____ diameter, bottom of? _____

Size of posts, 4 x 6 Studding 2 x 4 16 O. C. Sills 4 x 8 Roof Rafters 2 x 6 24 O. C. Girders 6 x 8

Size of girts 4 x 4

Size of floor timbers? 1st floor concrete 2d _____, 3d _____, 4th _____

O. C. " " " " _____, 2d _____, 3d _____, 4th _____

Span " " " " _____, 2d _____, 3d _____, 4th _____

Will the building be properly braced? _____

Building, how framed? _____

Material of foundation? concrete posts thickness of? _____ laid with mortar? _____

Underpinning, material of? _____ height of? _____ thickness of? _____

Will the roof be flat, pitch, mansard or hip? pitch Material of roofing? steel

Will the building be heated by steam, furnaces, stoves or grates? _____ Will the flues be lined? _____

Will the building conform to the requirements of the law? yes

Means of egress? _____

_____ Scuttle and stepladder to roof? _____

Estimated Cost, _____

\$ 190. Signature of owner or authorized representative, Thomas Skinner

Address, 43 Cotton St

Plans submitted? _____ Received by? _____

Plans must be submitted in duplicate, one set to be filed with the Department and the duplicate set thereof (bearing the approval of the Inspector of Buildings) shall be kept on the work and exhibited on demand.

PERMIT MUST BE RECEIVED BEFORE BEGINNING WORK

Commercial St.

192

No. 5576

APPLICATION FOR
Permit to Build
3rd CLASS BUILDING

LOCATION

No. 3666
State Pier
Commercial Street

WARD 3

Inspector.

CONDITIONS

PERMIT GRANTED

Permit filled out by Nov 9, 1923 192

Permit number

Plan number

FINAL REPORT

192

Has the work been completed in accordance
with this application and plans filed and ap-
proved?

Law been violated?

Nature of violation?

Violation removed when? 192

Estimated cost of building, etc., \$

Building Inspector.

APPROVAL OF PLANS

Supervisor of plans.



Location, ownership and detail must be correct, complete and legible. Separate application required for every building. Plans must be filed with this application.

APPLICATION FOR PERMIT TO BUILD

(3D CLASS BUILDING)

Portland, Me., November 29, 1920 19

To THE
INSPECTOR OF BUILDINGS

The undersigned hereby applies for a permit to build, according to the following Specifications:—

Location Thomas Street (i.e. 36-66 Commercial Street) Wd. 4

Name of owner is? The Longshore Carpenter's Society Address Robinson Hall, Middle Street

Name of mechanic is? William Gregory " 241 Congress

Name of architect is? (City land near Galt Block, (permission of Mayor)

Proposed occupancy of building (purpose)? temporary tool house

If a dwelling or tenement house, for how many families? _____

Are there to be stores in lower story? _____ No. _____

Size of lot, No. of feet front? _____; No. of feet rear? _____; No. of feet deep? _____

Size of building, No. of feet front? 16ft; No. of feet rear? 16ft; No. of feet deep? 36ft

No. of stories, front? 1; rear? _____

No. of feet in height from the mean grade of street to the highest part of the roof? 12ft

Distance from lot lines, front? _____ feet; side? _____ feet; side? _____ feet; rear? _____ feet

Firestop to be used? Yes

Will the building be erected on solid or filled land? _____

Will the foundation be laid on earth, rock or piles? _____

If on piles, No. of rows? _____ distance on centres? _____ length of? _____

Diameter, top of? _____ diameter, bottom of? _____

Size of posts? whole building covered with Carey's Slate Surface Asphalt

" girts? _____

" floor timbers? 1st floor wood, 2d _____, 3d _____, 4th _____

O. C. " " " " " " " " " " " "

Span " " " " " " " " " " " "

Braces, how put in? _____

Building, how framed? _____

Material of foundation? _____ thickness of? _____ laid with mortar? _____

Underpinning, material of? _____ height of? _____ thickness of? _____

Will the roof be flat, pitch, mansard, or hip? pitch Material of roofing? asphalt

Will the building be heated by steam, furnaces, stoves or grates? stove Will the flues be lined? yes

Will the building conform to the requirements of the law? yes

No. of brick walls? _____ and where placed? _____

Means of egress? _____

PERMIT MUST BE RECEIVED BEFORE BEGINNING WORK.

If the building is to be occupied as a Tenement House, give the following particulars:

What is the height of cellar or basement? _____

What will be the clear height of first story? _____ second? _____ third? _____

State what means of egress is to be provided? _____

_____ Scuttle and stepladder to roof?

Estimated Cost,
\$ 150.

Signature of owner or authorized representative,

Wray Gould

Address,

97 Monument St

Plans submitted? _____

Received by? _____

Plans must be submitted in duplicate, one set to be filed with the Department and the duplicate set thereof (bearing the approval of the Inspector of Buildings) shall be kept on the work and exhibited on demand.

Thames St.
191

No. 5909

**APPLICATION FOR
PERMIT TO BUILD 3d CLASS BUILDING**
LOCATION

No. Thames
36-66 Commercial St.

Ward 4

Inspector.

CONDITIONS

PERMIT GRANTED
November 29, 1920 191

Permit filled out by _____
Permit number _____
Plan number _____

FINAL REPORT

191

Has the work been completed in accordance with
this application and plans filed and approved?

Law been violated? _____
Nature of violation? _____

Violation removed when? _____ 191
Estimated cost of building, etc., \$ _____

Building Inspector.

APPROVAL OF PLANS

Supervisor of Plans.



Location, Ownership and detail must be correct, complete and legible.
 Separate application required for every building.
 Plans must be filed with this application.

Application for Permit for Alterations, etc.

To the Portland, October 11, 1922 192

INSPECTOR OF BUILDINGS:

The undersigned applies for a permit to alter the following described building:—

Location 46-48 Commercial Street Ward, 3 in fire-limits? Yes
 Name of Owner or Lessee, Eastern Steamship Corp Address 46 Commercial Street
 " " Contractor, Brown & Berry Co " Press Building
 " " Architect _____

Description of Present Bldg. PERMIT REPORT

Material of Building is wood Style of Roof, pitch Material of Roofing, asphalt
 Size of Building is 40ft feet long; 25ft feet wide. No. of Stories, 2
 Cellar Wall is constructed of brick is _____ inches wide on bottom and batters to _____ inches on top.
 Underpinning is _____ is _____ inches thick; is _____ feet in height.
 Height of Building 20ft Wall, if Brick; 1st, _____ 2d, _____ 3d, _____ 4th, _____ 5th, _____
 What was Building last used for? office building No. of Families? _____
 What will Building now be used for? same

DETAIL OF PROPOSED WORK

Demolish portion of building 8x25, and close in end of building with wood covered with metal, all exterior new woodwork to be covered with metal.
all to comply with the building ordinance

Estimated Cost \$ 900.

IF EXTENDED ON ANY SIDE

Size of Extension, No. of feet long? _____; No. of feet wide? _____; No. of feet high above sidewalk? _____
 No. of Stories high? _____; Style of Roof? _____; Material of Roofing? _____
 Of what material will the Extension be built? _____ Foundation? _____
 If of Brick, what will be the thickness of External Walls? _____ inches; and Party Walls _____ inches.
 How will the extension be occupied? _____ How connected with Main Building? _____

WHEN MOVED, RAISED OR BUILT UPON

No. of Stories in height when Moved, Raised, or Built upon? _____ Proposed Foundations _____
 No. of feet high from level of ground to highest part of Roof to be? _____
 How many feet will the External Walls be increased in height? _____ Party Walls _____

IF ANY PORTION OF THE EXTERNAL OR PARTY WALLS ARE REMOVED

Will an opening be made in the Party or External Walls? _____ in _____ Story.
 Size of the opening? _____ How protected? _____
 How will the remaining portion of the wall be supported? _____

Signature of Owner or Authorized Representative

Address

Brown & Berry
Russell

PERMIT MUST BE OBTAINED BEFORE BEGINNING WORK

46-8 Commercial St.
36-66

FINAL REPORT

102

Has the work been completed in accordance with this application and plans filed and approved?

Law been violated? ... Doc. No. ... of 192

Nature of violation?

Violation removed, when? ... 102

Estimated cost of alterations, etc., \$

Inspector of Buildings.

PERMIT MUST BE OBTAINED BEFORE BEGINNING WORK

PERMIT GRANTED

Oct 17, 1922

102

Permit filled out by

Permit number

46 Commercial

Station

NO VIOLATION REPORTED ON 11/1/22

NO VIOLATION REPORTED ON 11/1/22

Application for Permit for Alteration

Application for Permit for Alteration



Location, Ownership and detail must be correct, complete and legible.

Separate application required for every building.

Plans must be filed with this application.

Application for Permit for Alterations, etc.

To the Portland, February 19, 1921, 192

INSPECTOR OF BUILDINGS:

The undersigned applies for a permit to alter the following described building:—

Location 66 Commercial Ward, 4 in fire-limits? yes

Name of Owner or Lessee, Eastern Steamship Corp Address, Franklin Wharf

" " Contractor, Fred Hellier " 20 Turner

" " Architect _____ " _____

Description of Present Bldg.

Material of Building is wood Style of Roof, pitch Material of Roofing, shingles

Size of Building is 60 ft feet long; 25ft feet wide. No. of Stories, 2

Cellar Wall is constructed of piers is _____ inches wide on bottom and batters to _____ inches on top.

Underpinning is _____ is _____ inches thick; is _____ feet in height.

Height of Building 25ft Wall, if Brick; 1st, _____ 2d, _____ 3d, _____ 4th, _____ 5th, _____

What was Building last used for? junk shop No. of Families? _____

What will Building now be used for? demolish

DETAIL OF PROPOSED WORK

to demolish building all to comply with the building ordinance

Estimated Cost \$ 100.

IF EXTENDED ON ANY SIDE

Size of Extension, No. of feet long? _____; No. of feet wide? _____; No. of feet high above sidewalk? _____

No. of Stories high? _____; Style of Roof? _____; Material of Roofing? _____

Of what material will the Extension be built? _____ Foundation? _____

If of Brick, what will be the thickness of External Walls? _____ inches; and Party Walls _____ inches.

How will the extension be occupied? _____ How connected with Main Building? _____

WHEN MOVED, RAISED OR BUILT UPON

No. of Stories in height when Moved, Raised, or Built upon? _____ Proposed Foundations _____

No. of feet high from level of ground to highest part of Roof to be? _____

How many feet will the External Walls be increased in height? _____ Party Walls _____

IF ANY PORTION OF THE EXTERNAL OR PARTY WALLS ARE REMOVED

Will an opening be made in the Party or External Walls? _____ in _____ Story.

Size of the opening? _____ How protected? _____

How will the remaining portion of the wall be supported? _____

Signature of Owner or Authorized Representative Randall M. Allister

Address by Fred Hellier

PERMIT MUST BE OBTAINED BEFORE BEGINNING WORK

66 Commercial St.
36'

FINAL REPORT

1921

Has the work been completed in accordance with this application and plans filed and approved?

Law been violated? Doc. No. of 1st

Nature of violation?

PERMIT GRANTED

February 19, 1921 102

Permit filled out by

Permit number

Location 66 Commercial

Violation removed, w 102

Estimated cost of alterations, etc. \$.

Inspector of Buildings

ELECTRICAL INSTALLATIONS —

Permit Number 09739
Location 42 Commercial St.
Owner City
Date of Permit 4-14-83
Final Inspector 4-28-83
By Inspector Libby
Permit Application Register Page No 144

by _____ by _____
Service called in _____
Closing-in _____
INSPECTIONS: _____
PROGRESS INSPECTIONS: _____

CODE
COMPLIANCE
COMPLETED
DATE 4-28-83
DATE: _____

REMARKS:

Vertical lines for remarks.

923490

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee 170.00 Zone _____ Map # _____ Lot# _____
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: City of Ptd/Casco Bay Parking Garage
Address: _____
LOCATION OF CONSTRUCTION 46 Commercial St
Contractor: Cincinatti Time of Mains
Address: 930 Brighton Ave 04102 Phone # 774-2336 Richard
Est. Construction Cost: _____ Proposed Use: Parking K&K w/booth
Past Use: Parking Garage
of Existing Res. Units _____ # of New Res. Units _____
Building Dimensions L _____ W _____ Total Sq. Ft. _____
Stories: _____ # Bedrooms _____ Lot Size: _____
Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
Explain Conversion Installing toll booth w/handicapp access
attendance

For Official Use Only
Date March 11, 1992 Subdivision: _____
Inside Fire Limits _____ Name _____
Bldg Code: _____ Lot _____
Time Limit _____ Ownership: _____
Estimated Cost: _____

Zoning: Street Frontage Provided: _____
Provided Setbacks: Front _____ Back _____ Side _____ Eide _____
Review Required:
Zoning Board Approval: Yes _____ No _____ Date: _____
Planning Board Approval: Yes _____ No _____ Date: _____
Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
Special Exception _____
Other (Explain) WDA 3-19-92

Foundations:
1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:
1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:
1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:
1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

Ceiling:
1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____
3. Type Ceiling: _____
4. Insulation Type _____ Size _____
5. Ceiling Height: _____

Roof:
1. Truss or Rafter Size _____ Span _____
2. Sheathing Type _____ Size _____
3. Roof Covering Type _____

Chimneys:
Type: _____ Number of Fire Places _____ Date: _____
Signature: _____

Heating:
Type of Heat: _____

Electrical:
Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:
1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:
1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Permit Received By Mary Grestik

Signature of Applicant Richard B. Smith Date March 11, 1992
Richard Smith

CEO's District _____

CONTINUED TO REVERSE SIDE
Ivory Tag - CEO Mr. Leary

White - Tax Assessor

HISTORIC PRESERVATION

1. Not in District nor Landmark.
2. Does not require review.
3. Requires Review.

Approved
Approved with Conditions

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

OCT 14 1983

B.O.C.A. TYPE OF CONSTRUCTION 09-1056

ZONING LOCATION PORTLAND, MAINE Oct. 5, 1983

CITY of PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 40 Commercial Street Fire District #1 [] #2 []
1. Owner's name and address City of Portland Telephone
2. Lessee's name and address Bath Iron Works - 40 Commercial St. 04101 Telephone 761-4829
3. Contractor's name and address Lessee Telephone
Proposed use of building No. of sheets 1
Last use No. families
Material No. stones Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ Appeal Fees \$
FIELD INSPECTOR-Mr. @ 775-5451 Base Fee Late Fee
To install one 2500 gal. oxygen tank above ground, one 1800 gal. Argon Tank, one 12 ton CO2 tank, one 3000 gal. Apache tank. TOTAL \$ 100.00

Stamp of Special Conditions

Also, removable tube trailer Helium 55,000 Cubic Feet.

MAIL PERMIT TO 700 WASHINGTON ST., BATH, ME. 04530 - BATH IRON

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber-Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max on centers
Studs (outside walls and ceiling partitions) 2x4-16" O. C Bridging in every floor and flat roof span over 8 feet.
Joists and rafters 1st floor 2nd 3rd roof
On centers 1st floor 2nd 3rd roof
Maximum span 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY

DATE

MISCELLANEOUS

BUILDING INSPECTION-PLAN EXAMINER Will work require disturbing of any tree on a public street? NO
ZONING
BUILDING CODE Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES
Fire Dept
Health Dept
Other

Signature of Applicant Robert Herman Phone #
Type Name of above Robert Herman, for Bath Iron Works 1 [] 2 [] 3 [] 4 []
Other and Address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY


J M 3. 11/89

Permit No. 83/2056
Location 40 Commercial St.
Owner City of Portland
Date of permit 10-6-83
Approved 10-14-83
Dwelling _____
Garage _____
Alteration 2 Tenets


NOTES

*11/23/83 Harvey A. ...
1/13/84 ...*

Proposed location of
3-1000 gal Propane Tanks
For Temp Heat
MAINE STATE Pier
By MAINGAS
Nu Wincham



Comm. ST



Provide
Barricade
around Tanks

JPC

RECEIVED
OCT 13 1982
DEPT. OF BLDG. INSP.
CITY OF PORTLAND

Dr. RA Smith

Comm. ST

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP B.O.C.A. TYPE OF CONSTRUCTION 00890

OCT 13 1982

ZONING LOCATION PORTLAND, MAINE Oct. 13, 1982

CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION (Maine State Pier) 40 Was. Commercial St. Fire District #1 [] #2 []
1. Owner's name and address Bath Iron Works - same Telephone
2. Lessee's name and address Telephone
3. Contractor's name and address Maingas - Box 1090, North Windham, Me. Telephone 892-6744
Proposed use of building No. of sheets
Last use No. families
Material No. stones Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$
FIELD INSPECTOR - Mr @ 775-5451
Three 1,000 gal. propane bulk storage tanks.
Appeal Fees \$
Base Fee
L
AL \$ 75.00

(ISSUE PERMIT TO #3)

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Weight average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber - Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION - PLAN EXAMINER Will work require disturbing of any tree on a public street?
ZONING.
BUILDING CODE.
Fire Dept. Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?
Health Dept.
Others:

Signature of Applicant Phone #
Type Name of above Bob Smith for Maingas [] [] [] []
Other
and Address

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY

Permit # 82/890

Location 40 West Commercial St.

Owner Garth Iron Works

Date of permit 10-13-82

Approved 10-13-82

Dwelling _____

Garage _____

Alteration 3 purpose bulk storage tanks

NOTES

11/17/82
 11/17/82
 11/17/82
 11/17/82
 11/17/82
 11/17/82
 11/17/82

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION 00919

SEP 8 1983

ZONING LOCATION PORTLAND, MAINE August 31, 1983

CITY of PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B O C A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications.

LOCATION 40 Commercial Street

1 Owner's name and address Bath Iron Works Inc. - same Telephone 761-4850

2 Lessee's name and address Telephone

3 Contractor's name and address Maine Line Fence Co. - 272 Middle Rd. Telephone 829-5549

Cumberland Ctr. No. of sheets

Proposed use of building ribbon wire fence No. families

Last use No. families

Material No stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ Appeal Fees \$

FIELD INSPECTOR - Mr. @ 775-5451 Base Fee \$ 15.00

Late Fee

TOTAL \$ 15.00

To construct ribbon wire fence, existing fence with ribbon on top of fence, fence is to separate land belonging to City of Portland from land belonging to Bath Iron Works. as per plans. 2 sheets of plans.

Stamp of Special Conditions

send permit to # 1 04101

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? NO Is any electrical work involved in this work? NO
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing lumber-Kind Dressed or full size? Corner posts Sills
Size Girders Columns under girders Size Max on centers
Studs (outside walls and carrying partitions) 2x4-16" O C Bridging in every floor and flat roof span over 8 feet
Joists and rafters 1st floor 2nd 3rd roof
On centers 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No cars now accommodated on same lot to be accommodated number commercial car to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed

APPROVALS BY DATE MISCELLANEOUS
BUILDING INSPECTION-PLAN EXAMINER Will work require disturbing of any tree on a public street? NO
ZONING
BUILDING CODE Will there be in charge of the above work a person competent
Fire Dept to see that the State and City requirements pertaining thereto
Health Dept are observed? yes
Others

Signature of Applicant Gary Toppe Phone # same
Type Name of above Gary Toppe for Bath Iron Works 1 2 3 4
Other and Address

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY

Handwritten signature/initials

Permit no 83/919
Location 40 Commercial St.
Owner Bath Iron Works
Date of permit 8-31-83
Approved 9-8-83
Dwelling Nine feet
Garage
Alteration

NOTES

10/29/83
The fence
has been installed along
A width of 9 feet
permitted by the
Main gate house.
M
1783
M

CITY OF PORTLAND, MAINE
Department of Building Inspection



Certificate of Occupancy

LOCATION 40 Commercial Street

Date of Issue January 3, 1984

Issued to Bath Iron Works

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 82-387, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Limiting Conditions: Entire

Ship Repair Facility

This certificate supersedes
certificate issued

Approved:

1-3-84 *Marland Utting*
(Date) Inspector

[Signature]
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

June 3, 1982

Mr. Harold Plummer
Bath Iron Works Corporation
700 Washington Street
Bath, Maine 04530

Re: Maine State Pier - Commercial Street

Dear Sir:

Your building permit to renovate the North and South Sheds (as per plan) of the Maine State Pier, Commercial Street, Portland, Maine is being issued with the following requirements.

1. A manual fire alarm system will be installed.
2. Flow switches on sprinkler to activate evacuation system.
3. Emergency lighting will be installed.
4. Installation of exit signs at proper exits.
5. Provide additional exits between bay #37 and end of south shed.
Exit near bay #37.
6. Provide two (2) hour separation between industrial area (first floor) and office area (second floor).
7. All bath and toilet rooms will be vented of approved non-combustible material with a minimum cross sectional area of $\frac{1}{2}$ square foot and $\frac{1}{3}$ additional square foot for each additional water closet or urinal above two in number. Such ducts shall be of a adequate height and so located as to insure a minimum supply of 2 cubic feet of fresh air per square foot of room area or by a mechanical ventilation system capable of producing a change of air every 12 minutes.
8. Ventilation air for the business area and industrial area will be as per Sections M-1002.0 and M-1003.0 of the 1981 BOCA Basic Mechanical Code.
9. Natural or artificial lighting will be as stated in Section 704.0 and 706.0 of the 1981 Basic Building Code.
10. Plumbing and Electrical permits will be taken out by masters of their trade.

If you have any questions on these requirements, please call this office.

Sincerely,

P. S. Hoffses
Chief of Inspection Services

PSH/jmr

APPLICATION FOR PERMIT

PERMIT ISSU

B.O.C.A. USE GROUP F 00387

Jan 3 1982

B.O.C.A. TYPE OF CONSTRUCTION EXISTING

ZONING LOCATION PORTLAND, MAINE Jan, 20, 1982

CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 40 Commercial Street Fire District #1 #2

1. Owner's name and address Bath Iron Works Corp. - 700 Washington St. Telephone 443-3582

2. Lessee's name and address Bath Telephone

3. Contractor's name and address OWNERS Telephone

Proposed use of building No of sheets

Last use No families

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ 748,000

FIELD INSPECTOR - Mr. @ 775-5451

Appeal Fees \$ 25.00

Base Fee pd 3-5-82 \$ 50.00

Late Fee 4-30-82 \$ 750.00

TOTAL \$ 50.00

Major Site plan review Building permit as per plans

PERMIT ISSUED WITH LETTER Stamp of Special Conditions

Appeal submitted 3-11-82

Contact Harold Plummer at Ext 2595 - 443-3311, any questions, on permit

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber - Kind Trussed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O C Bridging in every floor and flat roof span over 8 feet
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number of cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY

BUILDING INSPECTION - PLAN EXAMINER
ZONING
BUILDING CODE
Fire Dept.
Health Dept.
Others

DATE

MISCELLANEOUS

Will work require disturbing of any tree on a public way?
Plumbing
Will there be in charge of the above work a person competent to see that the City requirements pertaining thereto are observed?

Signature of Applicant Harold Plummer

Type Name of above Bath Iron Works Corp. 1 2 3 4
Harold Plummer Other and Address

FIELD INSPECTOR'S COPY WITH APPLICANT'S COPY WITH LETTER

PERMIT ISSUED OFFICE FILE COPY WITH LETTER

NOTES

Permit No 827387

Location 411 Commercial St.

Owner South Iron Works

Date of permit 1-21-82

Approved 6-3-82

Dwelling

Garage

Alteration Iron Works Garage

7/15/82 Talked with
both foreman they
were cutting equipment
into the south shed
for storage

7/29/82 Inspected with lanes
separating between offices
& factory will be 2-hour
2 layers of 5/8" overlapping. Talked
with George Libby. Mill

8/20/82 South shed fire wall
sheetrock being installed 3/8"
double overlapped studs (metal)
are in place between bay #37 for other
fire wall through roof line. OK
new trussers being installed along
south shed pier. Mill sheetrocking
ceiling along north shed & studs in
place up stairs of north shed.

8-31-82 R. Hill sheetrocking checked
work & building

9-82 checked pres. OK
checked offices &
factory area

CERTIFICATE OF APPROVAL
FOR INTERNAL PLUMBING

THE TOWN/CITY OF Portland

TOWN/CITY CODE
06/070

LPI NUMBER
00723

DATE PERMIT ISSUED
7/7/83
Month Day Year

PERMIT NUMBER
701621C

Installer Name
STANLEY SEIBER

Owner Name
Walter D. Walker

Address
4 W. Commercial St.

- Certificate of Approval Number
1. Owner
 2. Licensed Master Plumber
 3. Licensed Oil Burner
 4. Employee of Public Utility
 5. Manufactured Housing Dealer
 6. Manufactured Housing Mechanic
 7. Limited License

THE INTERNAL PLUMBING INSTALLED PURSUANT TO THE ABOVE CERTIFICATE OF APPROVAL NUMBER HAS BEEN TESTED IN MY PRESENCE, FOUND TO BE FREE FROM LEAKS, AND WAS INSTALLED IN COMPLIANCE WITH THE MUNICIPAL AND STATE PLUMBING RULES.

Signature of Inspector
ERNOLO R. GOODWIN

Date Inspected
NOV 3 - 1983

ORIGINAL - To be sent to: Department of Human Services
Division of Health Engineering

OWNER'S COPY

INTERNAL PLUMBING PERMIT FOR THE TOWN/CITY OF Portland

Town/City Code - 06T - 4 1983 Number

Date Issued

INSTALLER'S

06/070

00723

7/7/83

2737

PERMIT NUMBER
701621P

Address of Where Plumbing is Done
4 W. Commercial St.

Name of Owner
Walter D. Walker

- Installer Code
1. Owner
 2. Licensed Master Plumber
 3. Licensed Oil Burner
 4. Employee of Public Utility
 5. Manufactured Housing Dealer
 6. Manufactured Housing Mech
 7. Limited License

Type of Construction	1. New	3. Addition	5. Replacement of Hot Water Heater	7. Hook-up of Modular Home
	2. Remodeling	4. Remodeling & Addition	6. Hook-up of Mobile Home	8. Other (Specify) <u>7</u>
Plumbing To Serve	1. Single (Res)	3. Mobile Home	5. Commercial	7. Other (Specify) <u>6</u>
	2. Multi-Fam (Res)	4. Modular Home	6. School	
Number of Fixtures or Hook-Ups	Sinks <u>0</u>	Toilet(s) <u>2</u>	Bath(s) <u>0</u>	Lavatories <u>2</u>
	Clothes Washer(s) <u>0</u>	Dish-Washer(s) <u>0</u>	Hot Water Heater(s) <u>1</u>	Floor Drain(s) <u>4</u>
				Shower(s) <u>0</u>
				Urinal(s) <u>0</u>
				Hook-Up(s) <u>0</u>

TOWN'S COPY

JAN 18 1983
JAN 19 1983
MAY 13 1983

IMPORTANT: Note the following conditions:

1. This Permit is non-transferable to another person or party.
2. If construction has not started within 6 months from the Date of Issue, this Permit becomes invalid.

Dept. of Human Services
Div. of Health Engineering

Fixture Fee 25.00
Hook-Up Fee 00.00
Total Fee 25.00

If Double Fee Check Box

Signature of LPI _____

HHE-211 Rev 780

09

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP B.O.C.A. TYPE OF CONSTRUCTION 091056

OCT 14 1983

ZONING LOCATION PORTLAND, MAINE Oct. 6, 1983

CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION ... 40 Commercial Street ... Fire District #1 [] #2 []
1. Owner's name and address City of Portland ... Telephone ...
2. Lessee's name and address Bath Iron Works - 40 Commercial St. 04101 ... Telephone 761-4829 ...
3. Contractor's name and address Lessee ... Telephone ...
Proposed use of building ... No. of sheets 1
Last use ... No. families ...
Material ... No. stories ... Heat ... Style of roof ... Roofing ...
Other buildings on same lot ...
Estimated contractual cost \$... Appeal Fees \$...

FIELD INSPECTOR--Mr. @ 775-5451 Base Fee ... Late Fee ... TOTAL \$ 100.00

To install one 2500 gal. oxygen tank above ground, one 1800 gal. Argon Tank, one 12 ton CO2 tank, one 3000 gal. Apache tank.

Stamp of Special Conditions

Also, removable tube trailer Helium 55,000 Cubic Feet.

MAIL PERMIT TO 700 WASHINGTON ST., BATH, ME. 04530 -- BATH Y&I

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate ... Height average grade to highest point of roof ...
Size, front ... depth ... No. stories ... sand or filled land? earth or rock?
Material of foundation ... Thickness, top ... bottom ... cellar ...
Kind of roof ... Rise per foot ... Roof covering ...
No. of chimneys ... Material of chimneys ... of lining ... Kind of heat ... flue ...
Framing Lumber-- Kind ... Dressed or full size? Corner posts ... Sills ...
Size Girder ... Columns under girders ... Size ... Max. on centers ...
Studs (outside walls and carrying partitions) 2x4-16 O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor ... 2nd ... 3rd ... roof ...
On centers: 1st floor ... 2nd ... 3rd ... roof ...
Maximum span: 1st floor ... 2nd ... 3rd ... roof ...
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot ... to be accommodated ... number commercial cars to be accommodated ...
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION--PLAN EXAMINER Will work require disturbing of any tree on a public street? no
ZONING:
BUILDING CODE: Will there be in charge of the above work a person competent
Fire Dept. to see that the State and City requirements pertaining thereto
Health Dept. are observed? yes
Others.

Signature of Applicant Robert Herman, for Bath Iron Works Phone #
Type Name of above

1

Other and Address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Oct 18, 1982
 Receipt and Permit number A-77820

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 40 Commercial St. Scholas Company trailer
 OWNER'S NAME: Bat's Iron Works ADDRESS: SHOALS FEES

OUTLETS:	Receptacles _____	Switches _____	Plugmold _____	ft. TOTAL _____	_____
FIXTURES: (number of)	Incandescent _____	Flourescent _____	(not strip) TOTAL _____	_____	_____
	Strip Flourescent _____	ft. _____	_____	_____	_____
SERVICES:	Overhead _____	Underground _____	Temporary <u>100</u> TOTAL amperes _____	_____	3.00
METERS: (number of)	_____	_____	_____	_____	.50
MOTORS: (number of)	Fractional _____	_____	_____	_____	_____
	1 HP or over _____	_____	_____	_____	_____
RESIDENTIAL HEATING:	Oil or Gas (number of units) _____	_____	_____	_____	_____
	Electric (number of rooms) _____	_____	_____	_____	_____
COMMERCIAL OR INDUSTRIAL HEATING:	Oil or Gas (by a main boiler) _____	_____	_____	_____	_____
	Oil or Gas (by separate units) _____	_____	_____	_____	_____
	Electric Under 20 kws _____	Over 20 kws _____	_____	_____	_____
APPLIANCES: (number of)	Ranges _____	Water Heaters _____	_____	_____	_____
	Cook Tops _____	Disposals _____	_____	_____	_____
	Wall Ovens _____	Dishwashers _____	_____	_____	_____
	Dryers _____	Compactors _____	_____	_____	_____
	Fans _____	Others (denote) _____	_____	_____	_____
TOTAL _____	_____	_____	_____	_____	_____
MISCELLANEOUS: (number of)	Branch Panels _____	_____	_____	_____	_____
	Transformers _____	_____	_____	_____	_____
	Air Conditioners Central Unit _____	_____	_____	_____	_____
	Separate Units (windows) _____	_____	_____	_____	_____
	Signs 20 sq. ft. and under _____	_____	_____	_____	_____
	Over 20 sq. ft. _____	_____	_____	_____	_____
	Swimming Pools Above Ground _____	_____	_____	_____	_____
	In Ground _____	_____	_____	_____	_____
	Fire/Burglar Alarms Residential _____	_____	_____	_____	_____
	Commercial _____	_____	_____	_____	_____
	Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	_____	_____	_____	_____
	over 30 amps _____	_____	_____	_____	_____
	Circus, Fairs, etc. _____	_____	_____	_____	_____
	Alterations to wires _____	_____	_____	_____	_____
	Repairs after fire _____	_____	_____	_____	_____
	Emergency Lights, battery _____	_____	_____	_____	_____
	Emergency Generators _____	_____	_____	_____	_____
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	_____	_____	_____	_____	_____
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	_____	_____	_____	_____	_____
	INSTALLATION FEE DUE: _____	_____	_____	_____	_____
	DOUBLE FEE DUE: _____	_____	_____	_____	_____
	TOTAL AMOUNT DUE: _____	_____	_____	_____	3.50

INSPECTION: Will be ready on _____, 19__; or Will Call _____
 CONTRACTOR'S NAME: Louis Manning
 ADDRESS: 108 Brighton Avenue
 TEL.: 775-1613
 MASTER LICENSE NO.: 00775 SIGNATURE OF CONTRACTOR: Alvin E. Meyer dba: Shoals Corp
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date August 24, 19 82
 Receipt and Permit number A 78781

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine.
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
 Maine, the Portland Electrical Ordinances, the National Electrical Code and the following specifications:

LOCATION OF WORK: 40 Commercial St.
 OWNER'S NAME: Northern Utilities ADDRESS: Forest Avenue FEES

OUTLETS:	Receptacles _____	Switches _____	Plugmold _____	ft. TOTAL _____	
FIXTURES: (number of)	Incandescent _____	Flourescent _____	(not strip) TOTAL _____		3.00
	Strip Flourescent <u>16</u> ft.				
SERVICES:	Overhead _____	Underground <u>x</u>	Temporary _____	TOTAL amperes <u>1600</u> ..	7.00
METERS: (number of) <u>1</u> ..					50
MOTORS: (number of)	Fractional <u>7</u> ..				3.50
	1 HP or over <u>3</u> ..				3.00
RESIDENTIAL HEATING:	Oil or Gas (number of units) _____				
	Electric (number of rooms) _____				
COMMERCIAL OR INDUSTRIAL HEATING:	Oil or Gas (by a main boiler) _____				
	Oil or Gas (by separate units) _____				
	Electric Under 20 kws _____	Over 20 kws _____			
APPLIANCES: (number of)	Ranges _____	Water Heaters _____			
	Cook Tops _____	Disposals _____			
	Wall Ovens _____	Dishwashers _____			
	Dryers _____	Compactors _____			
	Fans _____	Others (denote) _____			
	TOTAL _____				
MISCELLANEOUS: (number of)	Branch Panels <u>1</u> ..				1.00
	Transformers <u>1</u> ..				2.00
	Air Conditioners Central Unit _____				
	Separate Units (windows) _____				
	Signs 20 sq. ft. and under _____				
	Over 20 sq. ft. _____				
	Swimming Pools Above Ground _____				
	In Ground _____				
	Fire/Burglar Alarms Residential _____				
	Commercial _____				
	Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____				
	over 30 amps _____				
	Circus, Fairs, etc. _____				
	Alterations to wires _____				
	Repairs after fire _____				
	Emergency Lights, battery _____				
	Emergency Generators _____				
		INSTALLATION FEE DUE:			
	FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	DOUBLE FEE DUE:			
	FOR REMOVAL OF A "STOP ORDER" (304-16.b)	TOTAL AMOUNT DUE:			20.00

INSPECTION.
 Will be ready on _____, 19 ____; or Will Call _____
 CONTRACTOR'S NAME: Gerald A. Ross
 ADDRESS: 23 Berwick Rd. Long Meadow, Mass.
 TEL: 413-567-6348
 MASTER LICENSE NO.: 4756 SIGNATURE OF CONTRACTOR: [Signature]
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Nov. 10 82
 Receipt and Permit number A-92383

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 40 Commercial St.
 OWNER'S NAME: Bath Iron Works ADDRESS: State Pier

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____	
FIXTURES: (number of)	
Incandescent _____ Flourescent _____ (not strip) TOTAL _____	
Strip Flourescent _____ ft. _____	
SERVICES:	
Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____	
METERS: (number of) _____	
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) <u>3</u> _____	6.00
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____	Water Heaters _____
Cook Tops _____	Disposals _____
Wall Ovens _____	Dishwashers _____
Dryers _____	Compactors _____
Fans _____	Others (denote) _____
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT _____	INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____	DOUBLE FEE DUE:
	TOTAL AMOUNT DUE: 6.00

INSPECTION:
 Will be ready on 30x, 19 ; or Will Call _____
CONTRACTOR'S NAME: L & L Electric
ADDRESS: RFD # 2 P. O. Box 283 Gorham
TEL: 892-6217
MASTER LICENSE NO.: 02459 **SIGNATURE OF CONTRACTOR:** *[Signature]*
LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

Permit Number 92383
Location 40 Commercial St.
Owner BIW
Date of Permit 11-10-82
Final Inspection 12-6-82
By Inspector Libby
Permit Application Register Page No 132

by _____ by _____
Service called in _____
Closing-in 11-10-82
12-6-82

INSPECTIONS: _____
PROGRESS INSPECTIONS: _____

CODE COMPLIANCE COMPLETED
DATE 12-6-82
REMARKS _____

**CERTIFICATE OF APPROVAL
FOR INTERNAL PLUMBING**

THE TOWN/CITY OF _____

TOWN/CITY CODE: [0117] LPI NUMBER: [00123] DATE PERMIT ISSUED: [11/18] 67550 IC
Month Day Year
 Certificate of App. Number

Installer's Name: [S. COZZI]

**CERTIFICATE OF APPROVAL
FOR INTERNAL PLUMBING**

THE TOWN/CITY OF Randolph

TOWN/CITY CODE: [0117] LPI NUMBER: [00123] DATE PERMIT ISSUED: [11/9/83] 67550 IC
Month Day Year
 Certificate of App. Number

Installer's Name: [S. COZZI] P.I. M.I. [DW] Installer Code: [2]

Owner: Ernie James W. Jones

Address: 40 Commercial St. Subdivision: _____

- 1. Owner
- 2. Licensed Master Plumber
- 3. Licensed Oil Burner
- 4. Employee of Public Utility
- 5. Manufactured Housing Dealer
- 6. Manufactured Housing Mechanic
- 7. Unpaid License

THE INTERNAL PLUMBING INSTALLED PURSUANT TO THE ABOVE CERTIFICATE OF APPROVAL NUMBER HAS BEEN TESTED IN MY PRESENCE FOUND TO BE FREE FROM LEAKS AND WAS INSTALLED IN COMPLIANCE WITH THE MUNICIPAL AND STATE PLUMBING RULES.

Signature of LPI: [Signature]

OWNER'S COPY

Date Inspected: SEP 22 1983
 ORIGINAL - To be sent to: Department of Human Services
 Division of Health Engineering

Type of Construction	1 New	3 Addition	5 Replacement of Hot Water Heater	7 Hook-up of Modular Home
	2 Remodeling	4 Remodeling & Addition	6 Hook-up of Mobile Home	8 Other (Specify) [7]
Plumbing To Serve	1 Single (Res)	3 Mobile Home	5 Commercial	7 Other (Specify) [5]
	2 Multi-Fam (Res)	4 Mod-vlar Home	6 School	
Number of Fixtures or Hook-Ups	Sink(s) [7]	Toilet(s) [12]	Bathtub(s) []	Lavatory(s) []
	Shower(s) []	Urinal(s) []	Hot Water Heater(s) [1]	Floor Drain(s) [4]
	Clothes Washer(s) []	Dish Washer(s) []	Hook-Ups []	

TOWN'S COPY
 DEC 10 1982
 JAN 3 - 1983
 JAN 19 1983
 MAY 13 1983

IMPORTANT NOTE: This permit is non-transferable to another person or party.

1. This Permit is non-transferable to another person or party.

2. If construction has not started within 6 months from the date of issue, this Permit becomes void.

JUN 9 - 1983
 Dept. of Human Services
 Div. of Health Engineering

JUL 18 1983

Signature of LPI _____

Future Fee []
 Hook-Up Fee []
 Total Fee []
 Double Fee Check Box

MHE-211 Rev. 7/80



APPLICATION FOR PERMIT

PERMIT ISSUED
SEP 8 1983
CITY of PORTLAND

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION 00919
ZONING LOCATION PORTLAND, MAINE August 31, 1983

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B O C A Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications

LOCATION 40 Commercial Street
1 Owner's name and address Bath Iron Works Inc. - same Fire District #1 #2
2 Lessee's name and address Telephone 761-4350
3 Contractor's name and address Maine Line Fence Co. - 272 Middle Rd., Telephone 829-5549
Cumberland Ctr.
Proposed use of building ribbon wire fence No of sheets
Last use No families
Material No stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$
Appeal Fees \$
FIELD INSPECTOR--Mr Base Fee \$ 15.00
@ 775-5451 Late Fee
TOTAL \$ 15.00

To construct ribbon wire fence, existing fence with ribbon on top of fence, fence is to separate land belonging to City of Portland from land belonging to Bath Iron Works.
as per plans. 2 sheets of plans.

Stamp of Special Conditions

Send permit to # 1 04101
NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals

DETAILS OF NEW WORK

Is any plumbing involved in this work? No Is any electrical work involved in this work? No
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max on centers
Studs (outside walls and carrying partitions) 2x4-16" O C Bridging in every floor and flat roof span over 8 feet
Joists and rafters 1st floor 2nd 3rd roof
On centers 1st floor 2nd 3rd roof
Maximum span 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY DATE MISCELLANEOUS
BUILDING INSPECTION--PLAN EXAMINER Will work require disturbing of any tree on a public street? no
ZONING
BUILDING CODE. Will there be in charge of the above work a person competent
Fire Dept to see that the State and City requirements pertaining thereto
Health Dept are observed? yes
Others

Signature of Applicant Phone # same
Type Name of above Gary Toppi for Bath Iron Works 226
1 2 3 4
Other and Address



FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date April 14 1983
 Receipt and Permit number 09739

To the CHIEF ELECTRICAL INSPECTOR, Portland, Me.:
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
 Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:
 LOCATION OF WORK: 42 Commercial St. - Portland Ship Chandlery
 OWNER'S NAME: City of Portland, Me. ADDRESS: _____

OUTLETS:
 Receptacles 3 Switches _____ Plugmold _____ ft. TOTAL 3
 FIXTURES: (number of)
 Incandescent 2 Fluorescent _____ (not strip) TOTAL 2
 Strip Fluorescent _____ ft. _____

FEES

SERVICES:
 Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____
 METERS: (number of) _____
 MOTORS: (number of) _____

Fractional _____
 1 HP or over _____

RESIDENTIAL HEATING:
 Oil or Gas (number of units) _____
 Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING:
 Oil or Gas (by a main boiler) _____
 Oil or Gas (by separate units) _____
 Electric Under 20 kws _____ Over 20 kws _____

APPLIANCES: (number of)
 Ranges _____ Water Heaters _____
 Cook Tops _____ Disposals _____
 Wall Ovens _____ Dishwashers _____
 Dryers _____ Compactors _____
 Fans _____ Others (denote) _____
 TOTAL _____

MISCELLANEOUS: (number of)
 Branch Panels _____
 Transformers _____
 Air Conditioners Central Unit _____
 Separate Units (windows) _____
 Signs 20 sq. ft. and under _____
 Over 20 sq. ft. _____
 Swimming Pools Above Ground _____
 In Ground _____
 Fire/Burglar Alarms Residential _____
 Commercial _____
 Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____
 over 30 amps _____
 Circus, Fairs, etc. _____
 Alterations to wires _____
 Repairs after fire _____
 Emergency Lights, battery _____
 Emergency Generators _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE
 TOTAL AMOUNT DUE: 6.00

INSPECTION:
 Will be ready on _____, 19__; or Will Call xxx
 CONTRACTOR'S NAME: Seacoast Elec
 ADDRESS: Leavitt St. Long Island
 TEL.: _____
 MASTER LICENSE NO.: 3088 SIGNATURE OF CONTRACTOR: [Signature]
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

023490 023490

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee 170.00 Zone _____ Map # _____ Lot# _____
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: City of Pld/Casco Bay Parking Garage
Address: _____
LOCATION OF CONSTRUCTION 46 Commercial St
Contractor: Cincinnati Time of Mngt
Address: 930 Brighton Ave 04102 Phone # 774-2336 Richard
Est. Construction Cost: _____ Proposed Use: Parking K&E w/booth
Past Use: Parking Garage
of Existing Res. Units _____ # of New Res. Units _____
Building Dimensions L _____ W _____ Total Sq. Ft. _____
Stories: _____ # Bedrooms _____ Lot Size: _____
Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
Explain Conversion R Installing toll booth w/handicapp access
attendance

PERMIT ISSUED
For Official Use Only
Date: March 11, 1992 Subdivision: _____
Inside Fire Limits: _____
Bid Code: _____
Time Limit: _____
Estimated Cost: _____
Ownership: _____
CITY OF PORTLAND

Zoning: _____
Street Frontage Provided: _____
Provided Setback: Front _____ Back _____ Side _____
Review Required:
Zoning Board Approval: Yes _____ No _____ Date: _____
Planning Board Approval: Yes _____ No _____ Date: _____
Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
Special Exception _____
Other (Explain) WDA 3-19-92

HISTORIC PRESERVATION
1. Ceiling Joists Size: _____ Spacing _____ Not in District nor Landmark
2. Ceiling Strapping Size _____ Spacing _____ Does not require review
3. Type Ceilings: _____ Requires Review
4. Insulation Type _____ Size _____
5. Ceiling Height: _____

Roof:
1. Truss or Rafter Size _____ Span Action: Approved
2. Sheathing Type _____ Size _____ Approved with Conditions
3. Roof Covering Type _____

Chimneys:
Type: _____ Number of Fire Places _____ Date: 3/13/92
Signature: [Signature]

Heating:
Type of Heat: [Signature]

Electrical:
Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:
1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:
1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Foundation:
1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:
1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:
1. Studding Size _____ Spacing _____
2. No. window _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:
1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall _____
5. Other Materials _____

White - Tax Assessor:

Permit Received By: Mary Gresik
Signature of Applicant: Richard B. Smith Date: March 11, 1992
Signature: Richard Smith
CEO's Dist: _____
CONTINUED TO REVERSE SIDE
[Signature]
[Signature]
[Signature]
Ivory Tag - CEO

PLOT PLAN



FEES (Breakdown From Front)
 Base Fee \$ _____
 Subdivision Fee \$ _____
 Site Plan Review Fee \$ _____
 Other Fees \$ _____
 (Explain) _____
 Late Fee \$ _____

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS *3-30-91 2nd final stage of road 4-27-91 2nd final complete*

CERTIFICATION

Thereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as has authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

Richard Smith *930 Brighton Ave Portland Me* *774-2336*
 SIGNATURE OF APPLICANT ADDRESS PHONE NO.
Richard Smith *President Cincinnati Time Recorder of Me* *774-2336*
 RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE NO.

Cincinnati Time Recorder
930 Brighton Ave. Terrace
Portland, ME 04102
(207) 774-2335

March 11, 1992


City of Portland
Building Code Dept.
City Hall
Portland, ME 04101

Attached please find the plans for the parking attendants handicapped booth and the concrete ramp to provide wheelchair access and egress to the booth. The booth will be slightly larger than the current booth but will fit in the same area. The booth and ramp are all within the garage itself and thus should be treated as an interior renovation. The work is scheduled to begin on March twenty third and is a city project coordinated by Tom Velieux of the waterfront.

Thank You



Richard Smith




HANDICAP ACCESSIBILITY NOTES:
 --DOOR THRESHOLD 1/2" MAX.
 (RAMP TO UNDERSIDE OF THRESHOLD)
 --DOOR OPENING PRESSURE, 5#
 --DOOR CLEAR OPENING, 32" MIN.


A
 PLAN VIEW

THIS BUILDING WILL BE MANUFACTURED IN ACCORDANCE WITH PORTA-KING'S STANDARD SPECIFICATIONS FOR DURALUMINUM BUILDINGS (SEE ATTACHED FOR COMPLETE SPECIFICATIONS).

- ①-100 AMP 6-12 CIRCUIT LOAD CENTER
- ②-115V DUPLEX OUTLET (IN SHELF)
- ③-230V OUTLET
- ④-230V 11000 C/11000 H BTU HVAC
- ⑤-80 WATT SURFACE MOUNT LIGHT
- ⑥-40 WATT SURFACE MOUNT LIGHT
- ⑦-22" DEEP SHELF, PER DRAWING (32" A.F.F.)
- *1- HANDICAP WATER CLOSET
- *1- HANDICAP LAVATORY W/FAUCET
- * GRAB BARS FOR RESTROOM (34" A.F.F.)
- * ADDITIONAL THERMAL INSULATION (R-10)
- * VINYL TILE FLOOR (MEDIUM BEIGE)
- * 2- CASHIER WINDOWS (LOCK 54" A.F.F.)
- * 2- 3-WAY LIGHT SWITCHES
- * 1- LIGHT SWITCH



WALL SECTION DETAIL



ELEVATION A

PORTA-KING BUILDING SYSTEMS 4133 SHORELINE DRIVE EARTH CITY, MISSOURI 63045 1-800-BUILDING 314-291-4200 FAX 314-291-2857		
TITLE CINCINNATI TIME RECORDER OF MAINE, INC.		MODEL 18676DSL
JOB NO. 5274	DRAWN BY KCD	SHEET 1 OF 1
SCALE	DATE 3-2-92	

DURALUMINUM SPECIFICATIONS
Section 13120

1. SCOPE

1.1 Furnish model 18676DSL without weatherproof roof as manufactured by Porta-King Building Systems, St. Louis, Mo., or preapproved equal conforming to the following specifications. Building to ship completely assembled.

1.2 Related work not included in this section:

- Electrical service supply and connection as specified under Electrical Section;
- Foundation work;
- Unloading, placement, anchoring are specified under Carpentry Section.

2. SHOP DRAWINGS

2.1 Submit three (3) copies of shop drawings for approval prior to fabrication.

3. MATERIALS

3.1 PRODUCT CONSTRUCTION

Building to be of aluminum construction, with natural satin anodized aluminum exterior surfaces. Building height to be 87 7/8" (interior use).

3.1.1. Fasteners used to manufacture and assemble buildings to be corrosion-proof type and to permit on-site replacement of damaged components. Welded fabrication is not acceptable.

3.2 STRUCTURAL FRAMEWORK

Structural members to be extruded aluminum angles, channels, and tee sections of structural alloy 6063T6, anodized 204R1, with ribbed pattern exterior surfaces.

3.3 WALL PANELS

Wall panels to be 5/8" high-impact resistant and expansion resistant insulating REDEX board with 1" thick polyisocyanurate insulation, wall thickness of 2". (R-10)

3.4 FINISH

Anodized aluminum, diamond embossed sheet permanently laminated to exterior side. Interior to have vinyl walnut wood grain surface.

3.5 FLOOR STRUCTURE

Floor structure to be an integral part of the building with 1 1/2" solid waterproof insulating core fit tight against wall panels and fastened to bottom structural base frame. Building to have commercial grade vinyl tile standard in a medium-beige color.

DURALUMINUM SPECIFICATIONS
Section 13120

3.6 CEILING

Ceiling panel to be 3/4" thick high impact resistant, moisture resistant, and expansion resistant insulating REDEX board with 1" thick polyisocyanurate insulation. White vinyl permanently laminated to interior side, and plastic protective sheet laminated to upside. (R-10)

3.7 DOORS

Sliding doors to be of anodized aluminum, 1 3/4" tubular construction, half-glazed with clear tempered safety glass. Bottom portion to include panel finish to match interior and exterior building walls.

3.7.1. Sliding door to be ceiling suspended in overhead track assembly and shall be fully weatherstripped. Sliding door shall incorporate a maximum security laminated hook bolt deadlock with removable cylinders.

3.8 WINDOWS

Windows shall have anodized aluminum frames and inserts and to be industrial quality with active window panel to slide horizontally on stainless steel, ball-bearing rollers (plastic rollers are not acceptable). Windows to include inside positive locking device. Exterior window sill height to be 38" (inside sill height 34" from finished floor).

3.9 GLASS-GLAZING

Glass in sliding windows and doors to be 1/8" clear tempered safety glass. Fixed windows to be glazed with 1/4" clear annealed glass.

3.10 SHELF

Furnish 22" deep, full-width shelf, per plans, 32" from finished floor and with walnut wood grain plastic laminate to match interior walls.

3.11 ELECTRICAL SERVICE

Electrical service to include single phase, 100 amp capacity load center, pre-wired in conduit, with one 230V circuit and four 115V circuit capacity (2 spare circuits). Furnish (3) duplex 115V outlets and one 230V outlet. Electric work to be in conformation with the National Electric Code and to bear the I.B.E.W. Union Label.

3.11.1. Lights to be fluorescent type fixture with acrylic lens (tubes to be furnished by others)-20, 40, 80 watt, as shown on drawings.