

(COPY)

CITY OF PORTLAND, MAINE  
Department of Building Inspection



# Certificate of Occupancy

LOCATION 45 Water St.

Date of Issue September 29, 1960

Issued to Burnham & Morrill Company  
45 Water St.

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 60/806, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES  
Entire

APPROVED OCCUPANCY  
Refrigerated Warehouse

Limiting Conditions:

This certificate supersedes  
certificate issued

Approved:

*Carl Smith*  
Inspector

(Date)

*Albert J. Sears*  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

# Capitol Engineering Company

AIR CONDITIONING

VENTILATING

SHEET METAL WORK



2530-A

71-75 ROGERS STREET  
CAMBRIDGE 42, MASSACHUSETTS  
TELEPHONE - TROWBRIDGE 6-2346-7

September 21, 1960

Department of Building Inspection  
City of Portland  
Maine

Attention: Mr. Earle S. Smith  
Field Inspector

Subject: Refrigeration Units - New Building  
Burnham & Morrell Co.  
45 Water Street  
Portland, Maine

Gentlemen:

On September 16, 1960, we filed with your Building Department and received a receipt number 7488-H covering application for permit for refrigeration at above building. We went over this matter with Mr. Sears and requested that the permit be mailed to us in care of The Austin Company, c/o Burnham and Morrell, 45 Water Street, Portland, Maine.

I trust this satisfactorily answers your letter of September 19, 1960.

Very truly yours,

CAPITOL ENGINEERING COMPANY

by C. H. Chaisson  
C. H. Chaisson

CHC:jk  
cc:The Austin Co.  
T.G.Gallagher, Inc.

ALL CONTRACTS AND AGREEMENTS ARE CONTINGENT UPON STRIKES, ACCIDENTS OR OTHER DELAYS BEYOND OUR CONTROL.  
QUOTATIONS GIVEN ARE SUBJECT TO CHANGE WITHOUT NOTICE

BP-35 Water Street

July 21, 1960

Mr. R. R. Campbell, Project Manager  
The Austin Company  
450 West First Avenue  
Roselle, N. J.

Dear Mr. Campbell:

Your letter with plan attached showing fixed ladder on wall of building to give access to roof of refrigerator warehouse under construction for the Burnham and Maxwell Company has been received. The Fire Department has informed me that this arrangement is satisfactory for their purposes and on that basis it will satisfy requirements of the Building Code.

Very truly yours,

AJS/jg

Albert J. Sears  
Inspector of Buildings

45 Water Street

September 19, 1960

Mr. Thomas Gallagher  
c/o Capital Eng. Co.  
Cambridge, Mass.

cc to: The Austin Company  
P.O. Box 1437  
Portland, Maine

Dear Sirs:

It has been brought to the attention of this office that you are responsible for the installation of the "Refrigeration Units" at 45 Water Street, Portland, Maine.

This office will be unable to issue the required certificate of occupancy for this building until this oversight is corrected.

If additional information relative to the above is desired, please phone Inspector Earle Smith at SP. 4-8221, extension 234, any week day but Saturday between 8:00 and 9:00 A.M.

Very truly yours,

Earle S. Smith  
Field Inspector

ESS/js

[REDACTED]

... A ... of ...

...

10/10/10

...

OFFICES IN PRINCIPAL CITIES

# THE AUSTIN COMPANY

ENGINEERS AND BUILDERS

450 WEST FIRST AVENUE • ROSELLE, NEW JERSEY  
CHESTNUT 5-4000



July 15, 1960

W. O. 2296

City of Portland  
Department of Building Inspection  
389 Congress Street  
Portland, Maine

Att: Mr. Albert J. Sears  
Inspector of Buildings

Re: Burnham & Morrill Company  
Portland, Maine

Gentlemen;


We are enclosing herewith for your records one (1) print of our drawing #2, revise dated 7-14-60, showing the floor plan, sections and elevations of the refrigerated warehouse we are constructing for the above company. We have added a fixed access ladder to the roof of the building at the northeast corner. This is in accordance with your letter of June 30, 1960 and as approved on July 12, 1960 by Chief Johnson and Captain Flaherty of the Portland Fire Department.

We trust that this ladder meets with your approval.

Very truly yours,  
THE AUSTIN COMPANY  
W. A. LOUMOS  
District Engineer

*R. R. Campbell*  
R. R. Campbell  
Project Manager

RRC:ac  
Encls.





1-2 INDUSTRIAL ZONE

# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class  
Portland, Maine, July 6, 1960

**PERMIT ISSUED**  
00877  
JUL 12 1960  
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 45 Water Street Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_  
 Owner's name and address Burnham & Morrill Co., 45 Water Street Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address Owner Telephone 2-8341  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans \_\_\_\_\_ No. of sheets \_\_\_\_\_  
 Proposed use of building \_\_\_\_\_ No. families \_\_\_\_\_  
 Last use Smoke house No. families \_\_\_\_\_  
 Material Frame No. stories 1 1/2 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_  
 Estimated cost \$ \_\_\_\_\_ Fee \$ 1.00

### General Description of New Work

To demolish existing 1-1/2 story frame "smoke house" (recently used as storage house)

No sewer connections  
Land to remain vacant

*Provision letter sent 7-6-60*  
It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO Owners**

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing Lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_ Corner posts \_\_\_\_\_ Sills \_\_\_\_\_  
 Size Girder \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

PROVED:

*OR 7/12/60 - ags*

Burnham & Morrill Co.

Signature of owner by: *[Signature]*

INSPECTION COPY

7.6

CITY OF PORTLAND, MAINE  
DEPARTMENT OF BUILDING INSPECTION

Burnham & Morrill Company  
45 Water St.  
Portland Maine

July 6, 1960

Gentlemen:

With relation to permit applied for to demolish a building or portion of building at 45 Water St. it is unlawful to commence demolition work until a permit has been issued from this department.

Section 6 of the ordinance for rodent and vermin control provides: "It shall be unlawful to demolish any building or structure unless provision is made for rodent and vermin eradication. No permit for the demolition of a building or structure shall be issued by the Building Inspector until and unless provisions for rodent and vermin eradication have been carried out under supervision of a pest control operator registered with the Health Department.

The building permit for demolition cannot be issued until the provisions of this section have been satisfied. It is the obligation of owner or demolition contractor or both to take up with the Health Department the matter of complying with this section, being prepared to inform that department what registered pest control operator is to be employed.

Very truly yours,

*Albert J. Sears*

Albert J. Sears  
Inspector of Buildings

AJS/jg

Eradication of this building has been completed.

*J. S. Klein Jr.*

*OK.*  
*7-7-60*





**I-2 INDUSTRIAL ZONE  
APPLICATION FOR PERMIT**

*Class of Building or Type of Structure* 2nd class  
*Portland, Maine,* June 28 1960

**PERMIT ISSUED**

01806  
JUN 30 1960

**CITY of PORTLAND**

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 15 Water St. Within Fire Limits?  Dist. No. \_\_\_\_\_  
 Owner's name and address Burnham & Morrill Co. 45 Water St. Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address The Austin Company, 150 West First Ave. Roselle New Jersey Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 3  
 Proposed use of building Refrigerated warehouse No. families \_\_\_\_\_  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_  
 Material conc. blk. Heat 1 Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot several buildings. Fee \$ 80.00  
 Estimated cost \$ 80,000

**General Description of New Work**

To construct 1-story concrete block and brick (refrigerated warehouse) building 82' x 82' as per plans

Permit Issued with Letter

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** The Austin Co. P.O. Box 1437 Portland Me.

**Details of New Work**

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewerage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Column under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

**If a Garage**

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

**Miscellaneous**

Will work require disturbing of any tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Burnham & Morrill Company  
The Austin Company

by: The Austin Company  
William

Signature of owner

APPROVED:

with letter by agj

Inquiry - 45 Water Street - Burnham & Morrill Warehouse

June 20, 1960

The Austin Company  
450 West First Avenue  
Roselle, New Jersey

cc to: Burnham & Morrill Co.  
45 Water Street

Gentlemen:

Your letter requesting building permit application forms for a new refrigerated warehouse to be constructed in this City for the Burnham and Morrill Company has been received. It is necessary that applications for such a building permit be filed over the counter at this office, the forms being filled out on the typewriter by a permit clerk on the basis of information furnished by the person making application.

Before a permit can be issued, it is necessary that information be furnished indicating compliance with Zoning Ordinance and Building Code requirements. To this end it will be necessary to file a plot plan showing the location of the proposed building as regards street, lot lines and other buildings. The Burnham and Morrill Company property is located in an I-2 Industrial Zone where there are requirements for setbacks from street lines as well as lot lines.

It is further necessary that complete architectural and structural plans of the building be filed for checking against Building Code requirements. A statement of design (blank copy enclosed) covering any structural steel or reinforced concrete is required to be affixed to such plans. Both types of plans should be furnished at the time the application for permit is filed.

If further information concerning requirements is needed, we will furnish it as far as we are able upon request.

Very truly yours,

Albert J. Seart  
Inspector of Buildings

AJS/JG  
Encl.

OFFICES IN PRINCIPAL CITIES

# THE AUSTIN COMPANY

ENGINEERS AND BUILDERS

450 WEST FIRST AVENUE, ROSELLE, N.J.

TELEPHONE CHESTNUT 5-4000

W.O. 2295



June 17, 1960

Inspector of Buildings  
City Hall - Room 21  
Portland, Maine

Re: Burnham and Morrill Company  
Portland, Maine

Gentlemen:

We have been selected to design and construct a refrigerated warehouse for the above named company in your city. Kindly forward us the necessary building permit application forms for this building.


Very truly yours,

THE AUSTIN COMPANY

W. A. LOUMOS  
District Engineer

*R. R. Campbell*  
R. R. CAMPBELL  
Project Manager

REC:rr





FILL IN AND SIGN WITH INK

### APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Dec. 26, 1956

PERMIT ISSUED  
0227  
DEC 28 1956

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 45 Water St. Use of Building \_\_\_\_\_ No. Stories \_\_\_\_\_  
Name and address of owner of appliance Burnham Morrill Co., 45 Water St.  New Building  
Existing   
Installer's name and address Fels Co., 42 Union St. Telephone 2-1939

#### General Description of Work

To install 3 oil-burning equipment ~~and~~ with high pressure steam boiler

#### IF HEATER, OR POWER BOILER

Location of appliance boiler room Any burnable material in floor surface or beneath?  no  
If so, how protected? \_\_\_\_\_ Kind of fuel?  oil  
Minimum distance to burnable material, from top of appliance or casing top of furnace \*  
From top of smoke pipe \* From front of appliance \* From sides or back of appliance \*  
Size of chimney flue 10 in. dia. Other connections to same flue coal-fired boiler (used for stand-by)  
If gas fired, how vented? \_\_\_\_\_ Rated maximum demand per hour \_\_\_\_\_  
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?  yes

#### IF OIL BURNER

Name and type of burner Babcock & Wilcox Permit Issued with Letter  
Will operator be always in attendance?  yes Does oil supply line feed from top or bottom of tank?  bottom  
Type of floor beneath burner concrete Size of vent pipe \_\_\_\_\_  
Location of oil storage \_\_\_\_\_ Number and capacity of tanks 2-15,000 see separate permit  
Low water shut off \_\_\_\_\_ Make \_\_\_\_\_  
Will all tanks be more than five feet from any flame? \_\_\_\_\_ How many tanks enclosed? \_\_\_\_\_  
Total capacity of any existing storage tanks for furnace burners \_\_\_\_\_

#### IF COOKING APPLIANCE

Location of appliance \_\_\_\_\_ Any burnable material in floor surface or beneath? \_\_\_\_\_  
If so, how protected? \_\_\_\_\_ Height of Legs, if any \_\_\_\_\_  
Skirting at bottom of appliance? \_\_\_\_\_ Distance to combustible material from top of appliance? \_\_\_\_\_  
From front of appliance \_\_\_\_\_ From sides and back \_\_\_\_\_ From top of smokepipe \_\_\_\_\_  
Size of chimney flue \_\_\_\_\_ Other connections to same flue \_\_\_\_\_  
Is hood to be provided? \_\_\_\_\_ If so, how vented? \_\_\_\_\_ Forced or gravity? \_\_\_\_\_  
If gas fired, how vented? \_\_\_\_\_ Rated maximum demand per hour \_\_\_\_\_

#### MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

steam pressure atomizer burners  
no combustible material  
Permit Issued with Letter

Amount of fee enclosed? 3.00 (\$2.00 for one heater, etc., 80 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:  
*Albert*  
with letter by *AGP*

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?  yes

Fels Co., Inc.

Signature of Installer by: *R.C. Dutton*

INSPECTION COPY

MAINE PRINTING CO.

January 20, 1936

15 - 45 Water Street

Fels Company  
42 Union Street

Explosives Bureau & Merrill Co  
45 Water Street  
Mr. Kenneth R. Harrington  
Wellesley Hills, Mass.

Gentlemen:

Permit for installation of a high pressure steam boiler and three oil burners in connection therewith in boiler room of factory at the above location is issued herewith based on plans filed with application for permit. We have been unable to find on the plans any indication of a device for manually stopping the flow of oil to the burners from a convenient point located at a safe distance from them. Such a device is required by NFPA Pamphlet #31, which has been adopted as a standard by the principal officers. This permit is therefore issued on the condition that a device of this nature will be provided at such a location that it can be operated without danger of exposure to an unfriendly fire at the burners or in the boiler room.

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings

AJS/G

1/4/36

Mr. Sutton says that shutting off manually controlled valves in oil supply lines at tanks will create vacuum in supply lines and stop flow of oil to pumps and burners within a very short time. On this point that when we would accept these valves as the general re-note control device. - AJS

Memorandum from Department of Building Inspection, Portland, Maine

45 Water Street - Building permit for alterations to fish house for and by Burnham & Morrill - 11/14/56

Building permit for construction of a two story wood frame addition 10 feet by 10 feet on front of fish house at above location is issued herewith on basis of plan filed November 14, 1956, but subject to following conditions:

1. The 6x6 corner posts are to extend in one length from sills to plates supporting rafters with lapped splices not less than 18 inches long allowed.
2. Weather resistive covering of walls is to be other than roll roofing.
3. Roll roofing as roof is to bear the Class "G" label of Underwriters' Laboratories, Inc.

(Signed) Warren McDonald  
Inspector of Buildings

November 6, 1956

At - 45 Water Street

Copy to Burnham & Morrill Co.  
45 Water Street

Mr. Philip F. Snow  
477 Congress Street

Dear Mr. Snow:-

Examination of plan filed with application for permit for construction of a two story concrete block addition 10 feet by 10 feet on northerly end of fish house at the above location discloses the following questions as to compliance with Building Code requirements:-

1. For how many people will the door in second story opening onto platform of steel stairway be called upon to serve as a means of egress? There is a question as to whether or not this door may not be required to be 3 feet wide instead of the 2 feet 6 inches shown and as to what type of locking hardware is required thereon.
2. If projecting apron at door opening in first story is to be made an integral part of the floor slab as shown, it will need to be supported on a foundation wall extending at least 4 feet below grade.
3. A regular three piece bracket is required for support of the metal platform at second floor level and top fastening is required to be not less than a 3/4-inch diameter bolt extending through the wall of the building.
4. Foundation supporting foot of metal stairway is required to extend at least 4 feet below grade.

Information is needed on a revised plan as to how these details are to be cared for in compliance with Code requirements before a permit for construction of the addition can be issued.

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings

HJS/B



(1) INDUSTRIAL ZONE  
APPLICATION FOR PERMIT

PERMIT ISSUED  
02023  
NOV 15 1956  
CITY OF PORTLAND

Class of Building or Type of Structure Concrete Block  
Portland, Maine, November 5, 1956

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 45 Water St. Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_  
Owner's name and address Burnham & Morrill Co., 45 Water St. Telephone \_\_\_\_\_  
Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
Contractor's name and address OWNERS Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
Architect \_\_\_\_\_ Fish house (processing) No. families \_\_\_\_\_  
Proposed use of building \_\_\_\_\_ " \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use \_\_\_\_\_ No. stories 2 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_  
Material con. block No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_  
Other buildings on same lot \_\_\_\_\_  
Estimated cost \$ 1500. Fee \$ 5.00

General Description of New Work

To construct 2-story ~~wood~~ <sup>wood</sup> addition 10'x10' to fish house as per plan

Permit Issued with Memo.

Philip Snow, 477 Congress St.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO

Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? yes  
Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_ earth or rock?  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Dressed or full size? \_\_\_\_\_ Size \_\_\_\_\_  
Framing lumber—Kind \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_  
Corner posts \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Girders \_\_\_\_\_ Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_ height? \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_

If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes  
Burnham & Morrill Co.

APPROVED:  
with memo by ags

Signature of owner By: Frank C. Capay

INSPECTION COPY



October 10, 1956

AP 45 Water St.—Ventilation for fuel oil storage vault

M. B. Bourne & Sons  
56 Cross St.  
Mr. F. H. Goldsmith, Maintenance Supt.  
Burnham & Merrill Co.  
45 Water St.

Copy to Mr. Kenneth Warrington  
Wellesley Hills, Mass.

Gentlemen:-

Building permit for ventilation system for the oil storage vault  
is issued to M. B. Bourne & Sons, herewith, subject to the following:

1. As usual the details are to be in accordance with the standards  
set up by our Municipal Officers, namely regulations of MBFU for Installa-  
tion of Blower and Exhaust Systems for Lust, Stock and Vapor Removals and  
MBFU Pamphlet #90 Installation of Air Conditioning, Warm Air Heat, Air  
Cooling and Ventilation Systems.

2. The switch to operate the fan is to be located just outside the  
door of the vault and a suitable permanent sign is to be attached close to  
it indicating its use and warning that the vault is to be purged of danger-  
ous vapors by turning on the switch prior to entering the vault.

Very truly yours,

Warren McDonald  
Inspector of Buildings

WMcD/G

Enclosure to M. B. Bourne & Sons: Permit card and copy of application

PAUL R. WYMAN, Pres. and Treas.

**M. B. BOURNE & SON**  
*Established 1860*  
**Sheet Metal and Roofing Contractors**  
Ventilating and Air Conditioning  
56 CROSS STREET, PORTLAND 3, MAINE  
TELEPHONE 2-3907

October 8, 1956

Subject: Burnham & Morrill Co.  
Oil Storage Tank Ventilation

For the above subject job we propose to mount a roof fan on a curb near the center of the roof and drop a duct down to within 6 inches of the floor. Fan will have aluminum wheel and housing making it non-sparking in construction and motor will be mounted outside of air stream, (standard motor). Fan capacity 1500 cfm as noted on construction drawings. Electric wiring by their electrical contractor.

*William Beer*

WESTINGHOUSE AIR CONDITIONING Authorized ENGINEERING CONTRACTOR



(1) DISTRICT ZONE

# APPLICATION FOR PERMIT

01736

OCT 10 1956

Class of Building or Type of Structure \_\_\_\_\_  
Portland, Maine, Oct. 9, 1956

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~construct~~ install the following building ~~structure~~ equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 45 Water St. Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's name and address Burnham & Morrill Co., 45 Water St. Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address M. B. Bourne & Sons, 56 Cross St. Telephone 2-3907  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
 Proposed use of building oil storage tank No. families \_\_\_\_\_  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_  
 Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_ Fee \$ 2.00  
 Estimated cost \$ \_\_\_\_\_

### General Description of New Work

To install ventilation as per <sup>description</sup> ~~plan~~ filed.

INSPECTION NOT COMPLETED  
8/19/57

Permit Issued with Letter

CERTIFICATE OF  
REVISIONS

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO M. B. Bourne & Sons

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_ Size \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated.  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Burnham & Morrill Co.  
M. B. Bourne & Sons

Signature of owner by: [Signature]

INSPECTION COPY

August 24, 1956

AP - 45 Water Street

F. h. Goldsmith, Maintenance Supt.  
Burnham & Morrill Co.  
45 Water Street

Dear Mr. Goldsmith:-

Permit for installation of two 15,000 gallon tanks for storage of No. 6 fuel oil on your property at the above location is issued herewith subject to condition that enclosure is to be provided for tanks as outlined in our letter of August 17, 1956, construction of which is to be covered by a separate permit with application for which will be furnished plans showing full details of the construction and bearing the statement of design of the person responsible for its design.

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings

AJS/G

Robert H. Flaherty, Capt. Fire Department

August 23, 1956

Albert J. Sears, Deputy Inspector of Buildings

Installation of two 15000 gallon storage tanks for No. 6 fuel oil in pit outside building at plant of Burnham & Morrill Company at 45 Water Street.

Word has been received from Mr. Goldsmith of Burnham & Morrill Company that they will provide enclosure for those tanks as outlined in my letter of August 17, 1956, of which you have a copy. Since preparation of plans for the proposed slab may take some time and because they are anxious to get the tanks set as soon as possible, they would like to have permit issued for setting of tanks and will furnish information as to enclosure with application for a separate permit covering that part of the installation. Are you willing to approve the attached permit on this basis? I have seen the tanks and they do bear the Underwriters' Label.

---

Deputy Inspector of Buildings

AJS/G

Attachment: Application, plans and permit card

August 17, 1956

AP-45 Water Street

F. H. Goldsmith, Maintenance Supt.,  
Burnham & Morrill Co.,  
45 Water St.

Copy to Harry W. Marr  
Chief of the Fire Department

Dear Mr. Goldsmith:

Issuance of permit for installation of two 15,000 gallon fuel oil tanks for No. 6 fuel oil in pit outside building at the above location is being withheld pending decision as to protection of tanks. We understand that you would like to leave the tanks exposed to the open air without protection of any kind. However, such an arrangement would be contrary to regulations. We also understand that you would prefer not to bury the tanks in earth or sand. After conference with the Fire Department, it has been decided that the following construction will be acceptable:

1. Construct a masonry wall in opening between wall of tunnel and wall of boiler house and, if access to the space around tank is desired, provide an access door with six inch raised threshold in doorway.
2. Construct a concrete slab designed to support a live load of at least 150 pounds per square foot over the entire area of the pit.
3. If means for access to the space around tanks is provided, install a system of mechanical ventilation by which the space within the enclosure can be purged of any noxious fumes before anyone enters therein to inspect or work on tanks.

We shall be unable to issue a permit for installation of these tanks, until information is furnished that enclosure is to be provided as outlined above or in some other acceptable manner. A plan bearing a signed statement of design of person taking responsibility therefor showing method of support and reinforcement of slab over top of pit, construction and thickness of new section of wall, size and material of door if opening into tank enclosure is to be provided, etc. will need to be furnished before authorization for such work can be given.

Please let us know how you will care for this situation.

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings

AJS/B



# INDUSTRIAL ZONE APPLICATION FOR PERMIT

Class of Building or Type of Structure

Portland, Maine, Aug. 16, 1956

PERMIT ISSUED  
01365  
AJG 24 1956  
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~construct~~ install the following ~~building~~ equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 45 Water St. Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's name and address Burnham Morrill Co., 45 Water St. Telephone 2-8341  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address owner Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Telephone \_\_\_\_\_  
 Proposed use of building \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
 Last use \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ No. families \_\_\_\_\_  
 Material \_\_\_\_\_ Other buildings on same lot \_\_\_\_\_ Roofing \_\_\_\_\_  
 Estimated cost \$ \_\_\_\_\_

### General Description of New Work

To install 2-15,000 gallon fuel oil tanks for No. 6 oil, as per plan.  
Tanks to be in a pit.

Fee \$ 1.00

### CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and for the name of the heating contractor. **PERMIT TO BE ISSUED TO OWNER**  
Sent to Fire Dept. 8/23/56  
Received from Fire Dept. \_\_\_\_\_

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ Thickness \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Girders \_\_\_\_\_ Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: \_\_\_\_\_ On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial carr to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes  
 Burnham Morrill Co.

APPROVED:  
*[Signature]*  
CHIEF OF FIRE DEPT.  
INSPECTION COPY

September 17, 1956

17 - 25 Water Street

Mr. F. H. Goldsmith, Maintenance Dept.  
Bushman & Merrill  
25 Water Street

CC: to Mr. Kenneth K. Warrington  
Wellesley Hills, Mass.

Dear Mr. Goldsmith:

Permit for construction of enclosure over fuel oil tanks being installed at above location is issued herewith based upon plans filed with application for permit, but subject to the following conditions:-

1. Vent pipes are to extend high enough above top of slab over tanks to preclude any possibility of their being blocked by snow.

2. Fill pipes are to extend out through brick wall of enclosure in a location accessible to tank trucks.

3. A separate permit issuable only to the actual installer is required for installation of the system of mechanical ventilation to be installed for purging noxious fumes from the enclosure. Unless the motor operating the fan is to be outside the air stream, it is required to be of a non-sparking type. Either the fan or the fan housing is required to be of non-ferrous metal. The switch operating system is to be located just outside of door to enclosure and a sign indicating its use and warning that system is to be switched on prior to any one's entering the enclosure is to be posted nearby.

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings





INDUSTRIAL ZONE

# APPLICATION FOR PERMIT

Class of Building or Type of Structure  
Portland, Maine, Sept. 12, 1956

PERMIT ISSUED  
01519  
SEP 17 1956  
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~alter~~ ~~construct~~ ~~the~~ following building ~~in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:~~

Location 45 Water St. Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's name and address Burnham Morrill Co., 45 Water St. Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address OWNERS Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 2  
 Proposed use of building \_\_\_\_\_ No. families \_\_\_\_\_  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_  
 Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_  
 Estimated cost \$ 4,500. Fee \$ 5.00

### General Description of New Work

To construct enclosure for fuel oil storage tanks as per plans.

INSPECTION NOT COMPLETED  
8/19/57

Permit Issued with Letter.

CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and at the name of the heating contractor. **PERMIT TO BE ISSUED TO OWNERS**

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for seepage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:  
D. W. Max. R. H. F.  
with letter by GJS

Burnham Morrill Co.

INSPECTION COPY

Signature of owner by: A. H. Goldsmith Mayor

AP - 45 Water Street

July 27, 1956

Mr. F. H. Goldsmith, Maintenance Superintendent  
Burham & Morrill Company  
43 Water Street

Dear Mr. Goldsmith:

Building permit for erection of an outside brick chimney at your plant at the above location is issued herewith based on plans filed with the application for permit.

Installation of the new boiler and oil burning equipment will need to be covered by a separate permit issuable only to the actual installer thereof. If the heating contractor is to be responsible for the installation of the oil tanks, that part of the installation can be covered under the heating permit provided full information is furnished as to their location, labelling, coverage, etc.; otherwise a separate permit will need to be secured by the firm responsible for this installation.

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings

ms/e

# BURNHAM & MORRILL COMPANY



*Pure Food Products*  
PORTLAND 2, MAINE

IN REPLY REFER TO

July 13, 1956

Department of Building Inspection  
Portland  
Maine

Gentlemen:

This is our application for a building permit to construct a radial brick chimney 150' tall by 14' diam. at base on our property at East Deering plant and to have installed an oil fired water tube boiler of 45000# steam capacity in our present boiler room.

Application for a permit covering fuel oil tanks will be made at a later date.

The American Chimney Co., of New York City will construct the chimney and Babcock Wilcox Co. will construct the boiler, various other contractors will install piping, controls etc.

Our engineer is Kenneth R. Warrington, Wellesley Hills, Massachusetts.

Approximate cost ~~\$150,000.00~~ chimney \$20,000.00

Yours very truly,

Burnham & Morrill Co.

Franklyn Goldsmith

Maintenance Superintendent

FG:ra

*Brick Oven* BAKED BEANS - BROWN BREAD - FISHFLAKES - CODFISH CAKES - CLAMS - CLAM CHOWDER  
CLAM JUICE - SUGAR CORN - SUCCOTASH - MAINE CORN RELISH - STRINGLESS BEANS - SHELLED BEANS - SPAGHETTI  
RED KIDNEY BEANS - LIMA BEANS - WELSH RAREBIT - INDIAN PUDDING - PEEZ STEW and other Specialties

BURNHAM & MORRILL COMPANY



July 15, 1956

Department of Building Inspection  
Portland  
Maine

Gentlemen:

This is our application for a building permit to construct a radial brick chimney 150' tall by 14' diam. at base on our property at East Deering plant and to have installed an oil fired water tube boiler of 45000# steam capacity in our present boiler room.

Application for a permit covering fuel oil tanks will be made at a later date.

The American Chimney Co., of New York City will construct the chimney and Babcock Wilcox Co. will construct the boiler, various other contractors will install piping, controls, etc.

Our engineer is Kenneth R. Warrington, Wellesley Hills, Massachusetts.

Approximate cost ~~\$150,000.00~~ chimney \$ 20,000.00

Yours very truly,

Burnham & Morrill Co.

*Franklyn Goldsmith*  
Franklyn Goldsmith

Maintenance Superintendent

F0152

*Brick Oven* BAKED BEANS - BROWN BREAD - FISH FLAKES - CODFISH CAKES - CLAMS - CLAM CHOWDER  
CLAM JUICE - SUGAR CORN - SUCCOTASH - MAINE CORN RELISH - STRINGLESS BEANS - SHELL BEANS - SPAGHETTI  
RED KIDNEY BEANS - LIMA BEANS - WELSH RAREBIT - INDIAN PUDDING - BEEF STEW and other Specialties



(1) INDUSTRIAL ZONE

# APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class

Portland, Maine, July 13, 1956

PERMIT ISSUED

01034

JUL 17 1956

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 45 Water St. Within Fire Limits? no Dist. No. \_\_\_\_\_

Owner's name and address Burnham & Morrill Co., 45 Water St. Telephone \_\_\_\_\_

Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_

Contractor's name and address American Chimney Corp., New York Telephone \_\_\_\_\_

Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 2/1

Proposed use of building food processing (main building) No. families \_\_\_\_\_

Last use " " No. families \_\_\_\_\_

Material brick No. stories 5 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_

Other buildings on same lot \_\_\_\_\_

Estimated cost \$ 20,000. Fee \$ 20.00

## General Description of New Work

To erect outside brick chimney as per plans.

Permit Issued with Letter

CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owners

## Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_

Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_

Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_

Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_

Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_

Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_

Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_

Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_

No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Dressed or full size? \_\_\_\_\_

Framing lumber—Kind \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_

Corner posts \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_

Girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: \_\_\_\_\_

On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot \_\_\_\_\_ to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

## Miscellaneous

Will work require disturbing of any tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Burnham & Morrill Co.

APPROVED:

*with letter by agj*

INSPECTION COPY

Signature of owner by:

*J. H. Alden*



# APPLICATION FOR PERMIT

Class of Building or Type of Structure

Portland, Maine, April 6, 1955

PERMIT ISSUED

APR 11 1955

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair or demolish the following building structure equipment or specifications, if any, submitted herewith and the following specifications:

Location 45 Water St. Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's name and address Burnham Morrill Co., 45 Water St. Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address OWNERS Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Telephone \_\_\_\_\_  
 Proposed use of building \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 3  
 Last use \_\_\_\_\_ Men's and Women's Toilet Rooms & Processing Plant No. families \_\_\_\_\_  
 Material masonry No. stories 2 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ No. families \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_ Roofing \_\_\_\_\_  
 Estimated cost \$ 6,000. Fee \$ 6.00

### General Description of New Work

To construct 1-story masonry addition 12' x 27' on side of existing building to be used for men's and women's toilet rooms as per plans.

Permit Issued with Letter

CERTIFICATE OF OCCUPANCY  
REQUIREMENT

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owners

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? wharf earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? 8" height? 11' 6"

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? no  
 Will there be \_\_\_\_\_ of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Burnham Morrill Co.

APPROVED:

with letter by AGJ

INSPECTION COPY

Signature of owner by: \_\_\_\_\_





(1) INDUSTRIAL ZONE

# APPLICATION FOR PERMIT

Class of Building or Type of Structure Refrigeration  
Portland, Maine, Feb. 16, 1954

PERMIT ISSUED  
00173  
FEB 18 1954  
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE  
The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 45 Water Street  
Owner's name and address Burnham & Morrill Co., 45 Water St. Within Fire Limits? no Dist. No. \_\_\_\_\_  
Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
Contractor's name and address Affiliated Refrigeration Service, 801 Brighton Ave. Telephone \_\_\_\_\_  
Architect \_\_\_\_\_ Telephone \_\_\_\_\_  
Proposed use of building Fish house Specifications Plans yes ED No. of sheets \_\_\_\_\_  
Last use \_\_\_\_\_ No. families \_\_\_\_\_  
Material \_\_\_\_\_ No. stories Heat Style of roof \_\_\_\_\_ No. families \_\_\_\_\_  
Other buildings on same lot \_\_\_\_\_ Roofing \_\_\_\_\_  
Estimated cost \$ \_\_\_\_\_ Fee \$ 2.00

## General Description of New Work

To install refrigeration equipment in fish house at end of wharf  
Freon #12 to be used - compressor and equipment to be on second floor

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO Affiliated Refrigeration Service**

Sent to Fire Dept. 2/18/54  
Rec'd from Fire Dept. 2/18/54

## Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
Framing lumber—Kind \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
Corner posts \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Girders \_\_\_\_\_ Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

## Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

Oliver T. Lubow  
City of Portland

INSPECTION COPY

Signature of owner

Burnham & Morrill  
Affiliated Refrigeration Service

Geo. P. Hewes





AP 45 Water St.

November 16, 1953

Burnham & Morrill Co.  
45 Water Street

Mr. Philip P. Snow,  
477 Congress St.

Gentlemen:

Building permit for construction of a one story addition five feet by 34 feet on the side of the main factory building at 45 Water Street is issued herewith based on the plans filed with the application for permit. Since the addition is to be of Metal Frame Construction while the main building is of First Class Construction, the entire building will have to be classified as Metal Frame Construction after erection of the addition as far as application of requirements of the Building Code is concerned. This will mean that, if and when additions to the building are planned in the future, the allowable area of such additions, unless they are cut off from the present building by separations of four-hour fire resistance, will be limited by the area permissible for Metal Frame Construction rather than that for First Class Construction.

If welding rather than bolting is to be used for fastening the joints in the metal framework and supports for the addition, it is necessary that all such welding shall be performed only by welders who have been certified within one year of the date on which the work is done for welding within the limits of the City of Portland. The permit is issued on the basis that such will be the case.

Very truly yours,

Warren McDonald  
Inspector of Buildings

AJS/H



# APPLICATION FOR AMENDMENT TO PERMIT

**PERMIT ISSUED**

Amendment No. 11

**OCT 30 1953**

Portland, Maine, Oct. 27, 1953

**CITY of PORTLAND**

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE  
The undersigned hereby applies for amendment to Permit No. 53/1884, pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 45 Water St.  
Owner's name and address Burnham & Morrill Co., 45 Water St. Within Fire Limits? no Dist. No. \_\_\_\_\_  
Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
Contractor's name and address Grinnell Co., 275 W. Exchange St., Providence, RI Telephone \_\_\_\_\_  
Architect \_\_\_\_\_ Telephone \_\_\_\_\_  
Proposed use of building warehouse Plans filed yes No. of sheets 1  
Last use \_\_\_\_\_ No. families \_\_\_\_\_  
Increased cost of work \_\_\_\_\_ Additional fee 50

### Description of Proposed Work

To extend sprinkler system to cover entire building as per plan.

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cells \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_  
Framing lumber—Kind \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_  
Corner posts \_\_\_\_\_ Size \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
Girders \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet \_\_\_\_\_  
Joists and rafters: \_\_\_\_\_  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Approved: OK 10/30/53 - age \_\_\_\_\_  
Signature of Owner by E. Luntz \_\_\_\_\_  
Approved: 10/30/53 \_\_\_\_\_  
Inspector of Buildings

INSPECTION COPY



INDUSTRIAL ZONE

# APPLICATION FOR PERMIT

PERMIT ISSUED  
OCT 18 1953  
CITY OF PORTLAND

Class of Building or Type of Structure  
Portland, Maine, Oct. 16, 1953

INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ ~~alter~~ ~~repair~~ ~~demolish~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 45 Water St. Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's name and address Burnham & Morrill Co., 45 Water St. Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address Grinnell Co., 275 W. Exchange St., Providence R. I. Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
 Proposed use of building warehouse No. families \_\_\_\_\_  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_  
 Material masonry \_\_\_\_\_ No. stories 1 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_  
 Estimated cost \$ \_\_\_\_\_ Fee \$ 2.00

### General Description of New Work

To install automatic wet sprinkler system as per plan.  
(Another plan to follow)

Permit Issued with Memo

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO E. N. Sweetser, 38 Green St., Gorham

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16' O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

APPROVED:  
*North memo by AGJ*

### Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Burnham & Morrill Co.  
Grinnell Co.

Signature of owner by: *E. Sweetser*

INSPECTION COPY